

STEADY-STATE AND DYNAMIC BEHAVIOUR
OF COMBINED AND SEPARATE SLUDGE
.CARBON REMOVAL-NITRIFICATION
SYSTEMS

STEADY-STATE AND DYNAMIC BEHAVIOUR
OF COMBINED AND SEPARATE SLUDGE
CARBON REMOVAL-NITRIFICATION
SYSTEMS

BY

PAUL M. SUTTON M.Eng.

A Thesis

Submitted to the School of Graduate Studies
in Partial Fulfilment of the Requirements
for the Degree
Doctor of Philosophy

McMaster University
September 1976

DOCTOR OF PHILOSOPHY (1976)
(Chemical Engineering)

McMASTER UNIVERSITY
Hamilton, Ontario

TITLE : Steady-State and Dynamic Behaviour of
Combined and Separate Sludge Carbon
Removal-Nitrification Systems

AUTHOR : Paul Matthew Sutton
B.A.Sc. (Queen's University)
M.Eng. (McMaster University)

SUPERVISOR : Professor K. L. Murphy

NUMBER OF PAGES : xiii, 374

ABSTRACT

This dissertation examines the degree of nitrification which can be accomplished in combined and separate activated sludge systems over a temperature range of 5^o to 25^oC and a system solids residence time range of 4 to 10 days under both steady and non-steady operating conditions.

Treating municipal sewage under steady flow conditions, it was found that the rate of nitrification was independent of the concentration of filterable TKN or ammonia. Temperature and solids retention time significantly affected filterable TKN removal. The degree of nitrification obtained in both combined and separate sludge systems was comparable.

The parallel pilot plant systems were subjected to a number of non-steady influent conditions. The responses to a pulse change in influent pH and a step-down in temperature indicated that the separate sludge system had a greater capacity to withstand such conditions. Transfer function models, together with time series models, were developed to describe the dynamic responses of the nitrifying systems to changes in influent flow, and organic carbon and inorganic nitrogen concentration. The observed and model results indicated greater effluent filterable TKN variation can be expected from nitrifying systems operated under variable flow and concentration inputs than for variable concentration inputs alone.

ACKNOWLEDGEMENTS

I wish to express my appreciation to Dr. K. L. Murphy for his encouragement and counsel throughout the investigation and writing of this thesis.

I would also like to acknowledge my gratitude to others who contributed time and effort towards the accomplishment of this work.

To Dr. B. E. Jank for his assistance as Head of Biological Processes, Environmental Protection Service, and member of the Supervisory Committee.

To employees of the Environmental Protection Service, Wastewater Technology Centre, particularly Mr. K. Conn and his staff for their analytical support and J. Pries for his assistance during operation of the pilot plant.

To Dr. J. McGregor for his help in sorting out the statistical problems.

To Mr. B. A. Monaghan, a special debt of gratitude for his invaluable assistance during pilot plant operation and preparation of the final manuscript.

To Mrs. Jill Dagg for her diligence in typing the manuscript.

Most importantly, a special thanks to my wife, Joyce, for her support and encouragement throughout the project.

Acknowledgement is also made to McMaster University for their personal financial assistance and to the Environmental Protection Service, Canada Centre for Inland Waters, for their financial support of the project.

TABLE OF CONTENTS

	<u>Page</u>
INTRODUCTION	1
BACKGROUND	7
Principles of Biological Nitrification	7
Microbiology and Biochemistry	7
Reaction Kinetics	8
Environmental Factors	10
Carbon Removal-Nitrification Treatment Alternatives	14
PROCESS MODELLING FOR NITRIFICATION SYSTEMS	16
Pseudo "Steady-State" Modelling	16
Dynamic Modelling	19
Deterministic Dynamic Models	20
Linear Dynamic-Stochastic Models	24
EQUIPMENT AND PROCEDURES	29
Pilot Plant Design and Operation	29
Experimental Plan	31
Pseudo "Steady-State" Experimental Design	33
Non "Steady-State" Experimental Design	33
Sample Preparation and Analyses	37
DISCUSSION OF RESULTS	40
Pseudo "Steady-State" Behaviour	40
Evaluation of Combined and Separate Sludge Systems	40
Temperature and SRT Effects on Nitrification	48
Solids Production	66
Dynamic Behaviour of Nitrification Systems	68
System Response to pH and Temperature Changes	68
System Response to Hydraulic, Organic, and Inorganic Loading Variations	72
System Response to Natural Diurnal Variations in Flow and Concentration	86

TABLE OF CONTENTS (CONT'D)

	<u>Page</u>
CONCLUSIONS	95
RECOMMENDATIONS FOR FUTURE WORK	97
REFERENCES	98
APPENDIX A	105
Deterministic Dynamic Model For the Single-Stage Combined Sludge System	105
Parameter Values For Dynamic Models	109
APPENDIX B	112
Solids Retention Time (SRT) Calculation	112
Analytical Procedures	112
Total Kjeldahl Nitrogen	112
Ammonia	116
Nitrite	116
Nitrate Plus Nitrite	116
Chemical Oxygen Demand (COD)	116
Biochemical Oxygen Demand (BOD)	117
Filterable Organic Carbon (FOC)	117
Suspended Solids	117
Dissolved Oxygen	117
Temperature	117
pH	118
Alkalinity	118
Data Listing - Mode of Operation, Reactor Operating Results, Analyses	118
APPENDIX C	275
Pseudo "Steady-State" Experimental Run Results	275
Genuine Versus Non-Genuine Repeated Results	275
Nitrification Rate and Ammonia Concentration Relationship	275
Effect of NO_3^- -N on Analytical Determination of Filterable Organic Nitrogen	275
Nitrification - HRT Relationship	275

TABLE OF CONTENTS (CONT'D)

	<u>Page</u>
APPENDIX D	288
Mixing Characteristics of Reactors	288
Tanks in Series Model	288
Dispersion Model	289
Mixing Studies	290
APPENDIX E	313
Effect of SRT and Temperature Variables on Nitrification	313
Pseudo "Steady-State" Reparameterized Arrhenius Models	313
APPENDIX F	331
Development of Transfer Function-Noise Models	331
Effect of Altering Sampling Interval on TF-N Models	361
Combined Sludge Effluent TKN TF-N Model For New	361
Sampling Interval	361
Forecasting and Simulation Procedures	363
Forecasting System Response to Impulse Forcings	363
Predicting Responses to Simulated Input Conditions	363
APPENDIX G	371
Abbreviations and Symbols	371

LIST OF TABLES

<u>Table</u>		<u>Page</u>
1	Nitrogen Loadings for the San Francisco Bay Basin	3
2	Raw Wastewater Characteristics	32
3	Experimental Design Levels	34
4	Experimental Design for System Comparison	35
5	Non "Steady-State" Experiments	36
6	Experiment D5 Design Levels	38
7	Experiment D5 Design	39
8	Difference in Effluent Results from Parallel Operating Separate and Combined Sludge Systems	42
9	Difference in Effluent Results from TSC and SSC Sludge Systems	44
10	Temperature - SRT Factorial Design	53
11	Effects of System SRT and Temperature on Filterable TKN Removal in Separate and Combined Sludge Systems	54
12	Effects of System SRT and Temperature on the Unit Rate of Filterable TKN Removal in Separate and Combined Sludge Systems	56
13	Unit Nitrification Rate Variation with Temperature	57
14	Transfer Function-Noise Models Describing Observed Effluent TKN and Nitrate Nitrogen	77
15	Transfer Function-Noise Models for Three Hour Sampling Interval	82
B1	Solids Retention Time Calculations--Runs PSS-21 and -22	113
C1	Pseudo "Steady-State" Experimental Results	276

LIST OF TABLES (CONT'D)

<u>Table</u>		<u>Page</u>
C2	Genuine Versus Non-Genuine Repeated Experiments	282
C3	Combined Sludge System Rate Dependency on Ammonia Concentration	284
C4	Verification of Filterable TKN Removal-SRT-Temperature Relationship	287
D1	Tracer Response Analysis for SSC Sludge Reactor (2/1/75)	291
D2	Tracer Response Analysis for TSC Sludge Reactor (6/1/75)	295
D3	Tracer Response Analysis for FSC Sludge Reactor (8/7/75)	299
D4	Tracer Response Analysis for First Stage of TSS Sludge Reactor (7/1/75)	303
D5	Tracer Response Analysis Computer Program	307
E1	Detailed Effects of System SRT and Temperature on Filterable TKN Removal in Separate and Combined Sludge Systems	314
E2	Detailed Effects of System SRT and Temperature on Unit Rate of Filterable TKN Removal in Separate and Combined Sludge Systems	315
E3	ANOVA for Reparameterized Arrhenius Model for Combined Sludge Unit Rate Results 10 Day SRT	317
E4	ANOVA for Reparameterized Arrhenius Model for Combined Sludge Unit Rate Results 4, 7, and 10 Day SRT with K/K^*	318
E5	ANOVA for Reparameterized Arrhenius Model for Combined Sludge Filterable TKN Removal Results 4, 7, and 10 Day SRT with K/K^*	319
E6	Non-Linear Least Squares Computer Program	320
F1	Transfer Function-Noise Models for Combined Sludge System	332

LIST OF TABLES (CONT'D)

<u>Table</u>		<u>Page</u>
F2	Transfer Function-Noise Models for Separate Sludge System	334
F3	Diagnostic Checking of Final Effluent TKN and NO_3^- -N Models	336
F4	Calculation of Cross Correlations and Impulse Response Weights	337
F5	Transfer Function Model Parameter Determination Program	346
F6	Transfer Function-Noise Model Parameter Determination Program	350
F7	Forecasting Program	364
F8	Program to Determine Transfer Function-Noise Model Predictions for Simulated Input Conditions	369

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	Separate and Combined Sludge Carbon Removal-Nitrification Systems	5
2	Effect of pH on Nitrification Rate	11
3	Effect of Temperature on Nitrification Rate	13
4	Model Relationships for Single-Stage Combined Sludge System	23
5	Suspended and Supported Growth Carbon Removal-Nitrification Pilot Plant	30
6	Filterable TKN Removal in Combined and Separate Sludge Systems	41
7	Nitrate Plus Nitrite Nitrogen Production in Combined and Separate Sludge Systems	45
8	Effluent Nitrite Nitrogen Concentration from Combined and Separate Sludge Systems	46
9	Alkalinity Consumption in Combined and Separate Sludge Systems	47
10	Clarifier Effluent Suspended Solids from Carbon Removal-Nitrification Systems	49
11	Filterable Organic Nitrogen from Carbon Removal-Nitrification Systems	50
12	Non-Filterable Effluent TKN from Carbon Removal-Nitrification Systems	51
13	Unit Rate of Nitrification in the Combined Sludge System	59
14	Unit Rate of Nitrification in the Separate Sludge System	60
15	Unit Rate of Nitrification in the Separate Sludge Nitrification Reactor	61
16	Nitrification Rates Reported by Various Authors	62
17	Filterable TKN Removal in the Combined Sludge System	63

LIST OF FIGURES (CONT'D)

<u>Figure</u>		<u>Page</u>
18	Filterable TKN Removal in the Separate Sludge System	64
19	Filterable TKN Removal in the Separate Sludge Nitrification Reactor	65
20	Independence of TKN Removal and Hydraulic Residence Time	67
21	Required Solids Wasting in Separate and Combined Sludge Systems	69
22	Response of Carbon Removal-Nitrification Systems to pH Impulse	70
23	Response of Carbon Removal-Nitrification Systems to Temperature Step-Down	71
24	Programmed Influent Series	73
25	Cross Correlation Results for Effluent Filterable TKN	74
26	Cross Correlation Results for Effluent Nitrate Nitrogen	76
27	Observed and Model Results for Effluent TKN and Nitrate Nitrogen	78
28	Observed and Forecasted Response to Impulse Loadings	79
29	Response of Complete Mix and Plug Flow Nitrifying Systems to Impulse Loading Conditions	81
30	Observed Response to Hydraulic Step	83
31	Observed Response to Organic Carbon Step	85
32	Observed Response to Inorganic Nitrogen Step	87
33	Observed Response to Natural Daily Concentration Variation	88
34	Response of Separate Sludge System to D8 Baseline Day Input	90

LIST OF FIGURES (CONT'D)

<u>Figure</u>		<u>Page</u>
35	Predicted Response to Simulated Daily Concentration Variation	91
36	Predicted Response to Simulated Daily Concentration and Flow Variation	93
37	Response of Combined Sludge System to Daily Concentration and Flow Variation	94
C1	Independence of Nitrification Rate and Ammonia Concentration	283
C2	Effect of Oxidized Nitrogen on Filterable Organic Nitrogen Determination	285

INTRODUCTION

The original approach to waste treatment was to provide processes for the removal of settleable solids, the reduction of biochemical oxygen demand (BOD), and the elimination of bacterial contaminants. In recent years, eutrophication problems have focused attention on the requirement for nutrient control; phosphorus or nitrogen are considered to be the nutrients limiting algal production. As phosphorus was identified as the major pollutant, an intensive research program conducted over the past decade, has resulted in the development and full scale evaluation of phosphorus removal processes which are practical and economical.

Recently, research has led to the development of nitrogen removal technology. Deficiencies in process design for nitrogen removal still exist as clearly pointed out in this quotation from the Report of the WPCF Research Committee (1975);

"There have been many studies on the removal of nitrogen from wastewaters, but clear-cut design parameters that permit the application of treatment processes without difficulty have yet to be established. Pilot or large scale studies are now required to demonstrate the efficiency and reliability of available processes and attendant operational problems and their remedy."

Nitrogen control can be divided into two categories. The first involves processes which convert organic and ammonia nitrogen into nitrate nitrogen. The second category involves processes resulting in the complete removal of nitrogen from the wastewater.

The first category normally is termed nitrification and is effective in eliminating many problems associated with organic and ammonia nitrogen. The biochemical oxygen demand (BOD) of municipal wastes will be substantially influenced by the presence of ammonia. The conversion of ammonia to nitrate requires 4.6 parts of oxygen for each part of ammonia nitrogen. Therefore, ammonia in the effluent at concentrations of 20 mg/l as N would give a theoretical nitrogenous oxygen demand of 92 mg/l.

Additional reasons for ammonia nitrogen removal include:

- 1) NH_3 at low concentrations is toxic to fish,
- 2) NH_3 is corrosive to copper fittings,

- 3) NH_3 increases Cl_2 breakpoint requirements and contact time for adequate disinfection, and
- 4) eutrophication problems are associated with high nitrogen effluents.

Nitrogenous compounds enter the aquatic environment from natural and man-induced sources. Natural sources include dustfall, precipitation, nonurban runoff, and biological fixation. The quantities from natural sources can be increased by man's activity. For example, the combustion of fossil fuels can increase rainfall concentrations of nitrogen substantially. Nitrogen sources which can be directly attributed to man's activity include:

- 1) municipal wastewater,
- 2) industrial wastewater,
- 3) runoff from urban areas,
- 4) runoff from livestock feedlots, and
- 5) drainage from agricultural lands.

The significance of each source will vary depending on the population density, the degree of industrial development, and the farming practices in each particular area. An estimate of the nitrogen quantities, from various sources discharged in the San Francisco Bay Basin, California, is given in Table 1. Owing to the high degree of industrialization and large population density, municipal and industrial contributions are most significant.

Nitrogen control can be accomplished by either biological or physical-chemical means. A review of the advantages and disadvantages of a number of control alternatives (Sutton, Murphy, and Dawson, 1974) indicates that biological nitrification-denitrification may be the preferred approach. The popularity of this alternative is evident from the recent IAWPR conference proceedings (1975) entitled "Conference on Nitrogen as a Water Pollutant".

Biological nitrogen removal is essentially a two-step process, nitrification followed by denitrification. In the nitrification step, under aerobic conditions, autotrophic nitrifying organisms oxidize ammonia to nitrate. In the denitrification step, nitrate is reduced to molecular nitrogen by heterotrophic organisms in the absence of molecular oxygen.

TABLE 1 NITROGEN LOADINGS FOR THE SAN FRANCISCO BAY BASIN
(Brown and Caldwell, 1975)

Nitrogen Source	Nitrogen Discharge 1000 kg/yr	Percent of total
Municipal wastewater, before treatment	26,000	49
Industrial wastewater, before treatment	16,000	30
Vessel wastes, before treatment	60	0.1
Dustfall directly on Bay	590	1.1
Rainfall directly on Bay	390	0.8
Urban runoff	1,400	2.7
Non-urban runoff	1,900	3.6
Nitrogen applied to irrigated agricultural land	900	1.7
Nitrogen from dairies and feedlots	6,000	11
Total	53,000	100


Nitrification occurs in the activated sludge process when conditions are suitable for the retention and accumulation of nitrifying bacteria. The solids retention time (SRT), or sludge age, is a measure of the average retention time of the bacterial cells in the system. Successful nitrification depends on adherence to a sludge wasting program which results in an SRT adequate to retain and prevent the wash out of the slower growing nitrifying bacteria. Two basic process schemes available can be designated as:

- 1) a combined sludge system, and
- 2) a separate sludge system.


The combined sludge system may be a single or multi-stage system, while the separate sludge system is normally a two-stage system (Figure 1). In the combined sludge process, simultaneous carbon removal and nitrification are carried out. Provided that the rate of growth of nitrifying bacteria is sufficiently rapid to compensate for the organisms lost through sludge wasting, nitrification can be maintained. Consequently, nitrification depends upon the relationship of the growth rate of the nitrifying bacteria to the net solids production rate for the process. In the separate sludge system, carbon removal is carried out by heterotrophic microorganisms, separate and distinct from the subsequent nitrification step carried out by autotrophs. Thus separate sludge wasting procedures for each removal step can be incorporated.

There are advantages and disadvantages to both the combined and separate sludge systems. A separate system could be expected to offer more stability, less temperature sensitivity, and some buffering capacity to compounds toxic or inhibitory to nitrification. These advantages must be balanced against the possible overall increases in solids production and capital cost.


Parameter values derived from time averaged pseudo "steady-state" (constant flow with normal diurnal variations in organic and inorganic concentrations) data allow prediction of the average effluent concentration of filterable TKN (Sutton, Murphy, Jank, and Monaghan, 1975). This form of analysis may not be sensitive enough to differentiate between the alternative carbon removal-nitrification systems operating under "non-steady" conditions.



TWO-STAGE SEPARATE SLUDGE



SINGLE-STAGE COMBINED SLUDGE



TWO-STAGE COMBINED SLUDGE




FIG. 1 SEPARATE AND COMBINED SLUDGE CARBON REMOVAL - NITRIFICATION SYSTEMS

Nitrification systems, like all activated sludge processes, are dynamic systems subject to time varying loadings and exhibiting a response to their environment which varies with time. Pseudo "steady-state" parameter values are not capable of describing the temporal relationships between inputs and outputs. The stability of the nitrification alternatives can be obtained only by using techniques which elucidate the responses to non-steady operation.

Significant changes in raw wastewater pH are encountered periodically at municipal treatment plants receiving quantities of industrial wastes. Variations in temperature may be anticipated in treatment facilities in continental climates. The reported sensitivity of nitrification to temperature and pH (Wild, Sawyer, and McMahon, 1971) emphasizes the importance of defining the tolerance of such systems to abrupt changes in these factors.

This study has examined, at pilot-scale, the carbon removal and nitrification efficiencies obtained from three differing process configurations - a "single" and "two-stage" combined sludge systems (denoted SSC and TSC respectively) and a two-stage separate sludge system (TSS). The alternatives (Figure 1) were compared as to their effectiveness, in terms of nitrification, under a range of operating temperatures and solids retention times, at pseudo "steady-state" conditions.

Experimental observation, mathematical model building and simulation, and time series analysis are techniques by which the behaviour of dynamic processes can be assessed. In this study, these methods were utilized to compare the alternative carbon removal-nitrification schemes and provide a better understanding of factors affecting nitrification under non-steady conditions.


BACKGROUND

Principles of Biological Nitrification


Microbiology and biochemistry

Biological oxidation of inorganic nitrogen is almost entirely carried out in the aquatic environment by bacteria belonging to the family Nitrobacteraceae. The major well defined autotrophic bacteria which are known to oxidize ammonia to nitrite are the genera Nitrosomonas and Nitrosococcus. The genera Nitrobacter and Nitrocystis have been shown to oxidize nitrite to nitrate. The ability to oxidize inorganic nitrogen is not restricted to autotrophic bacteria. Verstraete and Alexander (1973) have demonstrated that heterotrophic nitrification occurs in soils, in sewage treatment plants, and in river and lake waters. Although a large number of heterotrophs have been identified as nitrifiers (Painter, 1975), heterotrophic nitrification appears to be of much less importance than autotrophic nitrification.

The autotrophic nitrifying organisms derive all their energy requirements for growth and cellular metabolism from the free energy released by the oxidation of an inorganic nitrogen substrate. The source of carbon used for growth is obtained from carbon dioxide or bicarbonate. The bacterial oxidation reactions of ammonia to nitrite and nitrite to nitrate can be represented by the following equations:



In the oxidation of ammonia to nitrite, nitrogen undergoes an oxidation state change from -3 to +3. This suggests that the reaction takes place in three steps since all known biochemical reaction mechanisms transfer one pair of electrons at a time. Kluyver and Donker (1926) postulated a three step sequence according to:



The intermediate, hydroxylamine (NH_2OH), was reported first by Hofman and Lees (1953) and has since been demonstrated as an intermediate by several other researchers. The formation of the second oxidation product, hyponitrite ($\text{H}_2\text{N}_2\text{O}_2$) has not yet been verified. In the oxidation of nitrite to nitrate, the nitrogen atom changes its oxidation state from +3 to +5 suggesting a one step reaction mechanism. No intermediates have been found in this enzymatic oxidation. The difference in free energy released in the oxidation reactions, 65.2 to 84.0 kcal/mole for ammonia oxidation and 17.5 to 24.0 kcal/mole for nitrite oxidation (Gibbs and Schiff, 1960) indicates that nitrite oxidation proceeds through a much simpler mechanism. The chemical energy released is stored or used in the form adenosine triphosphate (ATP). The generation of reducing compounds enables the nitrifiers to reduce carbon dioxide to the oxidation level of cellular components thereby removing the need for an organic carbon substrate as a carbon source.

Reaction kinetics

The growth rate of a bacterial culture is a function of the concentration of some limiting substrate. For many biological systems the Monod kinetic model has been found to represent this growth rate and limiting substrate relationship:

$$u = \frac{u^* S}{K_s + S} \quad , \quad \dots\dots\dots(4)$$

where u = growth rate (T^{-1}),

u^* = maximum growth rate coefficient (T^{-1}),

S = substrate concentration (M/L^3), and

K_s = substrate concentration at one half maximum growth rate (M/L^3).



Downing, Painter, and Knowles (1964), Poduska and Andrews (1975), and Knowles, Downing, and Barrett (1965) used the Monod kinetic model in their rate expressions in analyzing nitrification results. Applying the expression to the ammonia oxidation by Nitrosomonas, the K_s values determined were small (0.2 to 1.7 mg/l NH_4^+ -N, Knowles, Downing and

Barrett, 1975). A greater range of K_s values have been reported for Nitrobacter but generally indicate that the oxidation reaction can be considered independent of NO_2^- -N.

The maximum growth rate coefficient (u^*) represents the mass of organisms produced per unit mass of organisms per unit time when growing at non-limiting substrate concentrations. A wide range of values of the coefficient for both Nitrosomonas (Loveless and Painter, 1968) and Nitrobacter (Boon and Laudelot, 1962) have been reported. The difference in culture conditions (pH, temperature, etc.) may account for the varying results. The substrate utilization rate (K) can be related to the growth rate coefficient by consideration of the yield coefficient (Y):

$$K = \frac{u^*}{Y} \dots\dots\dots(5)$$

Using reported values of actual cell yields and $\text{C}_5\text{H}_7\text{O}_2\text{N}$ as an empirical cell formula for nitrifying bacteria, Haug and McCarty (1972) proposed the following overall mass balances combining nitrification assimilation:



On the basis of the equations, 20 mg of ammonia nitrogen would produce only 3 mg of Nitrosomonas and approximately 0.5 mg of Nitrobacter. These yields are less than 10 percent of that normally observed for heterotrophic bacteria.

The growth of microorganisms may also be expressed in terms of their doubling or generation time (t_d). This coefficient is related to the substrate utilization rate (K) according to:

$$K = \ln 2/t_d Y \quad \dots\dots(8)$$

Substituting appropriate K and Y values it is found that the generation times of the autotrophic nitrifying bacteria are in the range of 10 to 30 hours. Generation times for heterotrophic bacteria are frequently reported as 20 to 40 minutes. In a suspended growth or activated sludge system, a direct consequence of the slow growth rate or long generation time of nitrifiers, is the requirement to provide a sufficient solids retention time (SRT) or sludge age to retain an adequate population of these organisms. Solids retention time is a measure of the average retention time of the bacterial cells in the system. The SRT and the growth rate of organisms in an activated sludge plant are related according to:

$$SRT = \frac{1}{u} \quad \dots\dots\dots(9)$$

SRT is normally defined as the total mixed liquor suspended solids under aeration divided by the daily solids lost in the effluent or through sludge wasting.

Environmental factors

Autotrophic nitrifying organisms are obligate aerobes. Numerous reports indicate that in order to ensure that dissolved oxygen is not a limiting nutrient for nitrification, a level not less than 2.0 mg/l must be maintained (Wuhrmann, 1963, Painter, 1975). The stoichiometric oxygen requirements based on equations 1 and 2 are 3.43 mg oxygen/mg NH_4^+ -N and 1.14 mg oxygen/mg NO_2^- -N. Jeffrey and Morgan (1959) found that oxygen uptake values in BOD tests for nitrification were within 2.5 percent of the theoretical values.

Nitrification, like most bacterial processes, is affected by pH conditions. Generally optimum conditions have been found to exist between pH 8.0 and 9.0 (Figure 2). Variations in pH optima could be due to shock effects in adjusting culture conditions or improper acclimation. Haug and McCarty (1971) using a submerged aerobic filter found that the rate of nitrification at pH 6.0 approached rates at higher pH conditions (7 to 8.5) after an acclimation period of approximately 10 days.




FIG. 2 EFFECT OF pH ON NITRIFICATION RATE

Nitrification is a hydrogen ion producing reaction (equation 1). Since pH values less than 6.0 would likely affect the nitrification rate the alkalinity of the waste¹ is an important consideration. Assuming the pH is less than 8.5, the hydrogen ions produced during nitrification react with the bicarbonate in the wastewater, resulting in an increase in CO₂ concentration and a decrease in bicarbonate alkalinity according to:



Based upon equations 1 and 10, approximately 7 mg of bicarbonate alkalinity, expressed as CaCO₃, are required to neutralize the hydrogen ions produced during the oxidation of 1 mg of NH₄⁺-N. Calculations involving carbonic acid equilibria show that for wastewater with an alkalinity of 200 mg/l as CaCO₃, approximately 20 mg/l of NH₄⁺-N could be oxidized before the pH dropped below 6.0 if all the CO₂ produced remained in solution (Haug and McCarty, 1971). In most nitrifying reactors the CO₂ is stripped from solution tending to help maintain a neutral pH. In operating a rotating biological contactor for carbon (BOD) removal-nitrification of a municipal sewage with moderate alkalinity (approximately 120 mg/l as CaCO₃), Wilson (1975) found that 15 to 20 mg/l NH₄⁺-N were nitrified and the pH was never less than 6.8.

The process of nitrification occurs over a range of approximately 4° to 45°C with optima at about 35°C for Nitrosomonas (Buswell, Shiota, Lawrence, and Meter, 1954) and 35° to 42°C for Nitrobacter (Deppe and Engel, 1960, Laudelot and Van Tichelen, 1960). It has been shown to be strongly dependent on temperature. In a suspended growth nitrification system differences in the reported temperature sensitivity (Figure 3) may be due to differences in reactor SRT. Increasing SRT results in a decrease in the temperature sensitivity. Supported growth systems (trickling filter, rotating biological contactor, etc.), which could be expected to be operating at high SRT's, show reduced temperature sensitivity for nitrification (Wilson, Murphy, Sutton, and Jank, 1975, Huang, and Hopson, 1974).

Nitrifying organisms, especially Nitrosomonas, are susceptible to a number of inhibitors which may be present in municipal and industrial wastewaters. A number of metals are toxic to nitrifiers but the concentration required to cause inhibition is dependent on the state of the culture. Copper,




FIG. 3 EFFECT OF TEMPERATURE ON NITRIFICATION RATE

silver, mercury, nickel, chromium, and zinc all may inhibit nitrification under certain conditions. Downing, Tomlinson, and Truesdale (1964) identified a large number of organic materials which caused a reduction in nitrification rates in suspended growth systems. Thiourea, phenol, phenolic compounds, cresol, and halogenated solvents were some of the potential inhibitors identified. In screening the organic materials as nitrification inhibitors, unacclimated organisms were used and therefore the results may not reflect what actually would occur in a treatment plant.

Substrate and product inhibition has been reported for nitrification. Concentrations greater than 2500 mg/l nitrite-nitrogen have been found to inhibit Nitrosomonas (Meyerof, 1916, Lewis, 1959). At 1400 mg/l nitrite-nitrogen the growth of Nitrobacter has been affected (Boon and Laudelot, 1962). Such conditions are unlikely to be encountered in the treatment of municipal wastewaters but could occur in the treatment of nitrogenous industrial wastes.

Carbon Removal-Nitrification Treatment Alternatives

The process reactors available for carbon removal (BOD) - nitrification can be classified according to the nature of their biological growth. Activated sludge systems can be regarded as suspended growth reactors whereas systems in which growth occurs on, or within a solid media, can be termed supported growth reactors.

The two basic process schemes available for nitrification in the activated sludge process are the combined sludge process and the separate sludge process. In the combined sludge process, carbon removal and nitrification are carried out using the same sludge. In the separate sludge process, the biological reactions are carried out by different microorganisms in separate reactors.

A number of combined and separate sludge treatment plants have recently been designed to provide conditions for carbon removal and nitrification. Design has been based on criteria developed from studies during which wide variations and fluctuations in the nitrification efficiency were obtained. Mulbarger (1971), in the only intensive comparative experimental assessment of a combined and separate nitrification system to date, stated in reference to his experimental results that "Firm design and operational recommendations cannot be made at this time." Based on

daily composite sampling and nearly steady flow of a municipal sewage, he did find that his combined sludge system failed to exhibit the same degree of soluble effluent TKN stability as the separate system. More recently Lawrence and Brown (1973) concluded that nitrified effluents of essentially identical quality could be produced from separate and combined sludge systems based on limited data from a pilot plant study.

Although nitrification has been obtained for many years in combined sludge systems similar to the configurations previously noted (Figure 1), the reported results indicate little more than conditions necessary to achieve nitrification. Furthermore, there are many contradictions in the literature regarding these conditions. Beckman, Avedt, Mulligan, and Kehrberger (1972) utilizing laboratory and full-scale treatment facilities found at 10^o to 18^oC, sludge ages greater than six days were required for optimum nitrification. Wuhrmann (1968) stated that at a temperature above 14^oC, a sludge age of two to three days will yield a stable nitrification system. Prakasam and Loehr (1972) found complete nitrification at sludge ages greater than three days in treating a high nitrogen strength poultry waste at 20^oC.

Several investigations have been made to determine the feasibility of nitrification in the separate sludge system. Wild, Sawyer, and McMahon (1971) studied batch nitrification in the separate sludge unit. A continuous nitrification unit operated under controlled conditions was used to provide sludge to conduct the batch studies on the effects of temperature and pH on the nitrification rate. Barth and Brenner (1968), operating at 185 gpd three-stage N removal pilot plant, obtained an average 87% conversion of reduced nitrogen compounds to nitrate in the separate nitrification stage. Operation was over a temperature range of 12^o to 22^oC and at an average solids retention time of 22 days.

Although optimization of separate sludge systems has not been performed to any great extent, as reflected by the wide variations in efficiency, the high values frequently obtained indicate the potential and encourage further research.

A limited number of supported growth systems have been utilized for carbon removal and/or nitrification including trickling filters, submerged aerobic filters, and rotating biological contactors.

PROCESS MODELLING FOR NITRIFICATION SYSTEMS

Pseudo "Steady-State" Modelling

Process design requires rate data to be expressed as parameters which are useful from an engineering point of view. In order to describe the substrate removal rate in any biological waste treatment process an overall kinetic expression compatible with the fundamentals of microbiology, kinetics, and transport phenomena is necessary.

For a given reaction environment, substrate removal rate is a function of the concentration of substrate (S) and active biological solids (X):

$$\begin{aligned}\frac{dS}{dt} &= f(X,S), \\ \frac{dS}{dt} &= KXS^Z, \dots\dots\dots(11)\end{aligned}$$

where K is the substrate removal velocity, and the unit rate of substrate removal can be expressed as:

$$\frac{dS}{XdT} = KS^Z \dots\dots\dots(12)$$

This normalization procedure has been used by numerous authors (Wuhrmann and Mechsner, 1965, Busch 1971), and in fact forms the basis for most engineering design work in biological treatment. Although strictly empirical the unit rate concept is fundamentally related to biological growth kinetics.

The relationship between substrate removal and biological growth can be expressed by:

$$\frac{dX}{dt} = Y \frac{dS}{dt} \dots\dots\dots(13)$$

where $\frac{dX}{dt}$ = net growth rate of microorganisms (M/T), and
 Y = apparent yield coefficient.

Using the monod kinetic model to represent the kinetics of biological growth:

$$u = \frac{1}{X} \frac{dX}{dt} = \frac{u^*S}{K_s + S} \quad \dots\dots\dots(14)$$

where u = net growth rate (T^{-1}),
 u^* = maximum growth rate coefficient (T^{-1}),
 S = substrate concentration (M/L^3), and
 K_s = substrate concentration at one half maximum growth rate (M/L^3).

Combining equations 13 and 14:

$$\frac{1}{X} \frac{dS}{dt} = \frac{1}{Y} \frac{u^*S}{K_s + S} \quad \dots\dots\dots(15)$$

At low K_s values this expression becomes:

$$\frac{1}{X} \frac{dS}{dt} = \frac{u^*}{Y} = K \quad \dots\dots\dots(16)$$

Under such conditions the model is zero order independent of substrate concentrations. The zero order nature of the nitrification reaction, down to very low NH_4^+ -N values, has been illustrated by numerous researchers (Wild, Sawyer, and McMahon, 1971, Huang, 1973, and Kiff, 1972). It is reasonable to anticipate that the reaction rate will be zero-order with respect to substrate concentration at all practical NH_4^+ -N levels allowing the unit rate of removal to be expressed as a constant.

In order to relate the unit rate of ammonia removal to biological growth kinetics a measure of the active nitrifier population (X) is necessary. Techniques for determination of the autotrophic nitrifier fraction in a heterogeneous biological system are presently being developed (Srinath, Prakasam, and Loehr, 1974). The critical factors affecting the

autotrophic-heterotrophic population dynamics in an activated sludge system are the solids retention time and influent wastewater organic carbon to inorganic nitrogen (C/N) ratio. Combined sludge systems operating under similar environmental conditions (reactor pH, dissolved oxygen and temperature) will contain the same number of nitrifiers at equal SRT's. Combined sludge systems operating under similar environmental conditions will contain the same fraction of nitrifiers at equal SRT's and influent wastewater C/N ratios.

In order to maintain consistent ammonia removal or nitrification under pseudo "steady-state" conditions the fractional increase in Nitrosomonas during aeration must be greater than or equal to the corresponding fractional increase in sludge age. The growth rate of Nitrosomonas and consequent rate of ammonia removal can be strong function of temperature. Knowles, Downing, and Barrett, (1965) claimed that the maximum specific growth rate of Nitrosomonas was increased by approximately 9.5 percent for each degree celcius increase in temperature. For many reactions, the variation of rate with temperature under pseudo "steady-state" conditions may be represented by an Arrhenius relationship. This relationship can be represented as:

$$K = Ae^{-E/RT}, \quad \dots\dots\dots(17)$$

where

- K = reaction rate constant (day^{-1})
- A = frequency factor (day^{-1})
- E = activation energy (cal g-mole^{-1})
- R = universal gas constant ($\text{cal g-mole}^{-1} \text{ } ^\circ\text{K}^{-1}$)
- T = temperature ($^\circ\text{K}$)

Because temperature is a parameter that varies throughout the year in nearly every treatment plant, its effect on nitrification is important. In a particular operating alternative, the solids retention time may have to be significantly increased to compensate for low temperatures (i.e. below 10°C). If a plant does not have this capability, nitrification may be partially or completely lost.

Dynamic Modelling

The effects of fluctuations in many variables on the dynamic behaviour of nitrification alternatives cannot be predicted from pseudo "steady-state" parameter values. A sudden rainfall may result in a hydraulic impulse to a treatment plant. Little insight into the expected profile of recovery and time to return to normal operation would be gained by examination of the pseudo "steady-state" process design parameters.

While dynamic models for the activated sludge processes have been and are being developed (Blackwell, 1971, Smith and Eilers, 1970), these models do not extend to systems for carbon removal-nitrification. In one study, Downing, Painter, and Knowles (1964) used batch nitrification data and computer techniques to model the time dependent results. Lijklema (1973) used a limited amount of steady-state literature data to substantiate his model for nitrification in a single-stage activated sludge process. Poduska (1973) presented the most extensive dynamic study of the nitrification process. Using a synthetic feed and bench scale apparatus, the transient responses of the nitrifying culture were investigated for various dynamic forcings at constant temperature. The dynamic model developed considered only a single-stage system and did not account for the presence of heterotrophic bacteria and subsequent organic carbon degradation.

In assessing the effectiveness of the combined and separate sludge systems under non-steady operating conditions the variables of concern are fluctuations in hydraulic, organic, and inorganic loading, and variations in raw wastewater pH, and the temperature levels. By quantifying the effect of these variables an evaluation of the stability of the nitrification alternatives will be afforded.

The pseudo "steady-state" effect of temperature on many biological systems has often been represented by Arrhenius type expressions. These expressions could not be expected to predict the transitional or short term response to sudden changes in temperature. Similarly the transitional or short term response of biological systems to pH changes could not be expected to be predicted by pseudo "steady-state"

expressions (Downing, and Knowles, 1967). Little or no information exists in the literature regarding transitional responses to changes in temperature and pH, on combined and separate sludge systems operated for carbon removal-nitrification.

When adequate experimental facilities are available, qualitative comparisons can be made between process alternatives. The wastewater feed can be varied in temperature and pH level, in organic and inorganic concentration, and in flow rate, and the resulting effluent response observed. Mathematical modelling and simulation, and conventional time series or spectral analysis are some basic tools by which process response can be interpreted quantitatively.

Deterministic dynamic models

The purpose of seeking a deterministic or mechanistic model is to allow an explanation for the response of a process to variations in the input variables. If such models can be determined for the combined and separate sludge carbon removal-nitrification alternatives, the response of the processes to input variables which cannot be examined experimentally due to equipment or time limitations, can be examined. Deterministic models nearly always have empirical qualities and it is unlikely that a system as complex as a biological wastewater treatment plant will ever be described exactly by a theoretical model.

Through consideration of the following an attempt can be made to develop a mechanistic model for the activated sludge process, operated for nitrification:

- 1) the flow regime in the aeration basin,
- 2) the oxygen requirements of the system,
- 3) the representation of the performance of the final settler,
- 4) the effect of secondary parameters such as wastewater temperature, pH, and toxic substances,
- 5) the form of the equation expressing the time rate of synthesis of substrate into new cells, and
- 6) such factors as cell lysis, basal metabolism, and solubilization of particulate degradable organic carbon.

In modelling, the separate and combined sludge systems described here (Figure 1) ordinary differential equations are used to express the dynamic behaviour of each of the following: heterotrophs, Nitrosomonas, Nitrobacter, degradable organic carbon, ammonia nitrogen, nitrate nitrogen, and nitrite nitrogen. It is assumed that all the heterotrophic organisms can be represented by a characteristic organic carbon substrate utilization rate described by a linear correlation. The available carbon substrate is that measured as filterable degradable organic carbon. Substrate utilization by the nitrifying bacteria is assumed to follow Monod kinetics. One of the powerful advantages of Monod kinetics is that it is a continuous function reducing to first order at low substrate concentrations and approaching zero order at high substrate concentrations. One inherent weakness of the Monod function often cited (Powell, 1967) is that it shows the growth rate to be only dependent on the instantaneous substrate concentration exhibiting no lag in response to changes in concentration. The lag in growth rate exhibited by nitrifying bacteria for changes in ammonia and nitrite concentrations has been shown by Hofman and Lees (1953), Lees and Simpson (1957), and Laudelot and Van Tichelen (1960) to be very small.

In the expressions for the growth rate and consequent substrate utilization equations, no account will be given for variations in dissolved oxygen (DO), temperature or pH. The parameter values in these equations will be assumed constant reflecting constant DO, temperature, and pH.

In the organism material balances, reduction in cell growth due to lysis or endogeneous respiration is represented by a combined decay coefficient for each of the organism groups involved.

While, in developing the dynamic models, no attempt will be made to express the kinetic growth coefficients as functions of the transient loading condition, this assumption, as applied to the yield coefficient for heterotrophs, is questionable and a relation expressing the variation with loading may be necessary (Smith and Eilers, 1970). The small yield values reported for nitrifiers (Painter, 1970) makes any correction for ammonia and nitrite loading unnecessary. Similarly the insignificant yield value for Nitrosomonas allows the neglect of the

small amount of ammonia used in cell synthesis that does not appear as nitrite. The remaining coefficients, the linear coefficient describing heterotrophic growth and the maximum growth rate and saturation coefficients in the Monod models for nitrification, will be assumed constant over a given transient period. Providing the dynamic investigations involve relatively short term temporal periods, the possibility for changes in these parameters should be small.

In the initial model development, each aerator will be assumed completely mixed. Residence time distribution studies, may indicate that a different hydraulic model is necessary.

An adequate representation of the performance of the final settler is a complication in any model for the activated sludge system. Since the interactions between the aeration basin and the solid-liquid separators are not of prime importance in this research, we will consider the settlers to be zero volume devices whose efficiency can be described by a separation coefficient determined experimentally. No bacterial growth or changes in organic carbon, ammonia, nitrite, and nitrate are assumed to occur in the settler and the return flow and effluent streams contain equal proportions of all biological groups.

The dynamic model describing the single-stage combined sludge carbon removal-nitrification alternative is represented in Figure 4. In this figure:

V = volume of reactor (L^3),

F = flow rate (L^3/T),

S = limiting substrate concentration (M/L^3),

X = organism concentration (M/L^3),


$O, 1, 2, 3, 4, R1, W1$ = notations which relate to flow streams,

H, NS, NB = notations which relate to heterotrophs,

Nitrosomonas, and Nitrobacter, and

C, NH_4, NO_2, NO_3 = notations which relate to filterable degradable organic carbon, ammonia, nitrite, and nitrate.

In the model development, substrate and organism material balances are presented assuming the nitrification reactions follow the stoichiometric equations 1 and 2 and the general material balance for completely mixed reactors applies:



i, j, k - represent heterotrophs, Nitrosomonas, and Nitrobacter

FIG. 4 MODEL RELATIONSHIPS FOR SINGLE-STAGE COMBINED SLUDGE SYSTEM

rate of material accumulation	=	rate of material flow into reactor	-	rate of material flow out of reactor	+	rate of appearance or disappearance of material due to growth or utiliza- tion by organisms.
-------------------------------------	---	---------------------------------------	---	--	---	--

Details concerning the material balances are presented in Appendix A.

Similar models involving substrate and organism balances can be developed for the TSC and TSS sludge systems.

Before the equations which comprise the proposed dynamic models can be solved, values for the various parameters must be determined. Methods are discussed in Appendix A for determining the parameter values.

Having developed a dynamic mathematical model, the equations which comprise the model must be solved in order to predict behaviour with respect to time. Simulation packages which can be used in solution of the differential and algebraic equations comprising the dynamic models include DYNYSYS AND CSMP. DYNYSYS is a modular dynamic system simulation developed by A.I. Johnson and associates at McMaster University. Using this modular routine, a particular process can be simulated by assembling a number of modules representing the individual processes within the plant. Both differential and algebraic equations can be handled. CSMP (IBM, 1972) is an equation oriented approach differing from the modular approach in that equations are not integrated one at a time but simultaneously. CSMP is highly user oriented allowing concentration on model development and simulation results rather than on details of the computations.

Linear dynamic stochastic models

The activated sludge system is a heterogeneous culture system containing a wide spectrum of organisms interacting and competing for the many organic and inorganic substrates. In describing the single-stage combined sludge (SSC) carbon removal-nitrification alternative, the heterogeneous system was simplified by considering independent organism groups growing on defined substrates. A number of other assumptions are inherent in the model development to reduce the complexity of the process including:

- 1) the neglect of synergism or antagonism resulting from organism and substrate interaction,
- 2) the utilization of empirical functions to describe biological growth and consequent substrate removal,
- 3) the neglect of any lag in growth rate exhibited by both autotrophic and heterotrophic organism groups in response to changes in substrate concentration.
- 4) the assumption that kinetic growth coefficients are constant, unaffected by variations in loading conditions to the treatment plant, and variations in D.O., temperature, and pH within the aeration basin, and
- 5) the neglect of the effect on substrate removal of any physical-chemical mechanisms such as adsorption.

It is apparent that the highly complex nature of the activated sludge process makes it most unlikely that a "true" unified model, allowing extrapolation of process performance from one system to another, could be developed. The obscure, undefined processes will lead to output results not accountable by the model. Even if the proposed model for the SSC activated sludge system, with its stated weaknesses, was sufficient to describe the carbon removal-nitrification performance, there results a considerable number of time dependent growth and substrate removal functions complicating the usefulness of the model.

When dealing with systems that do not behave according to a relatively simple deterministic model and are complicated by unexplainable output variation or noise it may be more useful to utilize linear dynamic-stochastic models. The activated sludge system may well tend to act as a linear system because of a central limit or averaging effect of the many growth and substrate removal functions controlling the process. Consequently, linear transfer function models should describe the time-dependent behaviour adequately. Such models, together with linear time series models to account for the unexplained output variations, can be used to describe the response of the combined and separate sludge systems to input variations.

It is accepted that the levels of the inputs, such as concentration of $\text{NH}_3\text{-N}$ and organic carbon to the alternative carbon removal-nitrification systems (Figure 1) will result in a delayed response in the output levels. Such a change is referred to as a dynamic response and a model describing this dynamic response is referred to as a transfer function model.

These models are of the form:

$$Y_t = \sum_{i=1}^r \frac{(\omega_0 - \omega_1 \beta \dots - \omega_s \beta^s i)}{(1 - \delta_1 \beta \dots - \delta_r \beta^r i)} X_{i,t-b} \dots \dots \dots (18)$$

$$= \sum_{i=1}^r V_i(\beta) X_{i,t-b}$$

where Y_t = output deviation from the mean at time t,
 ω, δ = model parameter values,
 r, s = model orders
 b = delay period,
 X_{it} = the deviation from the mean of the i^{th} variable at time t,
 β = backward shift operator, and
 $V_i(\beta)$ = discrete transfer function model relating Y_t and $X_{i,t}$

Other influences which affect the output levels, referred to as noise, can be taken into account by a noise model:

$$N_t = \frac{(1 - \theta_1 \beta \dots - \theta_q \beta^q)}{(1 - \beta)^d (1 - \phi_1 \beta \dots - \phi_p \beta^p)} a_t \dots \dots \dots (19)$$

where N_t = disturbance in the output due to all sources other than the X_{it} 's
 θ, ϕ = model parameter values,
 p, d, q = model orders, and

a_t = a white noise sequence (independent random variables).

Therefore, the combined transfer function-noise (TF-N) model can be written:

$$Y_t = \sum_i V_i(\beta) X_{i,t-b} + N_t \quad \dots\dots\dots(20)$$

The building of these models is accomplished by an iterative procedure involving:

- 1) identification of the transfer model polynomial orders (r_i, s_i $i=1, 2\dots$) and delay period (b),
- 2) estimation of the parameters of the tentatively identified transfer function model,
- 3) identification of the noise model,
- 4) re-estimation of the parameters of the combined transfer function-noise model, and
- 5) diagnostic checking of the fitted model to verify adequacy.

In the identification stage of the transfer function model building sequence, cross correlation techniques may be used to indicate r, s , and b and estimate the impulse response values (V_i) of the transfer function model. The cross correlation function between two input-output series (x and y) separated by a constant interval or lag (k) is given by:

$$\rho_{xy}(k) = \frac{\gamma_{xy}(k)}{\rho_x \rho_y} \quad k = 0, \pm 1, \pm 2 \dots \quad \dots\dots\dots(21)$$

where $\gamma_{xy}(k)$ = cross covariance function between x and y , and
 ρ_x and ρ_y = constant standard deviations of the x and y series.

Determination of the cross correlation functions also allows a preliminary assessment of which input and output characteristics are most related.

In place of using cross correlation techniques to estimate the V_j values of the transfer function model, they can be determined directly through a relationship with the autocovariance function of the input series and the cross covariance function between the input-output series (Box and Jenkins, 1970a). Once V_j values are obtained, preliminary estimates for the model parameters (ω, δ) can be determined through use of an identity to equation 18 (Box and Jenkins 1960b). Beginning with the preliminary estimates, an efficient estimation procedure is used such as non-linear least squares to determine the parameter values.

The noise component of the combined TF-N model is identified by examining the residuals of the transfer function model using autocorrelation techniques.

Once diagnostic checking has varified the adequacy of the fitted model, it is possible to forecast future values of the output series Y_{t+j} using X_t as a leading indicator. This is accomplished by using the "difference" form of the combined TF-N model (Box and Jenkins, 1970c).

EQUIPMENT AND PROCEDURES


Pilot Plant Design and Operation

To evaluate the combined and separate sludge carbon removal-nitrification alternatives a pilot plant was designed by P.M. Sutton and K.L. Murphy and constructed at the Wastewater Technology Centre, Burlington, Ontario by Sutton and members of the pilot plant staff of the Environmental Protection Service. This facility, designed for a maximum hydraulic loading of $32.7 \text{ m}^3/\text{day}$ (7,200 lgpd), permits study of both suspended and supported growth carbon removal-nitrification systems (Figure 5).

The suspended growth systems for carbon removal-nitrification, designated as plants A and B, consists of two 2.81 m^3 (480 lg) plexiglass, dispersed air aeration tanks. Plant A contains a removable divider allowing either the two-stage or the single-stage combined sludge system (TSC or SSC) to be operated in parallel with Plant B. Plant B forms the two-stage separate sludge system (TSS), a fixed divider separating the reactor into two aeration tanks (B1 and B2). Three additional removable dividers were added to Plant B when required to form a five-stage combined sludge system (FSC). The circular clarifiers are 0.76 m (2.5 ft) in diameter providing a surface settling rate of $28.9 \text{ m}^3/\text{day}/\text{m}^2$ (590 lgpd/ft²) and a hydraulic detention time of 1.0 hr at a feed rate of 9.1 l/min (2.0 lgpd).

Variable speed positive displacement pumps deliver the wastewater to the reactors from a cooling unit capable of cooling to 3°C or heating to 25°C with a precision of $\pm 1^\circ\text{C}$. The biological solids retention time is controlled in the reactors by wasting from return sludge lines.

By control of the SRT and temperature, a pseudo "steady-state" operation point was approached. Using 24 hr time-averaged sampling, and parallel operation, the performance of any two alternatives could be assessed. In order to determine the kinetic removal rates used to describe the pseudo "steady-state" performance of the nitrification systems, the effluent from the reactors must contain residual filterable ammonia. When complete ammonia conversion was obtained, additional amounts of ammonia (NH_4Cl) were added as the nitrification rate was considered to be substrate



SUPPORTED GROWTH SYSTEM

SUSPENDED GROWTH SYSTEMS

FIG. 5 SUSPENDED AND SUPPORTED GROWTH CARBON REMOVAL - NITRIFICATION PILOT PLANT

limited at effluent $\text{NH}_4^+\text{-N}$ values less than 1.0 mg/l. Bicarbonate (NaHCO_3) was added to the feed when necessary to avoid any alkalinity limitation on the ammonia removal rates. The dissolved oxygen in the reactors was maintained above a minimum level of 2.0 mg/l.

To assess the dynamic behaviour of the carbon removal-nitrification alternatives, the input variables had to be artificially disturbed. The degrittied raw municipal wastewater pumped from the Burlington Skyway treatment plant contained normal diurnal variations in organic and inorganic concentrations (Table 2). The pilot plant variable speed pumps provided a means of delivering the wastewater to the reactors in any hydraulic pattern. This, together with supplementing the wastewater with organic carbon (dextrose) and inorganic nitrogen (NH_4Cl), allowed any combination of hydraulic, organic, and inorganic loading to be obtained.

Experimental Plan

The pilot plant program was divided into four phases covering the period from May 1973 to June 1975. Phase 1 consisted of the design and construction of the pilot plant facilities extending from May until October, 1973.

Start-up of facilities and preliminary experiments constituted Phase 2. Initially mixed-liquor suspended solids from the Burlington Skyway activated sludge plant were added to the aeration sections of Plants A and B (Figure 5) and continuous operation began immediately. The preliminary experiments which followed determined the operating limitations of the carbon removal-nitrification alternatives, allowing formulation of a concise experimental program designed to compare the systems under pseudo "steady-state" conditions. This experimental period designated Phase 3 extended from November 1973 until February, 1975. During Phase 3 preliminary non-steady and variable loading experiments were conducted.

Phase 4 concluded the experimental program and involved experiments designed to assess and compare the dynamic behaviour of the carbon removal-nitrification systems. During this phase, additional pseudo "steady-state" experiments were completed.

TABLE 2 RAW WASTEWATER CHARACTERISTICS

Characteristic mg/l	Mean	90%*
COD	325	460
BOD ₅	120	200
Filterable Organic Carbon (FOC)	28	37
SS	240	450
Filterable NH ₄ -N	15	18
Filterable TKN	17	25
Alkalinity (as CaCO ₃)	118	130

Note: *90% of observations are equal to or less than stated value

Pseudo "steady-state" experimental design

The primary factors considered to affect the pseudo "steady-state" performance of the nitrification alternatives in treating municipal wastewater were the solids retention time (SRT) or sludge age and temperature. Three levels of system SRT and five levels of temperature were selected (Table 3). The SRT levels were determined on the basis of practical design considerations for full scale facilities. The temperature levels reflect values under which treatment plants may operate in continental climates.

The system SRT was determined by a combination of hydraulic residence time and intentional solids wasting. Details concerning the calculation of the system SRT for each alternative appear in Appendix B. The experimental design, formulated to compare the operating alternatives (Table 4), allowed for a complete assessment of the two-stage separate sludge system (TSS) and a comparative assessment, through statistical methods, of the other alternatives (TSC and SSC). Additional pseudo "steady-state" experiments were undertaken to increase the precision of certain design parameter values derived for each alternative.

Pseudo "steady-state" was achieved by operating the reactors at the predetermined levels of SRT and temperature. After a sufficient period for temperature acclimation (Benedict and Carlson, 1973) and a minimum time of one and normally two or three system SRT's, the performance of the operating systems was assessed.

Non "steady-state" experimental design

To assess the dynamic behaviour of the combined and separate sludge systems, the parallel TSC and TSS systems were subjected to a variety of non-steady conditions (Table 5). Previous to each experiment the systems were operated at solids retention times of three to four days and at a temperature of approximately 15⁰C, conditions critical for nitrification, to ensure measurable responses would be observed. To assess the effect of hydraulics on combined sludge systems operated for carbon removal-nitrification under non-steady conditions the single-stage system (SSC) was compared to the five-stage system (FSC) in experiment D9 (Table 5).

TABLE 3 EXPERIMENTAL DESIGN LEVELS

Factor	Operating Value	Design Level
System Solids Retention Time days	4	-
	7	0
	10	+
Temperature °C	5	1
	10	2
	15	3
	20	4
	25	5

TABLE 4 EXPERIMENTAL DESIGN FOR SYSTEM COMPARISON

Run No.	Temperature Level	System Solids Single-Stage Combined (SSC)	Retention Time Two-Stage Separate (TSS)	Level Two-Stage Combined (TSC)
PSS-15 -17 -01 -08	1	0 - - -	+ 0 0 -	+ 0 - -
PSS-11 -21 -20 -57	2	0 + -	- 0 0 +	- 0 - -
PSS-13 -23 -25 -29	3	0 - -	+ 0 0 -	+ 0 - -
PSS-44 -31 -34 -16	4	0 + -	- 0 0 +	- 0 - -
PSS-54 -53 -52 -61	5	0 - -	+ 0 0 -	+ 0 - -
Repeats PSS-07 -14 -59 -58 -12 -60 -63 -49 -62 -55	1 1 2 2 3 3 4 4 5 5	- - - - + + - + - +	- + + - - + + - - +	+ + - - - + - - -

TABLE 5 NON "STEADY-STATE" EXPERIMENTS

Run No.	Baseline Temp. °C	Hydraulic Detention Time (Aeration) hrs	Run Length days	Experiment
D1	15	8	5	Step down in temperature of 5°C.
D2	15	8	8	pH impulse (HCl).
D3	15	8	4	Hydraulic impulse 2x baseline level for 10 hrs. (24-34 hrs).
D4	15	8	4	Hydraulic, plus OC, plus inorganic N impulse 2x mean levels for 10 hrs (24-34 hrs).
D5	14	8	10	Designed changes in hydraulic, OC, and TKN levels.
D6	13	8	4	Hydraulic step 2x baseline level.
D7	13	8	4	OC step addition of 40 mg/l C to normal levels.
+D8	13	8	4	Inorganic N step addition of 15 mg/l N to normal levels.
*D9	20	8	3	Hydraulic, plus OC, plus inorganic N impulse 2x mean levels for 10 hrs (24-34 hrs).

Note: *SSRT 2-3 days in SSC and FSC systems.
 †SSRT 6 days in TSS system.

The high degree of correlation between the input variables, typical of the daily input to wastewater treatment plants, made it necessary to artificially disturb the inputs in a designed manner in order to properly assess their individual effects. Two levels of flow rate, filterable organic carbon, and filterable TKN were chosen (Table 6) and an experimental design formulated (Table 7). During this experiment (D5) the temperature and system SRT conditions were maintained at the baseline conditions.

Sample Preparation and Analyses

Samples for organic carbon were prepared by filtration through 0.45 micron Gelman glass fiber filters followed by acidification to pH 2 with concentrated hydrochloric acid. Unfiltered TKN and COD samples were acidified with concentrated sulphuric acid. NO_3^- -N, NO_2^- -N, filtered TKN, NH_4^+ -N and COD samples were prepared for analyses by filtration through 0.45 micron Gelman glass fiber filters. All samples were stored at 0° to 5°C in polyethylene bottles while awaiting analyses except for BOD samples which were frozen.

The analytical procedures utilized are detailed in Appendix B.

TABLE 6 EXPERIMENT D5 DESIGN LEVELS

Influent Factors	Operating Value	Design Level
Flow Rate	9.0	+
l/min	4.6	-
Filterable OC	30 - 40	+
mg/l	10 - 20	-
Filterable TKN	20 - 30	+
mg/l	5 - 15	-

TABLE 7 EXPERIMENT D5 DESIGN

Time Period hrs	Flow Rate Level	Filterable OC Level	Filterable TKN Level
24 - 36	+	+	+
0 - 12	-	+	+
84 - 96	+	-	+
36 - 48	-	-	+
12 - 24	+	+	-
60 - 72	-	+	-
48 - 60	+	-	-
72 - 84	-	-	-
96 - 120	-	+	-
120 - 144	+	+	-
144 - 168	-	-	+
168 - 192	+	-	+
192 - 204	-	+	-
204 - 216	+	-	-
216 - 228	-	-	-
228 - 240	+	+	-

DISCUSSION OF RESULTS

Pseudo "Steady-State" Behaviour

Appendix B contains a computer listing of the complete day to day operating and analytical results during each phase of the experimental plan. The results of experiments, designed to compare the separate and combined sludge systems (Table 4), are tabulated in Appendix C (Table C1). Included are the results of other pseudo "steady-state" experiments undertaken to increase the precision of the derived design parameter values. Any experiments repeated, at equal SRT and temperature conditions are considered "genuine" repeats (Appendix C).

Evaluation of combined and separate sludge systems

The three carbon removal-nitrification systems were compared first in terms of their ability to remove filterable TKN. The results from the analysis of paired data over a system sludge age range of four to ten days and temperature range of 5⁰ to 25⁰C using a "t-test" indicated comparable removal of filterable TKN by the separate (TSS) and combined sludge systems (TSC and SSC) at equal system solids retention times. While the data might appear to favour the separate sludge system (Figure 6), a "t" value less than the critical value (95% level) for the differences (D_i values) in effluent TKN is indicated in Table 8. The lack of interaction between the differences in filterable TKN removal of the parallel operating systems and the solids retention time and temperature allowed the paired data to be statistically analysed as one data set.

The paired data from the operation of the TSS sludge system in parallel with either the SSC or TSC sludge system allowed a straight forward statistical assessment. In comparing the two combined sludge systems (SSC and TSC) such a procedure was not possible. The mean differences in treatment between the SSC and TSS sludge system and the TSC and TSS sludge system were determined. The two mean values were examined statistically to determine if they were significantly different from each other. Normal statistical procedures assume the populations from which the two means were derived, have equal variances. In this instance,




FIG. 6 FILTERABLE TKN REMOVAL IN COMBINED AND SEPARATE SLUDGE SYSTEMS

TABLE 8 DIFFERENCE IN EFFLUENT RESULTS FROM PARALLEL OPERATING SEPARATE AND COMBINED SLUDGE SYSTEMS

Parameter mg/l	\bar{D}	S_D^2/n	t	t $\alpha=.95$	t $\alpha=.99$
<u>TSS vs SSC</u>					
Filterable TKN	-0.06	0.87	0.06	1.77	2.65
NO ₃ + NO ₂ -N	1.47	1.43	1.23	1.81	2.76
SS	5.85	27.45	1.12	1.78	2.68
Alkalinity (as CaCO ₃)	1.79	10.32	0.54	1.78	2.68
<u>TSS vs TSC</u>					
Filterable TKN	0.51	1.09	0.49	1.75	2.60
NO ₃ + NO ₂ -N	0.33	0.66	0.41	1.76	2.62
SS	10.50	35.61	1.76	1.75	2.60
Alkalinity (as CaCO ₃)	2.87	21.90	0.61	1.76	2.62
Note: $\frac{S_D^2}{n}$ = estimated variance of \bar{D} , where					
$S_D^2 = \frac{\sum(D_i - \bar{D})^2}{n-1}$, and					
\bar{D} = mean difference in effluent parameter value (separate-combined sludge value),					
n = number of paired data points, and					
$t = \frac{\bar{D}}{S_D/(n)^{1/2}}$.					

the ratio of the variances when compared to the "F" statistic indicated that such an assumption was warranted (Table 9) and allowed the use of a "t-test" for the comparison of the means. The resulting "t" value was not significant implying that equal filterable TKN removal was obtained with both SSC and TSC sludge systems (Table 9). This allows an evaluation of the effect of reactor configuration on nitrification. The use of dye studies to approximate the hydraulics of the systems (Appendix D) indicated that the single-stage reactor could be considered a completely mixed system characterized by a large value of the dimensionless dispersion parameter D/uL . The mixing regime in the TSC sludge system can be approximated by a value of D/uL equal to 0.2, closer to conditions characteristic of full-scale basins with large length to width ratios. The results and a summary of the procedures used in conducting the dye studies is presented in Appendix D. The lack of difference in filterable TKN removal in the two combined sludge systems (Table 9), with substantially different mixing regimes, supports the "zero-order" nature of the nitrification reaction down to very low filterable TKN or NH_4^+ -N values. This lack of concentration dependency is further demonstrated in Appendix C (Table C, Figure C1).

In biological wastewater treatment plants designed for nitrogen conversion and removal, denitrification will normally follow the nitrification process. An important variable in design of denitrification systems is the influent nitrate concentration. The paired data analysis indicated that the alternative carbon removal-nitrification systems will produce equal amounts of $NO_3^- + NO_2^-$ -N (Tables 8 and 9). The nitrate production will be 0.8 g of $NO_3^- + NO_2^-$ -N per gram of filterable TKN removed (Figure 7). The NO_2^- -N concentration in the reactor effluents will normally be less than 1.0 mg/l (Figure 8).

The hydrogen ions produced during nitrification, react with the bicarbonate in the wastewater resulting in a decrease in alkalinity. The analysis of paired data indicated that the SSC and TSC, and TSS sludge systems consumed equal amounts of alkalinity during the nitrification reaction (Tables 8 and 9). The geometric and arithmetic mean values for the consumption ratio are 3.3 and 3.9 grams of alkalinity (as $CaCO_3$) consumed per gram of filterable TKN removed (Figure 9) considerably less than the theoretical value of approximately 7. The theoretical value assumes that no filterable TKN is used for assimilation of heterotrophic

TABLE 9 DIFFERENCE IN EFFLUENT RESULTS FROM TSC AND SSC SLUDGE SYSTEMS

Parameter mg/l	System Compared to TSS	\bar{D}	S_D^2	$\frac{S_{D1}^2}{2} - \frac{S_{D2}^2}{2}$	F $\alpha = .95$	t	t $\alpha = .95$
Filterable TKN	SSC	-0.06	12.19	1.43	3.05	0.40	2.05
	TSC	0.51	17.46				
NO ₃ + NO ₂ -N	SSC	1.47	15.73	1.59	3.15	0.41	2.06
	TSC	0.33	9.92				
SS	SSC	5.85	356.97	1.60	3.18	0.57	2.05
	TSC	10.50	569.73				
Alkalinity (as CaCO ₃)	SSC	1.79	144.48	2.27	3.08	0.19	2.05
	TSC	2.87	328.55				

Note: $S_D^2 = \frac{\sum(D1-D)^2}{n-1}$

n = number of paired data points

$t = \frac{\bar{D}_{TSC} - \bar{D}_{SSC}}{Sp \left(\frac{1}{n_{TSC}} + \frac{1}{n_{SSC}} \right)^{1/2}}$ where,

$Sp^2 =$ pooled variance for $D_{TSC} - D_{SSC}$, and

$Sp^2 = \frac{n_{TSC} (S_{D TSC}^2) + n_{SSC} (S_{D SSC}^2)}{n_{TSC} + n_{SSC}}$




FIG. 7 NITRATE PLUS NITRITE NITROGEN PRODUCTION IN COMBINED AND SEPARATE SLUDGE SYSTEMS




FIG. 8 EFFLUENT NITRITE NITROGEN CONCENTRATION FROM COMBINED AND SEPARATE SLUDGE SYSTEMS




FIG. 9 ALKALINITY CONSUMPTION IN COMBINED AND SEPARATE SLUDGE SYSTEMS


organisms and that the decrease in filterable TKN is proportional to the decrease in $\text{NH}_4^+\text{-N}$. Therefore, a more appropriate expression for the alkalinity consumption is in terms of the nitrate plus nitrite nitrogen formed. Using the arithmetic mean values from Figures 7 and 8 the consumption ratio is equal to 4.9 grams of alkalinity (as CaCO_3) per gram of $\text{NO}_3^- + \text{NO}_2^- \text{-N}$ formed. This value is still less than the theoretical value which is calculated from equations 6 and 7 to be 7.2. Wilson (1975) and Mulburger (1971) working with supported and suspended growth nitrifying systems respectively, found values of 5.9 and 6.1 grams of alkalinity consumed (as CaCO_3) per gram of oxidized nitrogen formed.

A paired "t-test" to determine whether there was a difference in suspended solids in the final clarifier effluents from the combined and separate sludge systems indicated a significant difference at the 95% but not at the 99% level (Table 8, TSS vs TSC). No statistical difference was indicated in comparing the two combined sludge systems (Table 9). The mean clarifier effluent suspended solids from both separate and combined sludge systems was 29 mg/l (Figure 10).

In certain instances a nitrogen control program may necessitate the addition of nitrification facilities without subsequent denitrification. In such cases, it is likely that a TKN limit will be specified. Even with complete nitrification, the clarified effluent can be expected to contain a small quantity of filterable organic nitrogen (Figure 11) probably associated with refractory compounds or metabolic by-products. The analytical determination of this material does not appear to be interfered with by the presence of $\text{NO}_3^- \text{-N}$ concentrations (Appendix C, Figure C2). In addition, the clarified effluent will contain 1.0 mg/l non-filterable TKN (Figure 12) caused by the presence of suspended solids as indicated in Figure 10.

Temperature and SRT effects on nitrification

In assessing the performance of the combined and separate sludge systems the analysis of paired data gives no indication of the effect on nitrification of the factors SRT and temperature. The results



PERCENT OF OBSERVATIONS EQUAL TO OR LESS THAN STATED VALUE

FIG. 10 CLARIFIER EFFLUENT SUSPENDED SOLIDS FROM CARBON REMOVAL-NITRIFICATION SYSTEMS




FIG. 11 FILTERABLE ORGANIC NITROGEN FROM CARBON REMOVAL-NITRIFICATION SYSTEMS




FIG. 12 NON-FILTERABLE EFFLUENT TKN FROM CARBON REMOVAL-NITRIFICATION SYSTEMS

of experiments, designed to compare the alternatives (Table 4), can be used to determine the importance of these factors through an analysis of variance (ANOVA). Tabulation of the TSS sludge system experiments in a form more suitable for an ANOVA (Table 10) reveals a complete factorial design, replicated once, at three levels of SRT and five levels of temperature (3x5). This same design (Table 10) applies to the combined sludge system when the SSC and TSC experiments are considered as one data set.

Temperature and SRT significantly affect filterable TKN removal in combined and separate sludge systems indicated by the values of the variance ratio being greater than the critical "F" value (ANOVA, Table 11). No significant temperature-SRT interaction is evident (Table 11). When the relation between the response (filterable TKN removal) and the levels of SRT and temperature are considered a more detailed ANOVA can be constructed. Since the levels of each variable are at equal intervals (Table 3) the components (linear, quadratic, cubic, etc.) of the main effects of the variables and of the interaction can be determined by means of orthogonal polynomials. This procedure may not only reveal significant main effects and interactions depending on the variable levels, which may have been masked in the overall mean square determination (Table 11), but can give an indication of the relationship between the response and the variables. Applying this procedure, a positive linear correlation is indicated between SRT and filterable TKN removal in the combined and separate sludge systems (Appendix E, Table E1). A curvilinear relationship may be more appropriate to describe the positive relationship of temperature and filterable TKN removal (Table E1). A summary of the calculations involved in preparing Table E1 are given in Appendix E.

The relationships between filterable TKN removal and SRT and temperature can be utilized in the design of carbon removal-nitrification systems. Another design approach for nitrification systems is the use of the unit rate of filterable TKN removal. The "zero-order" nature of the nitrification reaction allows the unit rate to be expressed as a constant (K). The ANOVA based on the experiments designed to compare the alternative carbon removal - nitrification alternatives (Table 10) can be constructed

TABLE 10 TEMPERATURE-SRT FACTORIAL DESIGN

Level of SRT	Level of Temperature				
	1	2	3	4	5
-	PSS-07 PSS-08	PSS-58 PSS-11	PSS-29 PSS-12	PSS-44 PSS-49	PSS-61 PSS-62
0	PSS-01 PSS-17	PSS-20 PSS-21	PSS-25 PSS-23	PSS-31 PSS-34	PSS-53 PSS-52
+	PSS-14 PSS-15	PSS-59 PSS-57	PSS-13 PSS-60	PSS-16 PSS-63	PSS-55 PSS-54

TABLE 11 EFFECTS OF SYSTEM SRT AND TEMPERATURE ON FILTERABLE TKN REMOVAL IN SEPARATE AND COMBINED SLUDGE SYSTEMS

Source of Variation	Sum of Squares	Degrees of Freedom	Mean Square (MS)	Variance Ratio (MS/MSPE)	F $\alpha=.95$
<u>Main Effects</u>					
SRT: TSS	935.63	2	467.82	14.49	3.68
SSC or TSC	886.20	2	443.10	15.10	3.68
Temp.: TSS	7339.02	4	1834.75	56.84	3.06
SSC or TSC	10091.20	4	2552.80	85.96	3.06
<u>SRT and Temp. Interaction:</u>					
TSS	364.97	8	45.62	1.41	2.64
SSC or TSC	442.01	8	55.25	1.88	2.64
<u>Pure Error (PE):</u>					
TSS	484.23	15	32.28	-	-
SSC or TSC	440.15	15	29.34	-	-

with the unit rate of filterable TKN removal as the response. The unit rate values for these experiments together with the results of other pseudo "steady-state" experiments undertaken to allow for complete system design are tabulated in Appendix C (Table C1).

The unit rate of filterable TKN removal in combined and separate sludge systems is significantly affected by temperature (Table 12). The system SRT has an important effect on the unit rate in the combined sludge systems. In the separate sludge system the result is dependent on the level of the variable as indicated by the more detailed ANOVA (Appendix E, Table E2). In both combined and separate sludge systems there are significant temperature - SRT interactions (Tables 12 and E2) affecting the unit filterable TKN removal rate.

In order to be useful for system design it is important to express the effects of temperature and SRT on nitrification in a concise fashion. The Arrhenius relationship (equation 16) has often been used to represent the variation of substrate removal with temperature in biological systems. A reparameterized form of this relationship is:

$$K = K^* e^{-E/R(\frac{1}{T} - \frac{1}{T_0})}, \quad \dots\dots\dots(22)$$

- where K^* = Ae^{-E/RT_0} ,
- K = reaction rate constant (day^{-1}),
- A = frequency factor (day^{-1}),
- E = activation energy (cal g-mole^{-1}),
- R = universal gas constant ($\text{cal g-mole}^{-1} \text{ } ^\circ\text{K}^{-1}$),
- T = temperature ($^\circ\text{K}$), and
- T_0 = median of the temperature range ($^\circ\text{K}$).

This form minimizes the interaction between the frequency factor (A) and the activation energy (E) which makes the Arrhenius equation a difficult expression to fit.

An analysis of variance (ANOVA) indicated no lack of fit, at a critical "F" value of $\alpha = .99$, when the reparameterized Arrhenius model was applied to the separate or combined sludge system unit rate data at each individual system SRT of 4, 7, and 10 days (Table 13) based on the complete pseudo "steady-state" data (Table C1). The details concerning the

TABLE 12 EFFECTS OF SYSTEM SRT AND TEMPERATURE ON THE UNIT RATE OF FILTERABLE TKN REMOVAL IN SEPARATE AND COMBINED SLUDGE SYSTEMS

Source of Variation	*Sum of Squares	Degrees of Freedom	*Mean Square (MS)	Variance Ratio (MS/MSPE)	F $\alpha=.95$
<u>Main Effects</u>					
SRT: TSS	2.64	2	1.32	2.75	3.68
SSC or TSC	1.56	2	0.78	13.00	3.68
Temp.: TSS	125.98	4	31.50	65.61	3.06
SSC or TSC	18.84	4	4.71	78.50	3.06
<u>SRT and Temp. Interaction:</u>					
TSS	13.50	8	1.69	3.52	2.64
SSC or TSC	4.82	8	0.60	10.04	2.64
<u>Pure Error (PE):</u>					
TSS	7.18	15	0.48	-	-
SSC or TSC	0.86	15	0.06	-	-
Note: *values x 10 ³					

*

*

TABLE 13 UNIT NITRIFICATION RATE VARIATION WITH TEMPERATURE

Reactor Configuration	Temp. Range °C	Arrhenius Model Parameters E cal/g-mole	A*	Anova Results MSLOF/MSPE	F α=.95	F α=.99
<u>Carbon Removal</u>						
<u>-Nitrification Systems</u>						
Combined Sludge						
4 day SRT	5-25	24700	1.47x10 ¹⁷	3.73	3.25	5.41
7 day SRT	5-25	13300	3.06x10 ⁸	3.57	2.64	4.00
10 day SRT	5-25	12450	8.29x10 ⁷	0.45	5.19	11.39
4,7, and 10 day SRT (pooled data with K/K*)						
Separate Sludge						
4 day SRT	5-25	29700	1.45x10 ²¹	5.59	3.33	5.64
7 day SRT	5-25	17550	9.76x10 ¹¹	1.86	2.70	4.14
10 day SRT	5-25	16950	4.66x10 ¹¹	0.25	5.19	11.39
4,7, and 10 day SRT (pooled data with K/K*)						
Nitrification System						
6 day SRT	6-25	32750	4.68x10 ²³	1.69	3.33	5.64
10 day SRT	6-25	20750	3.64x10 ¹⁴	4.16	2.70	4.14
15 day SRT	6-25	18850	1.48x10 ¹³	0.33	5.19	11.39

*Note: In calculating A reference temp. = To = 273 + 15 = 288°K

determination of the ANOVA results are given in Appendix E. The Arrhenius models are illustrated in Figures 13, 14 and 15 together with the models for the nitrification reactor (B2) of the separate sludge system. A system solids retention time of four, seven and ten days in the separate sludge system corresponds to values of six, ten, and fifteen days in the nitrification reactor. To examine any difference in temperature sensitivity between the four, seven, and ten day SRT's for the combined and separate sludge systems, the data were pooled using the ratio of K/K^* in equation 22. The lack of fit of the resulting single models (Table 13) indicates a significant temperature - SRT interaction verifying the previous results (Table 12 and E2). The decrease in activation energy (E) with increased SRT indicates reduced temperature sensitivity at high SRT values. The observed decrease in activation energy is caused by different relative changes in the fraction of nitrifiers present for a given temperature change for systems at different sludge ages. The importance of defining the system SRT in stating nitrification rates is illustrated by the variation in the Arrhenius parameter values (Table 13). The difference in rates observed by other authors (Figure 16) may be due to differences in SRT and/or the influent BOD_5/TKN ratio, another important variable shown to effect the fraction of nitrifiers in an activated sludge plant (Brown and Caldwell, 1975).

The relationship between SRT and the growth rate of organisms in an activated sludge plant (equation 9) presents a more fundamental approach to design for nitrification in a combined sludge system. This relationship is indirectly represented according to the correlation between the amount of filterable TKN removal and SRT and temperature. Expressing the effect of temperature on the amount of filterable TKN removal, according to the modified Arrhenius relationship (equation 22), the resulting individual models for the combined and separate sludge systems together with the models for the nitrification reactor (B2) are illustrated in Figures 17, 18, and 19. In this case the constant K represents the removal of filterable TKN.

Pooling the filterable TKN removal data to examine any difference in temperature sensitivity, an ANOVA indicated that the resulting single model for the combined sludge system was statistically unacceptable (Table E5).




FIG. 13 UNIT RATE OF NITRIFICATION IN THE COMBINED SLUDGE SYSTEM




FIG. 14 UNIT RATE OF NITRIFICATION IN THE SEPARATE SLUDGE SYSTEM




FIG. 15 UNIT RATE OF NITRIFICATION IN THE SEPARATE SLUDGE NITRIFICATION REACTOR




FIG. 16 NITRIFICATION RATES REPORTED BY VARIOUS AUTHORS




FIG. 17 FILTERABLE TKN REMOVAL IN THE COMBINED SLUDGE SYSTEM




FIG. 18 FILTERABLE TKN REMOVAL IN THE SEPARATE SLUDGE SYSTEM




FIG. 19 FILTERABLE TKN REMOVAL IN THE SEPARATE SLUDGE NITRIFICATION REACTOR

A similar result was found for the separate sludge system. The difference between the single models with a common activation energy (E), and the individual models is not readily discernible (Figure 17). This observation is supported by the lack of a temperature - SRT interaction previously noted (Table 11) in analyzing the results of the experiments designed to compare the alternative systems. A common temperature sensitive reflects equal relative changes in the number of nitrifiers present for a given temperature change for systems at different sludge ages.

The filterable TKN removal - SRT - temperature relationships (Figures 17, 18 and 19) suggest an independence of TKN removal and hydraulic residence time (HRT). This is verified by examining observed results at a substantially different HRT but at equal SRT and temperature conditions (Figure 20, Table C4).

By presenting the performance of the combined carbon removal-nitrification system according to Figure 17, an independence is implied between TKN removal and the BOD_5 loading. A different value for the influent BOD_5 from that encountered in this study will result in a difference in cell yield (heterotrophs) at the same SRT, and subsequently a difference in the amount of N removed by synthesis. Accounting for this difference, the pseudo "steady-state" design of nitrifying activated sludge system can be specified by noting the SRT necessary for a given filterable TKN removal. Fixing the SRT establishes the growth rate of both the autotrophic nitrifier population and the heterotrophic organisms. From the growth rate-substrate removal rate relationship for the heterotrophic population the other necessary design parameters (hydraulic detention time, mixed-liquor volatile, suspended solids concentration, etc.) can be established (Lawrence and McCarty, 1970).

Solids Production

Any postulated advantages of the separate sludge system such as greater stability or increased buffering capacity to compounds toxic or inhibitory to nitrification must be balanced against the additional cost of added clarification facilities and increased solids production. By determining the cumulative solids wasted during a pseudo "steady-state" operating period either in the process effluent or by intentional daily




FIG. 20 INDEPENDENCE OF TKN REMOVAL AND HYDRAULIC RESIDENCE TIME

wasting, solids production from the parallel operating alternatives was assessed. During the study, an average 1.6 kg of solids was wasted from the separate sludge system for every 1 kg wasted from the combined system (Figure 21).

Dynamic Behaviour of Nitrification Systems

The results of the experiments performed under non-steady conditions (Table 5) are included in Appendix B.

System response to pH and temperature changes

The transitional or short term response of the combined (SSC) and separate (TSS) sludge systems to changes in temperature and pH was investigated first. Parallel operation afforded a direct qualitative comparison of the response and recovery profiles of the carbon removal-nitrification systems.

A slower response to a step-down in temperature is indicated (Figure 22) for the separate sludge system. The approach by this system to TKN values "predicted" by the unit rate models at system SRT's of four days (Figures 13 and 14), lagged behind the combined sludge system. The minimum attainable filterable TKN concentration from the combined and separate sludge systems is 0.7 mg/l (Figure 9). The change in effluent filterable COD concentration further indicated the stability of the separate sludge system to changes in temperature.

The response to a reduction in feed pH was a significant change in effluent pH, and filterable TKN concentration (Figure 23). The separate systems exhibited a buffering capacity to a change in system pH which is reflected by the lag in response and recovery in terms of filterable effluent TKN concentration. This might be explained by the difference in system hydraulics. The nitrifying reactor (B2), of the separate sludge system (B1 and B2), exhibited a pH profile having a greater magnitude and a shorter duration than that of the combined sludge reactor. The "predicted" increased effluent filterable TKN reflects the loss in reactor volatile solids caused by decreased settleability. The observed effluent filterable COD concentrations




FIG. 21. REQUIRED SOLIDS WASTING IN SEPARATE AND COMBINED SLUDGE SYSTEMS




FIG. 22 RESPONSE OF CARBON REMOVAL NITRIFICATION SYSTEMS TO TEMPERATURE STEP-DOWN




FIG. 23 RESPONSE OF CARBON REMOVAL-NITRIFICATION SYSTEMS TO pH IMPULSE

(Figure 23), indicate the reduced effect of the toxic conditions on the separate sludge system.

System response to hydraulic, organic, and inorganic loading variations

Deterministic and linear dynamic - stochastic models were both considered in attempting to describe the response of the carbon removal-nitrification systems to variations in hydraulic, organic, and inorganic loading. The complexity of the activated sludge process, operated for carbon removal-nitrification, made it necessary to make a number of simplifying assumptions in the development of a deterministic model for the SSC sludge system. Even with these inherent weaknesses, which will give rise to unexplainable output variations or noise, the usefulness of the model is complicated by the number of time-dependent growth and substrate removal functions (Figure 4). With this in mind transfer function models together with linear time series models were used to describe the response of the combined and separate sludge systems to input variations.

Experiment D5 (Table 5) was designed to allow development of the linear dynamic-stochastic models. The designed input series (Figure 24) separated out the correlation between the input variables allowing assessment of the effects of flow, filterable OC, and filterable TKN on the output concentrations of filterable TKN and nitrate for the two-stage separate and single-stage combined sludge systems.

The cross correlation results indicated that for both sludge systems, the effluent filterable TKN concentration might be expected to increase in response to increases in influent filterable TKN concentration and flow upon the two hour analytical results (Figure 25). No significant response to changes in influent filterable OC concentration would be expected (Figure 25).

In evaluating the effluent nitrate-nitrogen response, a positive correlation to influent filterable TKN was indicated. The negative trend of the cross correlation functions between effluent nitrate concentration and influent filterable OC and flow indicated a possible significant negative




FIG. 24 PROGRAMMED INFLUENT SERIES




FIG. 25 CROSS CORRELATION RESULTS FOR EFFLUENT FILTERABLE TKN

correlation when the filterable OC loading (filterable OC x flow) was considered as the input variable to the separate and combined sludge systems (Figure 26).

Initial parameter values for the tentative transfer function models relating the output filterable TKN and NO_3^- -N values to the input variables were calculated by first determining the impulse response weights (V_i). The parameters in the tentative models were then estimated using non-linear least squares. Examination of the residuals of the fitted models led to the identification of the noise model orders. Re-estimation of the parameters led to combined transfer function noise models for effluent filterable TKN and NO_3^- -N (Tables F1 and F2). Comparison procedures and individual evaluation through diagnostic checking (Appendix F) led to the final model forms (Table 14). The computer programs used to determine auto and cross correlation results, impulse response weights, and least square parameter values are included in Appendix F together with examples of the programming results.

The observed and model results (Figure 27, Table 14) indicate that the effluent filterable TKN concentration from both systems responded positively to variations in TKN loading, but showed no significant response to changes in filterable OC concentration or loading. The magnitude and lag of the response was similar for both systems. The effluent NO_3^- -N concentration from the separate and combined sludge systems responded positively to changes in filterable TKN concentration and negatively to filterable OC loading.

Parallel reactor operation afforded insight into the response and recovery profiles of effluent filterable TKN from the combined and separate sludge systems when they were subjected to sudden changes in flow and flow plus filterable OC and TKN concentration levels (Table 5, D3 and D4). The observed results indicate that the magnitude of the response was greater in the separate sludge system (Figure 28). This may be due to the difference in hydraulic properties of the two systems. The results of experiment D9 (Figure 29) indicate the further the deviation from complete mixing, the greater the magnitude of the response. The value of the dimensionless dispersion parameter (D/uL) for the five-




FIG. 26 CROSS CORRELATION RESULTS FOR EFFLUENT NITRATE NITROGEN

TABLE 14 TRANSFER FUNCTION - NOISE MODELS DESCRIBING OBSERVED EFFLUENT TKN AND NITRATE-NITROGEN

Variable	System	Model
Filterable TKN	Combined	$Y_t = \frac{0.011}{1-0.786\beta} X1_{t-1} + \frac{1}{1-1.066\beta + 0.336\beta^2} \text{ at}$
	Separate	$Y_t = \frac{0.012 + 0.008\beta}{1 - 0.550\beta} X1_{t-1} + \frac{1}{1-1.394\beta + 0.540\beta^2} \text{ at}$
NO ₃ -N	Combined	$Y_t = 0.051 X2_{t-3} - \frac{0.003}{1-0.744\beta} X3_{t-3} + \frac{1}{1-0.889\beta} \text{ at}$
	Separate	$Y_t = 0.049 X2_{t-3} - \frac{0.004}{1-0.815\beta} X3_{t-1} + \frac{1}{1-1.127\beta + 0.221\beta^2} \text{ at}$
<p>where X₁ = TKN (filterable) loading (g/day), X₂ = Influent TKN (filterable) concentration (mg/l), and X₃ = OC (filterable) loading (g/day).</p>		




FIG. 27 OBSERVED AND MODEL RESULTS FOR EFFLUENT TKN AND NITRATE NITROGEN




FIG. 28 OBSERVED AND FORECASTED RESPONSE TO IMPULSE LOADINGS

stage combined sludge system (FSC) was found to be less than 0.2 (Appendix D). The NO_3^- -N results (Figure 29) verify that a shock loading condition has a greater impact on a nitrifying system with a mixing regime approaching plug flow. This same observation has been reported for full-scale complete mix and plug flow systems operated in parallel for BOD removal (Toerber, Paulson, and Smith, 1974).

To determine how appropriate the discrete transfer function noise models developed from experiment D5 are as a predictive tool, the effluent filterable TKN response during D3 and D4 was forecast. The models developed (Table 14) were based on two hour analytical results and must be altered to account for the sampling interval of three hours used in the non-steady experiments. The revised filterable TKN models (Table 15) were used to forecast the response of the combined (SSC) and separate sludge system (TSS) to the impulse loading conditions imposed during experiments D3 and D4. The response and recovery times showed good agreement (Figure 28). The magnitude of the response for experiment D4 was under-estimated. The impulse loading condition imposed during this experiment was beyond that encountered in the experiment D5 from which the models were developed. This could account for the difference between forecast and observed results. Details concerning the model revision procedures and forecasting methods are included in Appendix F.

The dynamic response of the combined and separate sludge systems to step changes in flow rate, organic carbon and inorganic nitrogen was investigated in experiments D6, D7 and D8. The step changes were initiated following observation of the performance of the systems for 24 hours under baseline conditions (Table 5).

In response to a doubling in flow rate, both systems increased in effluent filterable TKN corresponding to a decrease in removal (Figure 30). The pseudo "steady-state" relationships developed predict an independence of TKN removal and hydraulic retention time providing the solids retention time is maintained. Following an initial response, the combined sludge system performance verifies this relationship as a slightly lower removal level is established corresponding to a lower SSRT at the new pseudo "steady-state" (Figure 30). The response in terms of effluent nitrate




FIG. 29 RESPONSE OF COMPLETE MIX AND PLUG FLOW NITRIFYING SYSTEMS TO IMPULSE LOADING CONDITIONS

TABLE 15 TRANSFER FUNCTION - NOISE MODELS FOR THREE HOUR SAMPLING INTERVAL

Variable	System	Model
Filterable TKN	Combined	$Y_t = \frac{0.0156}{1-0.697\beta} X_{1,t-1} + \frac{1}{1-0.7254\beta + 0.195\beta^2} a_t$
	Separate	$Y_t = \frac{0.020 + 0.006\beta}{1-0.408\beta} X_{1,t-1} + \frac{1}{1-1.116\beta + 0.3964\beta^2} a_t$
where X_1 = TKN (filterable) loading (g/day).		




FIG. 30 OBSERVED RESPONSE TO HYDRAULIC STEP

was quite similar verifying the independence of nitrification and HRT (Appendix B). The decrease in filterable TKN removal in the separate sludge system (Figure 30) corresponds to a decrease in SSRT. The decrease in SSRT was caused by the loss of volatile solids in the nitrifying reactor (B2) through increased clarifier effluent suspended solids.

The organic carbon step imposed in D7 resulted in a doubling of the influent filterable BOD. The observed filterable TKN removal indicated an apparent delayed negative response both in the combined and separate sludge systems (Figure 31). This is likely not a true response but is due to a naturally occurring decrease in the influent filterable TKN concentration, limiting the TKN removal as evidenced by the low effluent values (Figure 31). This is supported by the filterable TKN removal results over the last 24 hour period. By maintaining the same system solids residence time (Figure 31), which involved increasing reactor volatile suspended solids together with increasing solids wasting from the reactors, the same number of nitrifiers was maintained and consequently the same filterable TKN removal resulted. This supports the contention that nitrification systems operating under similar environmental conditions (reactor pH, DO, and temperature) will contain the same number of nitrifiers at equal SRT's regardless of the C/N ratio.

In experiment D8 the inorganic nitrogen step imposed on the natural diurnal influent concentration, resulted in an apparent increase in filterable TKN removal (Figure 32) during the first day of addition (24 to 48 hr). For the combined sludge system, the removal results during the following days indicate that this response is likely associated with the system delay. The performance verifies that the combined sludge system was initially operating under critical nitrification conditions after which the same absolute amount of filterable TKN was removed at the stable SSRT conditions. This constant degree of nitrification is verified by equal daily mean effluent NO_3^- -N values during the experiment (Appendix B). The separate sludge system during D8 operated at a significantly higher SSRT due to an experimental error and therefore initially was not




FIG. 31 OBSERVED RESPONSE TO ORGANIC CARBON STEP

at critical nitrification conditions as evident from the effluent results (Figure 32) during day one (0 to 24 hr). Consequently, an increased degree of filterable TKN removal occurred following the nitrogen step. This result is verified by a corresponding increase in the level of effluent NO_3^- -N (Appendix B).

System response to natural diurnal variations
in flow and concentration

The step forcings and impulse loading conditions imposed during the non-steady experiments allow us to assess how combined and separate sludge systems operating under critical nitrification conditions respond to sudden changes in influent conditions and changes in the pseudo "steady-state" levels of the input variables. In establishing design criteria for wastewater treatment plants the response to the natural diurnal variation in flow and concentration normally encountered at a wastewater treatment plant is an important consideration. This response can be examined by reference to the baseline day results of the non-steady experiments.

The baseline influent TKN levels during experiments D3 and D6 (Figure 33) represent extremes in the natural concentrations encountered. The resultant TKN loadings lead to a significantly different effluent filterable TKN response (Figure 33) for both the combined and separate sludge systems even though the experimental SSRT (three days) and temperature (13° to 15°C) conditions were similar. The daily mean effluent filterable TKN values during these baseline days (Figures 28 and 30) can be predicted approximately by use of the pseudo "steady-state" TKN removal relationships developed at SSRT's of four days (Figures 17 and 18). In experiment D3 the predicted values for both the combined and separate sludge systems correspond to the residual filterable organic nitrogen concentration (0.7 mg/l) identified previously (Figure 11). In experiment D6 the predicted values are 4.8 and 4.0 mg/l filterable TKN for the combined and separate sludge systems respectively. These predicted values correspond quite closely to the observed daily mean results (Figures 28 and 30) during the baseline days.

In order to reduce the filterable effluent TKN variation in experiment D6 a greater SSRT would be necessary according to the pseudo




FIG. 32 OBSERVED RESPONSE TO INORGANIC NITROGEN STEP




FIG. 33 OBSERVED RESPONSE TO NATURAL DAILY CONCENTRATION VARIATION

"steady-state" relationships developed. This is verified by reference to the baseline day results for the separate sludge system in experiment D8 (Figure 32). The influent loading conditions were comparable to that encountered in experiment D6 but the effluent filterable TKN variation was reduced to the residual level (Figure 34).

In addition to experimental observation, the dynamic models developed in experiment D5 can be used to examine the response of the combined and separate sludge systems to natural influent concentration variations. The transfer function component of a TF-N model (equation 18) expresses the deterministic nature of the particular process. The noise model accounts for the unexplained output variations. Therefore the effluent variation due to the nature of the combined and separate sludge processes is determined from the transfer function model results.

By simulating the influent conditions encountered during the baseline days of experiments D3 and D6 the filterable TKN effluent variation was predicted using both the transfer function models and the combined transfer function-noise models. The transfer function models predict no significant filterable effluent TKN response in the combined or separate sludge systems for the influent conditions approximated from D3 (Figure 35). These results support the observed values (Figure 33). Simulating the influent conditions encountered in experiment D6, both the transfer function and combined TF-N models predict a significant filterable effluent TKN response for both SSC and TSS sludge systems (Figure 35). The observed effluent variation (Figure 33) over the twenty-four hour period is better predicted by the TF-N models. Details concerning the simulation and prediction methods are included in Appendix F.

The TF-N models were used to examine the response of the carbon removal nitrification systems to natural concentration and flow variation. In simulating hydraulic input conditions, the flow pattern and extent of variation chosen (maximum to average to minimum equal to 1.6:1.0:0.5) were representative of that to the Burlington Skyway Treatment Plant. The mean daily flow was set at the value maintained during the baseline days of the dynamic experiments (4.55 l/min). The simulated level and variation




FIG. 34 RESPONSE OF SEPARATE SLUDGE SYSTEM TO D8 BASELINE DAY INPUT




FIG. 35 PREDICTED RESPONSE TO SIMULATED DAILY CONCENTRATION VARIATION

in filterable TKN concentrations was that representing the D6 conditions. In response to these superimposed loading conditions, the TF-N model for the combined sludge system (SSC) predicts a greater effluent variation than for the variable concentration input alone (Figure 36). A similar result was found for the separate sludge system. Although a greater hourly variation in filterable TKN concentration is predicted, little difference exists in the calculated daily mean results (Figure 36) based on flow-weighted sampling. This would indicate that the relationships previously developed representing the daily mean filterable TKN removal performance under pseudo "steady-state" conditions may be used to determine results under variable flow conditions. This contention is supported by the observed results during a screening experiment in Phase 3 (Jan. 1975). In this experiment a sinusoidal flow pattern was superimposed upon the natural concentration variation (Figure 37). The observed response of the combined sludge system (Figure 37) was predicted closely by the pseudo "steady-state" relationship (Figure 17).




FIG. 36 PREDICTED RESPONSE TO SIMULATED DAILY CONCENTRATION AND FLOW VARIATION




FIG. 37 RESPONSE OF COMBINED SLUDGE SYSTEM TO DAILY CONCENTRATION AND FLOW VARIATION

CONCLUSIONS

This study, conducted under pseudo "steady-state" and non-steady conditions, supports the hypothesis that biological nitrification is feasible employing combined or separate sludge systems even under cold climatic conditions.

It may be concluded that under pseudo "steady-state" conditions:

- 1) Equal degrees of nitrification can be accomplished in combined or separate sludge nitrification systems.
- 2) For nitrogen levels commonly found in domestic wastewater, the rate of nitrification, expressed as the filterable TKN removed per unit mass of activated sludge, is independent of the concentration of filterable TKN down to values greater than 1.0 mg/l.
- 3) Even with complete nitrification an average value of approximately 1.0 mg/l of organic nitrogen can be expected in the filterable fraction of the effluent.
- 4) Temperature and solids residence time significantly effect filterable TKN removal in combined and separate sludge systems. Nitrification is essentially independent of hydraulic residence time.
- 5) A separate sludge system will produce a significantly greater amount of sludge compared to a combined sludge system.

An evaluation of the response of combined and separate sludge systems to non-steady influent conditions indicates that:

- 1) A pulse change in influent pH will cause a lower reactor pH but of shorter duration in a separate sludge system. The accompanying increase in effluent concentration of both filterable TKN and COD will be less.
- 2) For a step down in temperature, the increase in effluent filterable TKN concentration for a separate sludge system will be considerably slower than that of a combined sludge system.
- 3) Transfer function models together with time series models adequately describe both combined and separate sludge systems

operating under critical nitrifying conditions and are able to forecast the temporal variation in nitrification achieved.

- 4) The models developed for both separate and combined sludge systems indicate:
 - a) effluent filterable TKN concentration increases with filterable TKN loading but does not respond significantly to OC loading, and
 - b) effluent nitrate-N increases with filterable influent TKN concentration and decreases with influent filterable OC loading.
- 5) A greater effluent filterable TKN variation can be expected from nitrifying systems operated under variable flow and concentration inputs than for variable concentration inputs alone. The pseudo "steady-state" relationships can predict the daily mean effluent results based on flow-weighted sampling.



RECOMMENDATIONS FOR FUTURE WORK

- 1) A detailed investigation at the pilot scale level aimed at developing design criteria for total nitrogen removal in combined sludge nitrification and denitrification systems.
- 2) Develop and demonstrate the applicability of dynamic models for nitrifying activated sludge systems over a wide range of process conditions (temperature, solids retention time, etc.). These models may take the form of simple empirical transfer function-noise models or may be composed of deterministic and stochastic functions.
- 3) Investigate the feasibility of employing simple transfer function-noise models to describe the dynamic behaviour of existing full-scale wastewater treatment plants and applying them as a tool for process control and design extension.

REFERENCES

- Anderson, J.H., "Studies on the Oxidation of Ammonia by Nitrosomonas", Biochem. J., 95, 684 (1965).
- Barth, E.F., Brenner, R.D. and Lewis, R.F., "Chemical-Biological Control of Nitrogen and Phosphorus in Wastewater Effluents", J.Wat. Pollut Control Fed., 40, 2040 (1968).
- Beckman, W.J., Avendt, R.J., Mulligan, T.J., and Kehrberger, "Combined Carbon Oxidation-Nitrification," J.Wat. Pollut. Control Fed., 44, 10, 1916 (1972).
- Benedict, A.H. and Carlson, D.A. "Temperature Acclimation in Aerobic Bio-oxidation Systems", J.Wat. Pollut. Control Fed., 45, 1, 10 (1973).
- Blackwell, L.G. "A Theoretical and Experimental Evaluation of the Activated Sludge Process". Ph.D. Thesis, Clemson University, South Carolina (1971).
- Bobrow, A., Johnson, A.I., and Ponton, J.W. "Dynamics Manual and Application Studies". Dept. of Chemical Engineering, McMaster University, Hamilton, Canada (1970).
- Boon, B. and Laudelot, H., "Kinetics of Nitrate Oxidation by Nitrobacter winogradski", Biochem. J., 85, 440 (1962).
- Box, G.E.P. and Jenkins, G.M., Time Series Analysis, Forecasting and Control, Holden Day, San Francisco, Calif., p 379 (1970a).
- Box, G.E.P. and Jenkins, G.M., Time Series Analysis, Forecasting and Control, Holden Day, San Francisco, Calif., p 346 (1970b).
- Box, G.E.P. and Jenkins, G.M., Time Series Analysis, Forecasting and Control, Holden Day, San Francisco, Calif., p 402 (1970c).

Box, G.E.P. and Jenkins, G.M., Time Series Analysis, Forecasting and Control, Holden Day, San Francisco, Calif. p 363 (1970d).

Brown and Caldwell, "Case Histories of Nitrification and Denitrification Facilities" EPA Technology Transfer Design Seminar for Wastewater Treatment Facilities, Orlando, Florida (1974).

Brown and Caldwell, "Process Design Manual for Nitrogen Control", U.S. Environmental Protection Agency, Technology Transfer, Washington, October (1975).

Busch, A.W., Aerobic Biological Treatment of Waste Waters, Principles and Practice, Oligodynamics Press, Houston, Texas, Chapt. 3, p. 94 (1971).

Buswell, A.M., Shiota, T., Lawrence, N. and Meter, I.V., "Laboratory Studies on the Kinetics of the Growth of Nitrosomonas with Relation to the Nitrification Phase of the BOD Test", Appl. Micro., 2, 21 (1954).

Deppe, K. and Engel, H., "Untersuchungen uber Temperatureabhangigkeit der Nitratbildung durch Nitrobacter winogradski Buch. bei ungehemmten und gehemmten Wachstum", Zentbl. Bakt. Parasitkde 11, 113, 561 (1960).

Design and Analysis of Industrial Experiments, Edited by Davies, O.L., 2nd edition, Hafner Publishing Co., New York, p.290 (1956).

Downing, A.L., Painter, H.A. and Knowles, G., "Nitrification in the Activated Sludge Process", J. Inst. Sew. Purif., 130 (1964).

Downing, A.L., Tomlinson, T.G. and Truesdale, G.A., "Effect of Inhibitors on Nitrification in the Activated Sludge Process", Institute of Sewage Purification Journal and Proceedings, 537 (1964).

Downing, A.L. and Knowles, G., "Pollution Dynamics in Biological Treatment Plants", Advances in Water Pollution Research, Vol 2, Wat. Pollut. Control Fed., Washington, D.C., p. 117 (1967).

Draper, N.E., and Smith, H., Applied Regression Analysis, John Wiley and Sons Inc., New York, p. 67 (1968).

Engel, M.S., "The Growth and Autotrophic Metabolism of Nitrosomonas europaea", Ph.D. Thesis, Cornell University, Ithaca, N.Y. (1959).

Gibbs, M. and Schiff, J.A., Plant Physiology, VOL. 1B, edited by F. C. Steward, Academic Press, N.Y., Chapt. 5 (1960).

Haug, R.T. and McCarty, P.L., "Nitrification with Submerged Filters", J. Wat. Pollut. Control Fed., 44, 11, 2086 (1972).

Himmelblau, D.M., Process Analysis by Statistical Methods, John Wiley and Sons Inc., P. 194 (1970).

Hofman, T. and Lees, H., "The Biochemistry of the Nitrifying Organisms", Biochemical J., 54, 579 (1953).

Hoover, S.R., Porges, N. "Assimilation of Dairy Wastes by Activated Sludge, 11". Sewage and Industrial Wastes, 29, 306 (1952).

Huang, C.S. and Hopson, N.E., "Nitrification Rate in Biological Processes", Jour. Envir. Eng. Div., Proceedings of the American Soc. of Civil Engineers, 100, 409 (1974).

Huang, C.S., "Kinetics and Process Factors of Nitrification on a Biological Film Reactor", Ph.D. Thesis, State University of New York, Buffalo, N.Y. (1973).

IAWPR, Conference on Nitrogen as a Water Pollutant, Proceedings VOL. 3, Copenhagen, Denmark (1975).

IBM, Continuous System Modelling Program (360A-CX-16X) Application Description, 4th Edition, White Plains, New York (1972).

Jeffrey, E.A. and Morgan, P.F., "Oxygen Demand of Digested Sludge Liquor", Sew. Ind. Wastes, 31, 1, 20 (1959).

Kiff, R.J., "The Ecology of Nitrification/Denitrification in Activated Sludge", Water Pollution Control, 71, 475 (1972).

Kluyver, A.J. and Doner, H.L., "Die Einheit in der Biochemie", Chem. Zelle., 13, 134 (1926).

Knowles, G., Downing, A.L. and Barrett, M.J., "Determination of Kinetic Constants for Nitrifying Bacteria in Mixed Culture with the Aid of an Electronic Computer", J. gen. Microbiol., 38, 263 (1965).

Knowles, G., Downing, A.L. and Barrett, M.J., "Denitrification of Kinetic Constants for Nitrifying Bacteria in Mixed Culture with the Aid of an Electronic Computer", J. gen. Microbiol., 38, 263 (1965).

Laudelout, H. and Van Tichelen, L., "Kinetics of the Nitrite Oxidation by Nitrobacter winogradski", J. Bact., 79, 39 (1960).

Lawrence, A.M. and Brown, C.G., "Biokinetic Approach to Optimal Design and Control of Nitrifying Activated Sludge Systems", Presented at the Annual Meeting of the New York Wat. Pollut. Control Association, New York, (1973).

Lees, H., Simpson, J.R. "The Biochemistry of the Nitrifying Organisms. 5. The Nitrite Oxidation by Nitrobacter". Biochemistry Journal 65, 297, 1957.

Levenspiel, O., Chemical Reaction Engineering, John Wiley and Sons Inc., 5th E., p 242 (1967).

Lewis, R.F., "Isolation and Growth of Nitrosomonas in Pure Culture", ph.D. Thesis, Rutgers State University, New Jersey (1959).

- Lijklema, L. "Model for Nitrification in Activated Sludge Process", Environmental Science and Technology 7, 428 (1973).
- Loveless, J.E. and Painter, H.A., "The Influence of Metal Ion Concentrations and pH Value on the Growth of a Nitrosomonas Strain Isolated from Activated Sludge", J. gen. Microbiol., 52, 1 (1968).
- McGregor, J.F., "Optimal Choice of the Sampling Interval for Discrete Process Control," Technometrics, 18, 2, 151 (1976).
- Meyerhof, O., "Untersuchungen uber der Atmungsvorgang nitrifizierenden Bakterien. I. Die Atmung des Nitratbildners", Arch. ges. Physiol., 164, 353 (1916).
- Mulbarger, M.C., "Nitrification and Denitrification in Activated Sludge Systems", J. Wat. Pollut. Control Fed., 43, 10, 2059 (1971).
- Painter, H.A., "Microbial Transformations of Inorganic Nitrogen", IAWPR, Conference on Nitrogen as a Water Pollutant, Proceedings VOL. 3, Copenhagen, Denmark (1975).
- Parkin, G.F. and McCarty, P.L., "Characteristics and Removal of Soluble Organic Nitrogen in Treated Effluents," Progress in Water Technology, 7, 3, 435 (1975).
- Poduska, R.A. and Andrews, J.F., "Dynamics of Nitrification in the Activated Sludge Process", J. Wat. Pollut. Control Fed., 47, 11, 2599 (1975).
- Poduska, R.A. "A Dynamic Model of Nitrification for the Activated Sludge Process", Ph.D. Thesis, Clemson University, South Carolina (1973).
- Powell, E.O. "The Growth Rate of Microorganisms as a Function of Substrate Concentration". Microbial Physiology and Continuous Culture. London H.M.S.O. 34 (1967).

Prakasam, T.B.S. and Loehr, R.C., "Microbial Nitrification and Denitrification in Concentrated Wastes," Water Research, 6, 859 (1972).

Smith, R., Eilers, R.G. "Simulation of the Time-Dependent Performance of the Activated Sludge Process Using the Digital Computer". U.S. Department of the Interior, FWPCA, Cincinnati, Ohio (1970).

Srinath, E.G., Prakasam, T.B.S. and Loehr, R.C., "A Technique for Estimating Active Nitrifying Mass and Its Application in Designing Nitrifying Systems". Present at the 29th Annual Purdue Industrial Waste Conference, Purdue University, West Lafayette, Indiana (1974).

Standard Methods for the Examination of Water and Wastewater, 13th Ed. Amer. Publ. Health Assn., Washington, D.C. (1971).

Sutton, P.M., Murphy, K.L., and Dawson, R.N., "Low Temperature Biological Denitrification of Wastewater", J. Wat. Pollut. Control Fed., 47, 1, 122 (1975).

Sutton, P.M., Murphy, K.L., Jank, B. E. and Monaghan, B.A., "Efficacy of Biological Nitrification", J. Wat. Pollut. Control Fed., 47, 11, 2665 (1975).

Tan, P.G.C. "A Generalized, Steady-State Simulation of Wastewater Treatment Plants", M. Eng. Thesis, McMaster University, Hamilton, Canada (1972).

Tenney, M.W. and Echelberger, W.F., "Removal of Organic and Eutrophying Pollutants by Chemical-Biological Treatment", EPA Report No. R2-72-076 (1972).

Timpany, P.L., "Variations of Axial Mixing in an Aeration Tank", M.Eng. Thesis, McMaster University, Hamilton, Canada (1966).

Toerber, E.D., Paulson, W.L. and Smith, H.S., "Comparison of Completely Mixed and Plug Flow Biological Systems", J. Wat. Pollut. Control Fed., 46, 8, 1994 (1974).

Toerber, E.D., "Full Scale Parallel Activated Sludge Process Evaluation". U.S. Environmental Protection Agency, Report R2-72-065 (1972).

Verstaete, W. and Alexander, M., "Heterotrophic Nitrification by Arthrobacter", J. Bact., 110, 955 (1972).

Wild, H. E., Sawyer, C.N. and McMahon, T.C., "Factors Affecting Nitrification Kinetics", J. Wat. Pollut. Control Fed., 43, 9, 1845 (1971).

Wilson, R.W., "Continuous Fixed Film Biological Nitrification and Denitrification of Wastewater," M.Sc. Thesis, McMaster University, Hamilton, Canada (1975).

Wilson, R.W., Murphy, K.L., Sutton, P.M. and Jank, B.E., "Nitrogen Control: Design Considerations for Supported Growth Systems", Presented at 58th Annual Conference of Wat. Pollut. Control Fed., Miami Beach (1975).

Wuhrmann, K., "Effects of Oxygen Tension on Biochemical Reactions in Sewage Purification Plants", Advances in Biological Waste Treatment, Proceedings 3rd Conf. Biol. Waste Treatment, edited by W. W. Eckenfelder and J. McCabe, Pergamon Press, New York, p 27 (1963).

Wuhrmann, K. and Mechsner, K., "Beitrag zur Kenntnis der Mikrobiellen Denitrifikation", Path. Microbiol., 26, 579 (1965).

Wuhrmann, K. "Objectives, Technology and Results of Nitrogen and Phosphorous Removal Processes". Advances in Water Quality Improvement. Vol. 1, edited by Gloyna, E.F., Eckenfelder, W.W., University of Texas Press, p 121 (1968).

APPENDIX A

Deterministic Dynamic Model for SSC System

In modelling the SSC system, substrate and material balances are presented under the assumptions as presented in the section "Deterministic Dynamic Models."

Substrate balances

a) Filterable degradable organic carbon:

$$V_1 \frac{d S_1^C}{dt} = F_0 S_0^C + (F_{R1} - F_{W1}) S_1^C - F_1 S_1^C - \frac{u^H X_1^H V_1}{Y^H} \dots\dots\dots(23)$$

$$F_1 = F_0 + F_{R1} - F_{W1}$$

$$F_{R1} - F_{W1} = F_1 - F_0 \dots\dots\dots(24)$$

equation (23) becomes:

$$V_1 \frac{d S_1^C}{dt} = F_0 S_0^C - F_0 S_1^C - \frac{u^H X_1^H V_1}{Y^H} \dots\dots\dots(25)$$

where, $u^H = K_G^H S_1^C$, and

K_G^H = linear growth coefficient for heterotrophs (T^{-1})

b) Ammonia nitrogen:

$$V_1 \frac{d S_1^{NH_4}}{dt} = F_0 S_0^{NH_4} + (F_{R1} - F_{W1}) S_1^{NH_4} - F_1 S_1^{NH_4}$$

$$- \frac{u^{NS} X_1^{NS} V_1}{Y^{NS}} - .14 \frac{u^H X_1^H V_1}{Y^H} \dots\dots\dots (26.)$$

using equation (24), equation (26) becomes:

$$V_1 \frac{d S_1^{NH_4}}{dt} = F_0 S_0^{NH_4} - F_1 S_1^{NH_4} - \frac{u^{NS} X_1^{NS} V_1}{Y^{NS}} - .14 \frac{u^H X_1^H V_1}{Y^H} \dots\dots\dots (27)$$

where, the substrate utilization term u^{NS} is expressed by:

$$u^{NS} = u^{*NS} \frac{S_1^{NH_4}}{(K_s^{NS} + S_1^{NH_4})}$$

u^{*NS} = maximum growth rate coefficient (T^{-1}), and

K_s^{NS} = substrate concentration at one half maximum growth rate (M/L^3).

In the above substrate balance, the rate of disappearance due to heterotrophic growth is estimated from considering the heterotrophs to be represented by the composition $C_5H_7NO_2$ (Hoover and Porges, 1952).

c) Nitrite nitrogen:

$$V_1 \frac{d S_1^{NO_2}}{dt} = F_0 S_0^{NO_2} + (F_{R1} - F_{W1}) S_1^{NO_2} - F_1 S_1^{NO_2} + \frac{u^{NS} X_1^{NS} V_1}{Y^{NS}} - \frac{u^{NB} X_1^{NB} V_1}{Y^{NB}} \dots\dots\dots (28)$$

using equation (23), equation (27) becomes:

$$V_1 \frac{d S_1^{NO_2}}{dt} = F_0 S_0^{NO_2} - F_1 S_1^{NO_2} - \frac{u^{NS} X_1^{NS} V_1}{Y^{NS}} - \frac{u^{NB} X_1^{NB} V_1}{Y^{NB}} \dots\dots\dots(29)$$

where the substrate utilization term u^{NB} is expressed by:

$$u^{NB} = \frac{u^{*NB} S_1^{NO_2}}{(K_s^{NB} + S_1^{NO_2})}$$

u^{*NB} = maximum growth rate coefficient (T^{-1}), and

K_s^{NB} = substrate concentration at one half maximum growth rate (M/L^3).

d) Nitrate nitrogen:

$$V_1 \frac{d S_1^{NO_3}}{dt} = F_0 S_0^{NO_3} + (F_{R1} - F_{W1}) S_1^{NO_3} - F_1 S_1^{NO_3} + \frac{u^{NB} X_1^{NB} V_1}{Y^{NB}} \dots\dots\dots(30)$$

using equation (23), equation (29) becomes:

$$V_1 \frac{d S_1^{NO_3}}{dt} = F_0 S_0^{NO_3} - F_1 S_1^{NO_3} + \frac{u^{NB} X_1^{NB} V_1}{Y^{NB}} \dots\dots\dots(31)$$

Organism balances

Assuming the concentration of organisms in the feed stream is negligible ($X_0 = 0$), mass balances for heterotrophs, Nitrosomonas, and Nitrobacter can be written as:

$$V_1 \frac{d X_1^H}{dt} = (F_{R1} - F_{W1}) X_{R1}^H - F_1 X_1^H + V_1 (u^H - K_D^H) X_1^H \quad \dots\dots\dots(32)$$

$$V_1 \frac{d X_1^{NS}}{dt} = (F_{R1} - F_{W1}) X_{R1}^{NS} - F_1 X_1^{NS} + V_1 (u^{NS} - K_D^{NS}) X_1^{NS} \quad \dots\dots\dots(33)$$

$$V_1 \frac{d X_1^{NB}}{dt} = (F_{R1} - F_{W1}) X_{R1}^{NB} - F_1 X_1^{NB} + V_1 (u^{NB} - K_D^{NB}) X_1^{NB} \quad \dots\dots\dots(34)$$

where, K_D^H = decay coefficient for heterotrophs (T^{-1}),

K_D^{NS} = decay coefficient for Nitrosomonas (T^{-1}), and

K_D^{NB} = decay coefficient for Nitrobacter (T^{-1}).

Representing the settler performance by an efficiency E_1 , operation is according to:

$$X_2^H = (1.0 - E_1) X_1^H \quad \dots\dots\dots(35)$$

$$X_2^{NS} = (1.0 - E_1) X_1^{NS} \quad \dots\dots\dots(36)$$

$$X_2^{NB} = (1.0 - E_1) X_1^{NB} \quad \dots\dots\dots(37)$$

A solids balance around the settler yields:

$$F_1 X_1^H = F_2 X_2^H + F_{R1} X_{R1}^{NH}$$

and applying equation (35) leads to:

$$F_1 X_1^H = F_2 (1.0 - E_1) X_1^H + F_{R1} X_{R1}^{NH} \quad \dots\dots\dots(38)$$

The value of E_1 can be determined according to:

$$E_1 = \frac{X_1 - X_2}{X_1} \quad \dots\dots\dots(39)$$

Substituting equation (37) into the organism balance equation (31) and rearranging the result is:

$$V_1 \frac{dX_1^H}{dt} = V_1 X_1^H (u^H - K_D^H) - F_{W1} X_{R1}^H - F_2 (1.0 - E_1) X_1^H \dots\dots\dots(40)$$

The same expressions are applicable in terms of Nitrosomonas and Nitrobacter.

In summary, the important relationships describing the dynamic operation of the single-stage alternative appear in the information flow diagram (Figure 2).

Parameter Values for Dynamic Models

Before the equations which comprise the proposed dynamic models can be solved, values for the various parameters must be determined.

In the proposed models describing organic carbon degradation and resulting heterotrophic growth, values for the substrate utilization coefficient K_G^H and decay coefficient K_D^H , must be known or assumed. During steady-state simulation studies, Tan (1972), determined these values using a biological culture derived from an activated sludge plant treating the same raw sewage. Because the emphasis in this study is on nitrification, his values could be assumed sufficient for use in the organic carbon utilization and heterotrophic growth functions.

The u^* and K_S values in the Monod models for nitrification can be determined by various methods.

Determinations from pseudo "steady-state" studies, previously discussed, can be used to derive the parameter values. For example considering the single-stage carbon removal-nitrification alternative, at steady-state, equation 26 becomes:

$$F_0 (S_0^{NH_4} - S_1^{NH_4*}) = \frac{u^{NS} X_1^{NS} V_1}{Y^{NS}}, \dots\dots\dots(41)$$

$$\text{where, } u^{NS} = u^{*NS} \frac{S_1^{NH_4*}}{K_S^{NS} + S_1^{NH_4}} \dots\dots\dots(42)$$

substituting equation 41 into 40 and rearranging leads to:

$$\frac{T_1 X_1^{NS}}{S_0^{NH_4} - S_1^{NH_4}} = \frac{Y^{NS} K_S^{NS}}{u^{*NS}} \frac{1}{S_1^{NH_4}} + \frac{Y^{NS}}{u^{*NS}}, \dots\dots\dots(43)$$

where, $T_1 = \frac{V_1}{F_0}$, and $S_1^{NH_4}$ is the corrected effluent ammonia

concentration representing the concentration resulting if heterotrophic growth and subsequent nitrogen uptake did not occur. A graphical method can then be used to determine K_S^{NS} and u^{*NS} knowing Y^{NS} , from operating over a range of F_0 values.

Batch studies can be used to determine the kinetic parameter values. For ammonia utilization by Nitrosomonas, the batch process equations are:

$$\frac{d S^{NH_4}}{dt} = \frac{u^{*NS} S^{NH_4} X^{NS}}{Y^{NS} (K_S^{NS} + S^{NH_4})}, \text{ and} \dots\dots\dots(44)$$

$$\frac{d X^{NS}}{dt} = \frac{u^* S^{NH_4} X^{NS}}{K_S^{NS} + S^{NH_4}} - K_D^{NS} X^{NS}. \dots\dots\dots(45)$$

The kinetic coefficients in these equations can be determined by a computer simulation of the unsteady-state equations. For a given set of initial parameter values, the simulation will produce curves of X^{NS} and S^{NS} versus time. Values of Y^{NS} and K_D^{NS} will be supplied as input and therefore are not part of the parameter set. Both the above batch and previously developed continuous time-dependent equations require initial values for the organism concentrations. Determination of these initial values can be afforded by developing a relationship, through batch experiments, between ammonia removal rate and percent Nitrosomonas present.

The above parameter determination procedures are applicable as well to the carbon and nitrite substrates involved and the corresponding heterotrophic and Nitrobacter organisms groups. A more direct procedure for determining an initial estimate of the heterotrophic population would be through the use of oxygen uptake measurements in which nitrification was inhibited (Toerber, 1972).

Applying kinetic coefficients determined from batch or continuous pseudo"steady-state" studies assumes that they are applicable to

transient conditions.

Another method of determining the parameters for the models developed, involves utilizing an optimization search routine along with the particular dynamic simulation method. The search routine determines the parameter values which give the best fit to the transient data.

Yield and decay coefficients for the nitrifying bacteria are quite small making experimental determination difficult. A review of the literature may be used to determine these values.

APPENDIX B

Solids Retention Time (SRT) Calculation

The solids retention time for each reactor-clarifier system is defined as the solids in the aeration tank divided by the solids intentionally wasted or lost over the clarifier weir per day. During pseudo "steady-state" period the calculated SRT is based on a cumulative mean aeration tank MLSS concentration and total solids wasted or lost from the system. For the combined sludge systems (SSC, TSC, FSC), the final result is the system solids retention time (SSRT) for that pseudo "steady-state" period (Table B1). For the separate sludge system (TSS) the SRT for B1 and B2 were calculated in the above manner. The TSS system solids retention time (SSRT) was then calculated weighting the individual SRT's for B1 and B2 according to their aeration tank volumes (Table B1). The dates over which the SSRT was calculated during each pseudo "steady-state" period are indicated in the "Data Listing" section under "Mode of Operation" (Appendix B).

Analytical Procedures

Total kjeldahl nitrogen

Total kjeldahl nitrogen analyses (organic plus ammonia nitrogen) were performed according to Technicon Auto-analyser Industrial Method 146-71A. Essentially this procedure consists of digestion of organic matter at 380°C followed by measurement of the ammonia produced using the Berthelot reaction in which the formation of a blue indophenol complex occurs when ammonia reacts with sodium phenate followed by the addition of sodium hypochlorite. Glycine standards were used for calibration. For keeping unfiltered samples homogenized in the sample cups the system has two air aspirators. One aspirator provides complete mixing in the cup being sampled while the second aspirator mixes the next cup on the tray.

BLE B1 SOLIDS RETENTION TIME CALCULATIONS - RUNS PSS - 21 AND - 22

TSC SYSTEM

Date	Aeration Tank MLSS		†Cumul. Mean A	Mean Plant Solids g	Intentional Waste Vol. l	Intentional Waste Conc. g/l	Wasting Solids Waste g	Unintentional Wasting g	Total Waste g	Cumul. Total Waste g	Cumul. SRT days
	A1	A2									
(1974)											
17/6	6.47	7.49	7.14	15593.8	45.5	10.26	466.8	104.8	2099.2	2099.2	7.8
					47.8	9.92	474.2				
					95.5	11.03	1053.4				
18/6	5.94	5.795	5.84	14178.5	91.0	9.93	903.6	146.8	2489.7	4588.9	6.2
					138.8	10.37	1439.3				
19/6	5.91	5.51	5.65	13562.6	95.5	9.19	877.6	188.7	1728.1	6317.0	6.4
					63.7	10.39	661.8				
20/6	6.02	5.885	5.93	13409.8	113.8	10.13	1152.8	157.2	1310.0	7627.0	7.0

Note: *A is weighted MLSS according to A1 and A2 tank volumes.
 †Cumul. stands for cumulative.

TABLE B1 (Cont'd)

TSS SYSTEM: REACTOR B1

Date	Aeration Tank B1	Tank g/l Cumul. Mean B1	MLSS	Mean Plant Solids g	Intentional Waste Vol. l	WASTING Waste Conc. g/l	WASTING Solids Waste g	Unintentional Wasting g	Total Waste g	Cumul. Total Waste g	Cumul. SRT days
(1974)											
17/6	3.81	3.81	3.81	3017.5	159.3 182	8.69 7.47	1384.4 1359.5	125.8	2869.7	2869.7	1.05
18/6	3.585	3.69	3.69	2928.4	136.5 204.8	6.94 9.93	947.3 2033.7	325.0	3306.0	6175.7	0.95
19/6	3.69	3.69	3.69	2928.4	159.3 227.5	7.37 7.00	1174.0 1592.5	146.8	2913.3	9089.0	0.97
20/6	3.35	3.61	3.61	2858.1	182.0 273.0	6.60 5.53	1201 1509.7	52.4	2763.1	11852.1	*0.96

TABLE B1 (Cont'd)

TSS SYSTEM: REACTOR B2

Date	Aeration Tank B2 g/l Cumul.	Tank MLSS Mean B2	Plant Solids g	Intentional Waste Vol. l	WASTING Waste Conc. g/l	WASTING Solids Waste g	Unintentional Wasting g	Total Waste g	Cumul. Total Waste g	Cumul. SRT days
(1974)										
17/6	4.09	4.09	5693.3	35.5	6.65	236.1	125.8	361.9	361.9	15.7
18/6	3.535	3.81	5303.5	68.3	6.36	434.1	109.8	538.9	900.8	11.8
19/6	3.610	3.74	5213.0	68.3	6.37	435.1	188.7	623.8	1529.6	10.3
20/6	3.05	3.57	4971.2	35.5	5.41	192.0	83.9	275.9	1800.5	* 11.0
<p>Note: * TSS system solids retention time (SSRT) = $\frac{174 (.96) + 306 (11.0)}{480} = 7.4$</p>										

Ammonia

Analyses of ammonia nitrogen were conducted using Technicon Auto-analyser Industrial Method 98-70W. This is essentially the same technique employed for Total kjeldahl nitrogen with the omission of the selenium dioxide/sulphuric acid/perchloric acid digestion step which ammonifies the organic nitrogen fraction. Ammonium chloride standards provided calibration.

Nitrite

Technicon Auto-analyser Industrial Method 100-70W was used for nitrite-nitrogen determinations. This technique involves a reaction between nitrite and sulphanilamide under acid conditions to form a diazo compound which in turn is coupled with N-1-naphthylethylenediamine to form a reddish purple azo dye. Colourimetric determination is then made on the sample.

Nitrate plus nitrite

Nitrate plus nitrite-nitrogen analyses were performed using Technicon Auto-analyser Industrial Method 100-70W. In this method, the nitrate-nitrogen is reduced to nitrite in the copper-cadium reduction column. The sample is then analysed for nitrite nitrogen as described previously.

Chemical oxygen demand (COD)

Early COD determinations were done according to the dichromate reflux method described in "Standard Methods" (1971). During the research period, a modified version of Technicon Auto-analyser Industrial Method No. 268-73W was adapted for COD analysis. A Technicon Solidprep 11 sampler was introduced in place of the normal sampler. This allowed analysis of samples containing suspended solids and provided high shear homogenization of samples with the dichromate and sulphuric acid reagents. Standard solutions were prepared using ammonium chloride. The standards were first analysed using the "Standard Methods" reflux technique and then analysed on the Technicon equipment. The standard peaks produced on the Technicon System were then calibrated against the "Standard Methods" results.

This complicated approach was necessary since the sample digestion time in the Auto-analyser was shorter than that in the standard reflux test. This resulted in a lower degree of reaction completion with the Auto-analyser when heterogeneous sewage samples were tested. With this procedure modification in effect, Auto-analyser COD results for sewage samples were generally only 5 to 7 percent lower than results obtained via the "Standard Methods" technique.

Biochemical oxygen demand (BOD)

The 5 day, 20 degree C BOD determinations were performed according to the method described in "Standard Methods" pages 489 - 495 (1971).

Filterable organic carbon (FOC)

Twenty micro-litre samples previously acidified and purged were injected into a Beckman Infrared Carbon Analyser. The resulting peaks were compared to a calibration curve prepared from standards using anhydrous potassium biphthalate.

Suspended solids

Gelman .45 micron glass fibre filters were dried, but not washed, for at least two hours in a 103 degree C oven. They were then cooled in a dessicator and weighed. Suspended solids determinations were made by filtering a minimum of 10 ml of solution through a filter. The filter was then re-dried at 103 degrees for two or more hours, dessicated for 15 minutes and re-weighed. The increase in weight was taken as a measure of the suspended solids.

Dissolved oxygen

An Electronic Instruments Ltd. Dissolved Oxygen Metre Model 15A was used for dissolved oxygen determinations. It was found necessary to calibrate the probe roughly once a week.

Temperature

The D.O. metre also included a temperature probe and this was used for measurement of the feed stream and the reactor

temperatures.

pH

pH was measured using an Orion Specific Ion Meter (Model 401) together with Fisher Combination electrodes (Cat. 1e-639-90).

Alkalinity

By using the Orion pH meter, 50 ml samples were titrated to a pH of 4.8 by addition of .02 N sulphuric acid. Results were expressed as mg/l as calcium carbonate.

Data Listing - Mode of Operation, Reactor Operating Results, Analyses

The complete pilot plant data listing, composed of three sections, appears on the following pages. Contained under "Mode of Operation" is a chronological listing of information concerning pilot plant flow rates, operating reactor or mode, and raw sewage characteristics. This section also lists information on plant upsets, identifies acclimation and chemical addition periods, and notes the period over which the SSRT calculation was made for each plant. Contained under "Reactor Operating Results" is a chronological listing of the solids concentrations in the reactors, the waste concentrations and amounts, and other reactor characteristics such as pH, temperature, etc. Some clarifier effluent characteristics are also listed for the reactor system. Contained under "Analyses" is a chronological listing of analytically determined results for the various reactor streams.

The abbreviations and symbols used in the data listing are interpreted in Appendix G.

MODE OF OPERATION

YEAR	DATE	DAY	MON	TIME	STOP	OPERATING MODE	FFED RATES	RETURN SLUDGE RATES	PH TEMP	SS	ALK
74	23/04	AM	AND	STOP	1	24/04/74	0900 HRS	1.6	8.0	7.68	---
74	24/04	AM	AMMONIA SPIKE	1.25	1.25	1.25	1.6	1.6	7.6	131	---
74	25/04	AM	STOP	1.25	1.25	1.25	1.6	1.6	AT 0900 HRS	---	---
74	26/04	AM	STOP	1.25	1.25	1.25	1.6	1.6	7.5	174	204
74	27/04	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.4	13.5	240
74	28/04	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.5	8.0	174
74	29/04	AM	PLANT A AND PLANT B	1.25	1.25	1.25	1.6	1.6	TO SSRT 10 DAYS	AND 20 C	---
74	30/04	AM	PLANT A AND PLANT B	1.25	1.25	1.25	1.6	1.6	29/04/74 TO 01/05/74	---	---
74	30/04	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.5	20.0	199
74	01/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.3	20.5	192
74	02/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.4	21.3	209
74	03/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.4	21.3	209
74	04/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.4	21.3	209
74	05/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.4	21.3	209
74	06/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.4	21.3	209
74	07/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.4	21.3	209
74	08/05	AM	RETURN SLUDGE	1.25	1.25	1.25	1.6	1.6	7.4	13.5	186
74	09/05	AM	RETURN SLUDGE	1.25	1.25	1.25	1.6	1.6	7.6	14.0	122
74	10/05	AM	RETURN SLUDGE	1.25	1.25	1.25	1.6	1.6	7.4	14.0	170
74	11/05	AM	RETURN SLUDGE	1.25	1.25	1.25	1.6	1.6	7.4	176	202
74	12/05	AM	RETURN SLUDGE	1.25	1.25	1.25	1.6	1.6	7.8	10.0	134
74	13/05	AM	RETURN SLUDGE	1.25	1.25	1.25	1.6	1.6	7.5	14.3	141
74	14/05	AM	AMMONIA SPIKE	1.25	1.25	1.25	1.6	1.6	7.5	14.3	104
74	15/05	AM	STOP	1.25	1.25	1.25	1.6	1.6	AT 0300 HRS	---	---
74	16/05	AM	AMMONIA SPIKE	1.25	1.25	1.25	1.6	1.6	3.8	14.0	176
74	17/05	AM	AMMONIA SPIKE	1.25	1.25	1.25	1.6	1.6	9.9	14.5	131
74	18/05	AM	AMMONIA SPIKE	1.25	1.25	1.25	1.6	1.6	AT 0900 HRS	---	---
74	19/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.6	14.3	256
74	20/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	TO SSRT 7 DAYS	AND 5 C	---
74	21/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7.5	4.5	59
74	22/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	19/05/74 TO 23/05/74	---	---
74	23/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	9.5	---	216
74	24/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	4.0	11.1	213
74	25/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	4.3	1.83	214
74	26/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	3.5	1.37	214
74	27/05	AM	ACCLIMATING	1.25	1.25	1.25	1.6	1.6	7 DAYS	AND 5 C	---

MODE OF OPERATION

YEAR	DATE	DAY	MON	TIME	OPERATING MODE	FEED RATES	RETURN SLUDGE RATES	PH	TEMP	SS	ALK
74	12/07	AM	3	1.6	PLANT A	2.0	2.0	7.2	132	107	
74	13/07/74	AM	1	2.0	ACCLIMATING PLANT A (SSC) AND PLANT B (TSS) TO SSRT 4 DAYS AND 15 C	2.0	2.0				
74	13/07	AM	1	2.0	2.0	2.0	2.0				
74	14/07	AM	1	2.0	2.0	2.0	2.0				
74	15/07	AM	1	2.0	PLANT A AND PLANT B CALCULATIONS BASED FROM 15/07/74 TO 18/07/74	2.0	2.0				
74	15/07/74	AM	1	2.0	AMMONIA SPIKE TO 0.90J HRS TEMPERATURE CONTROLLER START AT 1700 HRS	2.0	2.0				
74	15/07	AM	1	2.0	2.0	2.0	2.0				
74	16/07/74	AM	1	2.0	ACCLIMATING COMPLETE	2.0	2.0				
74	16/07	AM	1	2.0	2.0	2.0	2.0				
74	17/07/74	AM	1	2.0	AMMONIA SPIKE TO 0.90J HRS TEMPERATURE CONTROLLER START AT 1700 HRS	2.0	2.0	7.5	240	113	
74	17/07	AM	1	2.0	2.0	2.0	2.0				
74	18/07	AM	1	2.0	2.0	2.0	2.0				
74	19/07/74	AM	1	2.0	ACCLIMATING PLANT A (TSC) AND PLANT B (TSS) TO SSRT 4 DAYS AND 15 C	2.0	2.0	7.3	652	108	
74	19/07	AM	1	2.0	2.0	2.0	2.0				
74	20/07	AM	1	2.0	AMMONIA SPIKE TO 0.90J HRS TEMPERATURE CONTROLLER START AT 1700 HRS	2.0	2.0				
74	21/07/74	AM	1	2.0	2.0	2.0	2.0				
74	21/07	AM	1	2.0	2.0	2.0	2.0				
74	22/07/74	AM	1	2.0	ACCLIMATING COMPLETE	2.0	2.0				
74	22/07	AM	1	2.0	2.0	2.0	2.0				
74	23/07/74	AM	1	2.0	ACCLIMATING PLANT A (TSC) AND PLANT B (TSS) TO SSRT 7 DAYS AND 20 C	2.0	2.0	7.3	248	104	
74	23/07	AM	1	2.0	2.0	2.0	2.0				
74	24/07	AM	1	2.0	2.0	2.0	2.0				
74	25/07	AM	1	2.0	PLANT A AND PLANT B CALCULATIONS BASED FROM 25/07/74 TO 28/08/74	2.0	2.0				
74	25/07	AM	1	2.0	2.0	2.0	2.0				
74	26/07	AM	1	2.0	2.0	2.0	2.0				
74	27/07	AM	1	2.0	2.0	2.0	2.0				
74	28/07/74	AM	1	2.0	AMMONIA SPIKE TO 0.90J HRS TEMPERATURE CONTROLLER START AT 1700 HRS	2.0	2.0				
74	29/07	AM	1	2.0	2.0	2.0	2.0				
74	30/07/74	AM	1	2.0	ACCLIMATING COMPLETE	2.0	2.0	7.6	272		
74	30/07	AM	1	2.0	2.0	2.0	2.0				
74	31/07	AM	1	2.0	2.0	2.0	2.0				
74	01/08	AM	1	2.0	MIXED LIQUOR IN RAW SEWAGE OVERTNIGHT SOLIDS A2=25, B1=30, B2=23 MG/L	2.0	2.0	7.4	238	111	
74	01/08	AM	1	2.0	OPERATOR ERROR IN ESTIMATE EFFLUENT	2.0	2.0	7.3	-999		
74	02/08	AM	1	2.0	2.0	2.0	2.0				
74	03/08	AM	1	2.0	2.0	2.0	2.0				
74	04/08	AM	1	2.0	PLANT A AND PLANT B CALCULATIONS BASED FROM 04/08/74 TO 08/08/74	2.0	2.0				
74	05/08	AM	1	2.0	OPERATOR ERROR IN ESTIMATE MLSS A1=5800, A2=7000, B1=4000, B2=4000 MG/L	2.0	2.0				
74	05/08	AM	1	2.0	2.0	2.0	2.0				
74	05/08	AM	1	2.0	CLARIFIER TO 0.90J HRS BLANKET PLANT CONTROLLER START AT 1700 HRS DURING WEEK	2.0	2.0				
74	05/08	AM	1	2.0	AMMONIA SPIKE TO 0.90J HRS	2.0	2.0				

YEAR	DATE	OPERATING MODE	FEED RATES	RETURN SLUDGE RATES	PH	TEMP	SS	ALK
74	12/12	1	1.25	1.6	5.8	2.5	120	
74	12/13	1	1.25	1.6	7.6	2.5	108	
74	12/14	1	1.25	1.6				
74	12/14	2	1.25	1.6				
74	12/15	1	1.25	1.6				
74	12/16	1	1.25	1.6				
74	12/17	2	1.25	1.6				
74	12/17	1	1.25	1.6				
74	12/18	1	1.25	1.6				
74	12/19	1	1.25	1.6				
74	12/20	1	1.25	1.6				
75	01/21	2	1.25	1.6				
75	01/22	2	1.25	1.6				
75	01/23	2	1.25	1.6				
75	01/24	2	1.25	1.6				
75	01/25	2	1.25	1.6				
75	01/26	2	1.25	1.6				
75	01/27	2	1.25	1.6				
75	01/28	2	1.25	1.6				
75	01/29	2	1.25	1.6				
75	01/30	2	1.25	1.6				
75	01/31	2	1.25	1.6				
75	02/01	2	1.25	1.6				
75	02/02	2	1.25	1.6				
75	02/03	2	1.25	1.6				
75	02/04	2	1.25	1.6				
75	02/05	2	1.25	1.6				
75	02/06	2	1.25	1.6				
75	02/07	2	1.25	1.6				
75	02/08	2	1.25	1.6				
75	02/09	2	1.25	1.6				
75	02/10	2	1.25	1.6				
75	02/11	2	1.25	1.6				
75	02/12	2	1.25	1.6				
75	02/13	2	1.25	1.6				
75	02/14	2	1.25	1.6				
75	02/15	2	1.25	1.6				
75	02/16	2	1.25	1.6				
75	02/17	2	1.25	1.6				
75	02/18	2	1.25	1.6				
75	02/19	2	1.25	1.6				
75	02/20	2	1.25	1.6				
75	02/21	2	1.25	1.6				
75	02/22	2	1.25	1.6				
75	02/23	2	1.25	1.6				
75	02/24	2	1.25	1.6				
75	02/25	2	1.25	1.6				
75	02/26	2	1.25	1.6				
75	02/27	2	1.25	1.6				
75	02/28	2	1.25	1.6				
75	02/29	2	1.25	1.6				
75	02/30	2	1.25	1.6				
75	03/01	2	1.25	1.6				
75	03/02	2	1.25	1.6				
75	03/03	2	1.25	1.6				
75	03/04	2	1.25	1.6				
75	03/05	2	1.25	1.6				
75	03/06	2	1.25	1.6				
75	03/07	2	1.25	1.6				
75	03/08	2	1.25	1.6				
75	03/09	2	1.25	1.6				
75	03/10	2	1.25	1.6				
75	03/11	2	1.25	1.6				
75	03/12	2	1.25	1.6				
75	03/13	2	1.25	1.6				
75	03/14	2	1.25	1.6				
75	03/15	2	1.25	1.6				
75	03/16	2	1.25	1.6				
75	03/17	2	1.25	1.6				
75	03/18	2	1.25	1.6				
75	03/19	2	1.25	1.6				
75	03/20	2	1.25	1.6				
75	03/21	2	1.25	1.6				
75	03/22	2	1.25	1.6				
75	03/23	2	1.25	1.6				
75	03/24	2	1.25	1.6				
75	03/25	2	1.25	1.6				
75	03/26	2	1.25	1.6				
75	03/27	2	1.25	1.6				
75	03/28	2	1.25	1.6				
75	03/29	2	1.25	1.6				
75	03/30	2	1.25	1.6				
75	03/31	2	1.25	1.6				
75	04/01	2	1.25	1.6				
75	04/02	2	1.25	1.6				
75	04/03	2	1.25	1.6				
75	04/04	2	1.25	1.6				
75	04/05	2	1.25	1.6				
75	04/06	2	1.25	1.6				
75	04/07	2	1.25	1.6				
75	04/08	2	1.25	1.6				
75	04/09	2	1.25	1.6				
75	04/10	2	1.25	1.6				
75	04/11	2	1.25	1.6				
75	04/12	2	1.25	1.6				
75	04/13	2	1.25	1.6				
75	04/14	2	1.25	1.6				
75	04/15	2	1.25	1.6				
75	04/16	2	1.25	1.6				
75	04/17	2	1.25	1.6				
75	04/18	2	1.25	1.6				
75	04/19	2	1.25	1.6				
75	04/20	2	1.25	1.6				
75	04/21	2	1.25	1.6				
75	04/22	2	1.25	1.6				
75	04/23	2	1.25	1.6				
75	04/24	2	1.25	1.6				
75	04/25	2	1.25	1.6				
75	04/26	2	1.25	1.6				
75	04/27	2	1.25	1.6				
75	04/28	2	1.25	1.6				
75	04/29	2	1.25	1.6				
75	04/30	2	1.25	1.6				
75	05/01	2	1.25	1.6				
75	05/02	2	1.25	1.6				
75	05/03	2	1.25	1.6				
75	05/04	2	1.25	1.6				
75	05/05	2	1.25	1.6				
75	05/06	2	1.25	1.6				
75	05/07	2	1.25	1.6				
75	05/08	2	1.25	1.6				
75	05/09	2	1.25	1.6				
75	05/10	2	1.25	1.6				
75	05/11	2	1.25	1.6				
75	05/12	2	1.25	1.6				
75	05/13	2	1.25	1.6				
75	05/14	2	1.25	1.6				
75	05/15	2	1.25	1.6				
75	05/16	2	1.25	1.6				
75	05/17	2	1.25	1.6				
75	05/18	2	1.25	1.6				
75	05/19	2	1.25	1.6				
75	05/20	2	1.25	1.6				
75	05/21	2	1.25	1.6				
75	05/22	2	1.25	1.6				
75	05/23	2	1.25	1.6				
75	05/24	2	1.25	1.6				
75	05/25	2	1.25	1.6				
75	05/26	2	1.25	1.6				
75	05/27	2	1.25	1.6				
75	05/28	2	1.25	1.6				
75	05/29	2	1.25	1.6				
75	05/30	2	1.25	1.6				
75	05/31	2	1.25	1.6				
75	06/01	2	1.25	1.6				
75	06/02	2	1.25	1.6				
75	06/03	2	1.25	1.6				
75	06/04	2	1.25	1.6				
75	06/05	2	1.25	1.6				
75	06/06	2	1.25	1.6				
75	06/07	2	1.25	1.6				
75	06/08	2	1.25	1.6				
75	06/09	2	1.25	1.6				
75	06/10	2	1.25	1.6				
75	06/11	2	1.25	1.6				
75	06/12	2	1.25	1.6				
75	06/13	2	1.25	1.6				
75	06/14	2	1.25	1.6				
75	06/15	2	1.25	1.6				
75	06/16	2	1.25	1.6				
75	06/17	2	1.25	1.6				
75	06/18	2	1.25	1.6				
75	06/19	2	1.25	1.6				
75	06/20	2	1.25	1.6				
75	06/21	2	1.25	1.6				
75	06/22	2	1.25	1.6				
75	06/23	2	1.25	1.6				
75	06/24	2	1.25	1.6				
75	06/25	2	1.25	1.6				
75	06/26	2</						

MODE OF OPERATION									
YEAR	DATE	OPERATING MODE	FEED RATES	RETURN SLUDGE RATES	PH TEMP	SS	ALK	RAW SEWAGE	
	DAY	MON	A	B	A	B2		PH	TEMP
75	05	03	1	1.0	1.0	1.25		8.0	29
75	06	03	1	1.0	1.0	1.25		8.0	27
75	07	03	2	1.0	1.0	1.25			
75	07	03	1	1.0	1.0	1.25			
75	08	03	1	1.0	1.0	1.25			
75	08	03	2	1.0	1.0	1.25			
75	09	03	1	1.0	1.0	1.25			
75	09	03	2	1.0	1.0	1.25			
75	10	03	1	1.0	1.0	1.25			
75	11	03	2	1.0	1.0	1.25			
75	11	03	1	1.0	1.0	1.25			
75	12	03	1	1.0	1.0	1.25			
75	13	03	1	1.0	1.0	1.25			
75	14	03	1	1.0	1.0	1.25			
75	15	03	1	1.0	1.0	1.25			
75	15	03	2	1.0	1.0	1.25			
75	17	03	1	1.0	1.0	1.25			
75	18	03	1	1.0	1.0	1.25			
75	19	03	1	1.0	1.0	1.25			
75	20	03	1	1.0	1.0	1.25			
75	21	03	1	1.0	1.0	1.25			
75	22	03	1	1.0	1.0	1.25			
75	23	03	1	1.0	1.0	1.25			
75	24	03	1	1.0	1.0	1.25			
75	25	03	1	1.0	1.0	1.25			
75	26	03	1	1.0	1.0	1.25			
75	27	03	1	1.0	1.0	1.25			
75	28	03	1	1.0	1.0	1.25			
75	29	03	1	1.0	1.0	1.25			
75	30	03	1	1.0	1.0	1.25			
75	31	03	1	1.0	1.0	1.25			
75	01	04	1	1.0	1.0	1.25			
75	02	04	1	1.0	1.0	1.25			
75	03	04	1	1.0	1.0	1.25			
75	04	04	1	1.0	1.0	1.25			
75	05	04	1	1.0	1.0	1.25			
75	06	04	1	1.0	1.0	1.25			
75	07	04	1	1.0	1.0	1.25			
75	08	04	1	1.0	1.0	1.25			
75	09	04	1	1.0	1.0	1.25			
75	10	04	1	1.0	1.0	1.25			
75	11	04	1	1.0	1.0	1.25			
75	12	04	1	1.0	1.0	1.25			
75	13	04	1	1.0	1.0	1.25			
75	14	04	1	1.0	1.0	1.25			
75	15	04	1	1.0	1.0	1.25			
75	16	04	1	1.0	1.0	1.25			
75	17	04	1	1.0	1.0	1.25			
75	18	04	1	1.0	1.0	1.25			
75	19	04	1	1.0	1.0	1.25			
75	20	04	1	1.0	1.0	1.25			
75	21	04	1	1.0	1.0	1.25			
75	22	04	1	1.0	1.0	1.25			
75	23	04	1	1.0	1.0	1.25			
75	24	04	1	1.0	1.0	1.25			
75	25	04	1	1.0	1.0	1.25			
75	26	04	1	1.0	1.0	1.25			
75	27	04	1	1.0	1.0	1.25			
75	28	04	1	1.0	1.0	1.25			
75	29	04	1	1.0	1.0	1.25			
75	30	04	1	1.0	1.0	1.25			
75	31	04	1	1.0	1.0	1.25			
75	01	05	1	1.0	1.0	1.25			
75	02	05	1	1.0	1.0	1.25			
75	03	05	1	1.0	1.0	1.25			
75	04	05	1	1.0	1.0	1.25			
75	05	05	1	1.0	1.0	1.25			
75	06	05	1	1.0	1.0	1.25			
75	07	05	1	1.0	1.0	1.25			
75	08	05	1	1.0	1.0	1.25			
75	09	05	1	1.0	1.0	1.25			
75	10	05	1	1.0	1.0	1.25			
75	11	05	1	1.0	1.0	1.25			
75	12	05	1	1.0	1.0	1.25			
75	13	05	1	1.0	1.0	1.25			
75	14	05	1	1.0	1.0	1.25			
75	15	05	1	1.0	1.0	1.25			
75	16	05	1	1.0	1.0	1.25			
75	17	05	1	1.0	1.0	1.25			
75	18	05	1	1.0	1.0	1.25			
75	19	05	1	1.0	1.0	1.25			
75	20	05	1	1.0	1.0	1.25			
75	21	05	1	1.0	1.0	1.25			
75	22	05	1	1.0	1.0	1.25			
75	23	05	1	1.0	1.0	1.25			
75	24	05	1	1.0	1.0	1.25			
75	25	05	1	1.0	1.0	1.25			
75	26	05	1	1.0	1.0	1.25			
75	27	05	1	1.0	1.0	1.25			
75	28	05	1	1.0	1.0	1.25			
75	29	05	1	1.0	1.0	1.25			
75	30	05	1	1.0	1.0	1.25			
75	31	05	1	1.0	1.0	1.25			

15.0
15.0

MODE OF OPERATION										---RAW SEWAGE---		
YEAR	DATE	OPERATING MODE	FEED RATES	RETURN SLUDGE RATES	PH	TEMP	SS	HACH NH3N	ALK			
75	04/05	1	2.0	2.5	7.4	23.0	350					
75	05/05	2	2.0	2.5	7.4	23.0	350					
75	05/05	1	2.0	2.5	7.4	23.0	350					
75	06/05	2	2.0	2.5	7.4	23.0	350					
75	06/05	3	2.0	2.5	7.4	23.0	350					
75	07/05	3	2.0	2.5	7.4	23.0	350					
75	08/05	3	2.0	2.5	7.4	23.0	350					
75	09/05	1	2.0	2.5	7.4	23.0	350					
75	10/05	1	2.0	2.5	7.4	23.0	350					
75	11/05	1	2.0	2.5	7.4	23.0	350					
75	12/05	1	2.0	2.5	7.4	23.0	350					
75	01/06	1	2.0	2.5	7.4	23.0	350					
75	02/06	1	2.0	2.5	7.4	23.0	350					
75	03/06	1	2.0	2.5	7.4	23.0	350					
75	04/06	1	2.0	2.5	7.4	23.0	350					
75	05/06	1	2.0	2.5	7.4	23.0	350					
75	06/06	1	2.0	2.5	7.4	23.0	350					
75	07/06	1	2.0	2.5	7.4	23.0	350					
75	08/06	1	2.0	2.5	7.4	23.0	350					
75	09/06	1	2.0	2.5	7.4	23.0	350					
75	10/06	1	2.0	2.5	7.4	23.0	350					
75	11/06	1	2.0	2.5	7.4	23.0	350					
75	12/06	1	2.0	2.5	7.4	23.0	350					

MODE OF OPERATION									
DATE	OPERATING	FEEED	RATES	RETURN	SLUDGE	RATES	---RAW SEWAGE---		
YEAR	DAY	MON	TIME	A	B	A	B1	B2	HACH
75									NH3N
									PH
									TEMP
									SS
									ALK

STOP

0.

REACTOR OPERATING RESULTS

YEAR	DATE	TIME	REACTOR MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	NH3N	NO3N	PH	TEMP	SIT	DO	OUR
73	09	11	A	4300	11850	58	262	7.4	5.5	325	11.3			
73	10	11	A	5260	3400									
73	11	11	A	4160	3130									
73	11	11	A	5290	3520	10960	58	81						
73	14	11	A	5210	3810									
73	15	11	EA	5440	SOLIDS = 11720	52		98	10	7.3	12.0	390	5.8	
73	15	11	EA	5730	3790	9770	58	50	199	7.3	5.5	345	8.3	
73	17	11	A	5480	11470	58		85	17	7.4	6.0	290	6.5	
73	17	11	A	4390				43	8	7.2	5.5	235	8.1	
73	18	11	A	5470				43						
73	19	11	EA	5610	SOLIDS = 9830	32		50	209	7.2	5.0	540	5.4	
73	19	11	A	4800	3750									
73	20	11	EA	5680	SOLIDS = 50	50								
73	21	11	A	5670	9280	72		50		7.4	5.0	320	7.4	
74	01	11	A	5960	10600	58		93		7.4	5.0	320	8.3	
74	01	11	A	4410	9170	33		34		7.4	4.5		4.3	
74	01	11	A	4320	7760	160		25	6	7.3	4.5		2.3	
74	01	11	A	4330	8070	50		27	6	7.2	4.8		3.7	
74	01	11	A	5550	10480	20		40	7	7.1	4.8		3.1	
74	01	11	A	5400	7610	20		38		7.4	5.3	350	2.7	
74	01	11	A	5570										
74	01	11	A	5290	3460	20								
74	01	11	A	6000	3320	20								
74	01	11	A	5040	9650	20								
74	01	11	A	5330	9630	20								
74	01	11	A	5330	9630	20								
74	01	11	EA	5310	SUSPENDED SOLIDS = 9650	20		191	156	7.4	4.8	380	5.2	
74	01	11	A	5300	9630	20								
74	01	11	A	5300	10200	20		103		7.3	4.8		4.3	
74	01	11	A	4870	10200	20								
74	02	00	A	4700	13940	40		30		7.7	4.5		6.7	
74	04	00	A	5480	13140	30								
74	04	00	A	4850	3610	20								
74	04	00	A	4730	10360	20								
74	04	00	A	4950	9830	20								

ALL OXYGEN UP-TAKE RATES WERE CARRIED OUT IN PH OF EACH DAY. THE AVERAGE OF AN AM AND PM SAMPLE. THE OXYGEN UP-TAKE RATE (4% OXYGEN PER MG MLSS PER HOUR) IS RECORDED ON THE AM CARD EACH DAY.

WASTE WERE CARRIED OUT IN PH OF EACH DAY. THE AVERAGE OF AN AM AND PM SAMPLE. THE OXYGEN UP-TAKE RATE (4% OXYGEN PER MG MLSS PER HOUR) IS RECORDED ON THE AM CARD EACH DAY.

SUSPENDED SOLIDS =

SOLIDS =

APPEAR HIGH, THIS IS DUE TO SLUDGE BLANKET

REACTOR OPERATING RESULTS

YEAR	DATE	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	NH3N HACH	PH	TEMP	MIN SET	DO	OUR
74	04	02	2130	A	4910		3550	20	43	125	7.4	5.0	340	5.9	3.03
74	05	02	2900	A	5045		8500								
74	05/02/74			OPERATOR A VSS WAS TAKEN, THEREFORE THE VSS VALUE SHOWN WAS BASED ON A VSS OF 67 PER CENT											
74	05	02	2900	A	5320	3565	9710	31	44		7.2	4.8		4.6	
74	05	04	2130	A	5730		9700	20	6						
74	05	04	2130	A	5870		12150	21	14		7.3	11.0		1.8	
74	05	06	2130	A	6250	4450	10150	21	7	89	7.3	11.0	865	1.9	5.07
74	05	07	2130	A	6070		8650	27	21		7.2	10.0		4.5	
74	05	07	2130	A	6260		9080	35	13	103	7.3	10.3	595	5.2	4.63
74	05	07	2130	A	5780	3940	9870	30	14		7.2	20.3		5.6	
74	05	07	2130	A	5990		9400	28	73						
74	05	07	2130	A	5750		9150	20							
74	05	07	2130	A	5130		12370								
74	05	07	2130	A	6090	3960	12380								
74	05	07	2130	A	5840		12300								
74	05	07	2130	A	5480	3610	10250	20							
74	05	07	2130	A	5000		12100								
74	05	07	2130	A	5060		12170								
74	05	07	2130	A	8670		8670	47	25	40	7.1	20.5	585	3.1	6.55
74	05	07	2130	A	5410	3740	12380								
74	05	07	2130	A	5900		12380								
74	05	07	2130	A	5230	3530	10550	15							
74	05	07	2130	A	5000		11570								
74	05	07	2130	A	4950		12510								
74	05	07	2130	A	6770	4520	10620								
74	05	07	2130	A	5740		10210	14	33	17	5.3	20.0	520	3.5	3.22
74	05	07	2130	A	6860		11540	20	63			14.8		6.5	
74	05	07	2130	A	7430		9960	20	22		7.3	14.5		4.6	
74	05	07	2130	A	4440		8040	15	23		7.3	14.8		5.1	
74	05	07	2130	A	8440		7910	23	702		7.1	15.0		4.5	
74	05	07	2130	A	4440		8440	23							

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N NO3N HACH	PH	TEMP	30 MIN SET	DO	OUR
74	13	06	13 06	PM	A	5900	4330	5850	11		5.8	7.8	10.5		2.8	
74	14	06	14 06	AM	A	5800		8570	30		7.8	7.8	10.5		4.7	
74	15	06	15 06	AM	A				30							
74	16	06	16 06	AM	A				40							
74	17	06	17 06	PM	A				20							
74	18	06	18 06	AM	A				40							
74	19	06	19 06	AM	A				30							
74	20	07	20 07	AM	A	5800			30	15						
74	21	07	21 07	AM	A											
74	22	07	22 07	AM	A	6190	4620	5970	60	16	22	6.5	15.0	650	4.7	5.82
74	23	07	23 07	AM	A	5900		7130	60	20		5.7	15.0		6.6	
74	24	07	24 07	AM	A	6090		6020	71	14		6.0	14.0		5.8	
74	25	07	25 07	AM	A	7100		6250	60	17	16	5.5	14.0	670	5.7	4.52
74	26	07	26 07	AM	A	6180		4460	20							
74	27	07	27 07	AM	A	6410		9650	40							
74	28	07	28 07	AM	A	5030		7520	40							
74	29	07	29 07	AM	A	5270			67	14		7.0	14.5		3.0	
74	30	07	30 07	AM	A											
74	31	07	31 07	PM	A	5320	3720	5500	75	15	59	7.1	14.0	235	3.3	2.46
74	1	07	1 07	AM	A	5170		8530	35							
74	2	07	2 07	AM	A	5270		7330	45	14		6.9	14.5		3.2	
74	3	07	3 07	AM	A			8740	30							
74	4	07	4 07	AM	A	6230	4510	8800	35	21	43	6.8	14.0	300	3.4	6.10
74	5	07	5 07	AM	A	5080		10730	35							
74	6	07	6 07	AM	A	7200		12240	30	56		5.8	14.5		3.5	
74	7	07	7 07	AM	A			11370	30							
74	8	07	8 07	AM	A			10880	40							
74	9	07	9 07	AM	A				40							
74	10	07	10 07	AM	A				35							
74	11	07	11 07	AM	A				30							
74	12	07	12 07	AM	A	8010		11050	70	7		7.1	20.5		5.4	
74	13	07	13 07	AM	A	7210		13470	50	8						
74	14	07	14 07	AM	A			11780	30							
74	15	07	15 07	AM	A	7710	4550	11590	45	28	6	6.3	21.0	700	5.5	5.07
74	16	07	16 07	AM	A	7390		9060	35							
74	17	07	17 07	AM	A	5210	3470		35	15	5	5.8	21.0	330	5.2	5.31
74	18	07	18 07	AM	A	5700			35	23		5.3	19.5		6.5	5.31
74	19	07	19 07	AM	A	5930		9220	35	23		5.8	17.0		6.2	6.3
74	20	07	20 07	AM	A	5910			35							
74	21	07	21 07	AM	A	6700			35	26						
74	22	07	22 07	AM	A	6240		10320	35	12		5.9	10.0		6.1	
74	23	07	23 07	AM	A			10660	35							

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	HACH	NO3N	PH	TEMP	SET	MIN	DO	JUR
74	16	09	1600	A	7270	4070	11350	40	32	61	6.7	24.5	720	1.1	11.63		
74	17	10	AM	A	6180		13970	80	29		6.8	24.5		0.1			
74	28	10	PM	A	6450		12260	40				25.0		3.4			
74	28	10	AM	A	5830			50									
74	29	10	PM	A				50									
74	30	10	PM	A	6790		11540	35	30		6.8	25.0		3.1			
74	31	11	AM	A	6770			35	21		6.6	24.5		4.5			
74	01	11	AM	A	7140		11990	35	8								
74	02	11	AM	A	7390		20720	40	14								
74	03	11	AM	A			12850	40	14								
74	04	11	AM	A				40	30	42	7.0	24.0	900	2.4	24.95		
74	04	11	AM	A	8160	5794	13930	40	26	3	6.1	24.0	925	5.4			3.95
74	04	11	AM	A	7390		10520	20	44		6.2	23.5		6.6			
74	14	11	AM	A	6090	3960		20			6.2	24.0		4.7			
74	14	11	AM	A	6480		12180	20									
74	15	11	AM	A	7320			35									
74	16	11	AM	A				30	12		7.3	13.0		7.1			
74	17	11	AM	A	6130			30									
74	18	11	AM	A	5680		11620	30	5		7.3	11.0		4.0			
74	19	11	AM	A	5900		9990	30	4		7.6	11.0		4.2			
74	20	11	AM	A			10160	20									
74	20	11	AM	A	5880		10950	30	13		7.4	10.5		5.7			
74	21	11	AM	A			4600	10									
74	22	11	AM	A	5560	3730	9990	20	17	42	7.0	11.0	946	2.9	5.11		
74	22	11	AM	A	5470		9220	20									
74	23	11	AM	A	5760			20	26								
74	23	11	AM	A	5230		9420	20	6		7.0	11.0		4.9			
74	26	11	AM	A	5310	3680	9980	15	15	19	7.0	11.0	950	3.0	4.99		
74	27	11	AM	A	5160		9550	20									
74	27	11	AM	A			9010	20									
74	28	11	AM	A			9170	25									
74	28	11	AM	A				30									
74	29	11	AM	A				45									
74	30	11	AM	A	4800		8270	30	3		7.3						
74	30	11	AM	A	5030			45	9								
74	01	12	AM	A	4530		7060	50	19								
74	02	12	AM	A			7490	30									
74	03	12	AM	A			7490	30									
74	03	12	AM	A			8380	35	18								
74	04	12	AM	A	4940			35									

ERROR NO VSS WAS TAKEN, THEREFORE THE VSS VALUE

ERROR OF 71 PER CENT

DUPLICATE

04/11

SHOWN

BASED

ON A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

OPERATED

ON

11/74

DUPLICATE

BASED

ON

A

REACTOR

OPERATOR

WAS

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	HACH	NH3N	NO3N	PH	TEMP	SET	DO	OUR
75	23	01	01	0300	A	3920													
75	29	01	01	0500	A	3670													
75	29	01	01	0915	A	3580													
75	29	01	01	1100	A	3620	2710	3620	25	20									
75	29	01	01	1300	A	3500													
75	29	01	01	1500	A	3590													
75	29	01	01	1700	A	3750													
75	29	01	01	1900	A	3600													
75	29	01	01	2100	A	3780													
75	30	01	01	0300	A	3810													
75	30	01	01	0500	A	3800													
75	30	01	01	0700	A	3840													
75	30	01	01	0900	A	3810													
75	30	01	01	1100	A	3570													
75	30	01	01	1300	A	3660	2630	3660	60	18									
75	30	01	01	1500	A	4000													
75	30	01	01	1700	A	3900													
75	30	01	01	1900	A	4270		4270	1160	5					7.0	15.5		3.9	
75	30	01	01	2100	A	4310		4310	1160	8					7.0	15.5		4.7	
75	31	01	02	0300	A	4290		4290	500	2					7.2	10.0			
75	31	01	02	0500	A	4230		4230	750	16					7.3	9.5			
75	31	01	02	0700	A	4370		4370	500	11					7.2	10.0			
75	31	01	02	0900	A	4100		4100	500	5					7.3	9.5			
75	31	01	02	1100	A	4100		4100	500	12					7.3	9.5			
75	31	01	02	1300	A	4340		4340	1000	15	80				7.3	9.5		5.0	5.01
75	31	01	02	1500	A	4280	3050	4280	1200	15					7.3	9.5		5.0	5.01
75	31	01	02	1700	A	3770		3770	500	3					7.3	9.5		4.6	
75	31	01	02	1900	A	5660		5660	250	43					7.4	15.0		4.6	
75	31	01	02	2100	A	5300		5300	250	46					6.8	15.0		4.7	
75	31	01	02	0300	A	5730		5730	250	41					6.8	15.0		4.7	
75	31	01	02	0500	A	6340		6340	250	54					6.8	15.0		4.7	
75	31	01	02	0700	A	5710		5710	250	46					6.8	15.0		4.7	
75	31	01	02	0900	A	5400	3510	5400	20	24	16				6.8	15.0		4.7	
75	31	01	02	1100	A	5590		5590	25	28					7.0	15.0		4.7	
75	31	01	02	1300	A	5580		5580	140	31					7.0	15.0		4.7	
75	31	01	02	1500	A	4440		4440	100	24					7.0	15.0		4.7	
75	31	01	02	1700	A	4370		4370	150	24					7.0	15.0		4.7	

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	EFFLUENT NH3N HACH	PH	TEMP	30 MIN SET	DC	OUR
75	03	02	AM	A	2300	1680	2300	210	32	82		7.4	14.9		6.5	
75	03	03	AM	A	2340	1490	2360	175	25			7.2	14.5		6.4	
75	04	05	AM	A	2220	1350	2190	170	27	70	4.0	7.4	13.6		6.7	
75	05	05	AM	A	2060	1400	2020	130	33	84		7.4	13.0		6.7	
75	06	05	AM	A	1980	1500	2080	130	54	97		7.4	9.0		7.0	
75	07	05	AM	A	2110	1500	2100	115	50	102		7.4	9.0		7.2	
75	07	05	AM	A	2050	1360	1950	148	36							
75	08	05	AM	A	1960	1610	1940	148	78	52	2.5	7.3	14.0		5.7	
75	09	05	AM	A	1940	1750	2080	140	42	11	8.0	7.1	15.0		5.7	
75	11	05	AM	A	2160	1750	2210	140	33						5.7	
75	11	05	AM	A	2130	1520	2070	105	34	58					5.7	
75	12	05	AM	A	2140	1520	2070	105	50	113	20.0	7.9	14.5		5.7	
75	13	05	AM	A	2020	1750	2320	105	170			7.9	14.5		5.7	
75	14	05	AM	A	2100	1880	2360	105	52	115		7.8	14.5		5.7	
75	15	05	AM	A	2220	1900	2030	105	60	104		7.7	14.5		5.7	
75	16	05	AM	A	2630	2140	3000	131	229	91	13.5	7.6	15.0		5.7	
75	17	05	AM	A	2870	2140	2840	140	265	74	6.5	7.4	15.0		4.7	
75	18	05	AM	A	3000	1895	2840	135	255			7.5	14.5		6.1	
75	18	05	PM	A	2840	1370	2900	135	28			7.4	14.5		6.0	
75	19	05	PM	A	1370	1530	1370	112								
75	20	05	AM	A	2600	1310	1895	99	28			7.6	14.5		7.2	
75	21	05	AM	A	1870	1160	2335	132	23	86	0.5	7.6	14.5		7.2	
75	22	05	AM	A	1920	1260	1800	75	24	91	7.3	7.7	14.5		6.2	
75	23	05	AM	A	1890	1110	1455	105	43	94	1.1	7.7	14.5		6.2	
75	24	05	AM	A	2780	1180	1780	105	23	83		7.7	14.5		6.2	
75	25	05	AM	A	1900	1780	1780	105	43						6.2	
75	26	05	AM	A	1700	1780	1780	105	22						6.2	
75	27	05	AM	A	1660	1780	1780	105	13						6.2	
75	28	05	AM	A	2050	1780	1780	105	26						6.2	
75	28	05	AM	A	1780	1780	1780	105	26						6.2	
75	29	05	AM	A	1780	1780	1780	105	26						6.2	
75	29	05	AM	A	1780	1780	1780	105	26						6.2	

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N HACH	PH	TEMP	MIN SET	DO	OJR
75	04	05	AM	A	3090	2160	3090	128	28				30		
75	05	05	AM	A	3070	2160	3425	128	34	56	7.1	23.5	320	4.3	11.93
75	09	05	AM	A	3780				32			25.5			
75	09	05	PM	A	2380		2380	160	16		7.3	13.5			
75	10	05	AM	A				20							
75	11	05	AM	A	2020		2020	160	12						
75	11	05	PM	A			2520	200							
75	12	05	PM	A											

NO VSS WAS TAKEN, THEREFORE THE VSS VALUE SHOWN, IS BASED ON 13/05/75 VSS (81 PER CENT)

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC.	IGAL WASTE	SS ALK	EFFLUENT	RETURN SLUDGE	PH	TEMP	30 MIN SET	DC	OJR
75	12	05	12/05	AM	A	1970	1590	1900	150	14	179	3820	7.2	12.5		3.7	
75	13	05	12/05	PM	A	1830				1				13.0		3.4	
75	13	05	12/05	AM	A	1700	1330	1750	128	14	204		7.1	12.2		4.4	
75	13	05	12/05	PM	A	1800				32		4130				4.6	
75	14	05	12/05	AM	A	2240	1780			41	190	3290	7.2	12.4		4.2	
75	14	05	12/05	PM	A	2350		2300	146	39		4500		12.5		5.2	
75	15	05	12/05	AM	A	3030	2220	3010	160	33	180	4350	7.2	12.6		5.6	
75	15	05	12/05	PM	A	2990				32		5500				5.6	
75	16	05	12/05	AM	A	3210	2360	3210	129	30		5600		12.5		3.1	
75	16	05	12/05	PM	A												
75	17	05	12/05	AM	A												
75	17	05	12/05	PM	A												
75	18	05	12/05	AM	A												
75	18	05	12/05	PM	A												
75	19	05	12/05	AM	A												
75	19	05	12/05	PM	A												
75	20	05	12/05	AM	A												
75	20	05	12/05	PM	A												
75	21	05	12/05	AM	A												
75	21	05	12/05	PM	A												
75	22	05	12/05	AM	A												
75	22	05	12/05	PM	A												
75	23	05	12/05	AM	A												
75	23	05	12/05	PM	A												
75	24	05	12/05	AM	A												
75	24	05	12/05	PM	A												
75	25	05	12/05	AM	A												
75	25	05	12/05	PM	A												
75	26	05	12/05	AM	A												
75	26	05	12/05	PM	A												
75	27	05	12/05	AM	A												
75	27	05	12/05	PM	A												
75	28	05	12/05	AM	A												
75	28	05	12/05	PM	A												
75	29	05	12/05	AM	A												
75	29	05	12/05	PM	A												
75	30	05	12/05	AM	A												
75	30	05	12/05	PM	A												
75	31	05	12/05	AM	A												
75	31	05	12/05	PM	A												
75	01	06	01/06	AM	A												
75	01	06	01/06	PM	A												
75	02	06	01/06	AM	A												
75	02	06	01/06	PM	A												
75	03	06	01/06	AM	A												
75	03	06	01/06	PM	A												
75	04	06	01/06	AM	A												
75	04	06	01/06	PM	A												
75	05	06	01/06	AM	A												
75	05	06	01/06	PM	A												

THEREFORE THE VSS VALUE

3070 7.3 12.0 7.9

2680 12.5 6.5

3200 12.5 4.9

2840 11.7 3.3

3330 12.7 5.4

3370 12.7 3.1

3090 12.0 5.1

4070

1890 7.4 12.7 4.9

2670 12.5 3.1

2560 7.4 13.5 2.9

2430 12.5 2.9

2590 7.6 12.5 2.9

WAS TAKEN, (PER CENT)

16 24

25 80

28 168

41 169

50

28

31 135

31 243

43 197

1800 ERROR NO VSS WAS TAKEN, (PER CENT)

1800 138

1680 1361

1690 1360

1670 1360

1820 1450

1850 1620

2030 160

1990

2130 1610

1540 1200

1360

1450 1170

1430 1270

1560 129

OPERATOR DUE TO OPERATOR IS BASED ON 27/05/75

1680 1361

1690 1360

1670 1360

1820 1450

1850 1620

2030 160

1990

2130 1610

1540 1200

1360

1450 1170

1430 1270

1560 129

REACTOR OPERATING RESULTS

YEAR	DATE	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	EFFLUENT	RETURN SLUDGE	PH	TEMP	MIN SET	DC	OUR
75	04	06	PM	A	1560				25			2060	7.4	12.7	30	7.8	
75	05	06	AM	A	1720	1250	1615	128	45	156				12.5		8.0	
75	05	06	AM	A	1510				74			2220		12.9		7.8	
75	06	06	AM	A	1500	1190	1500	64	38			2160	7.3	12.8		7.9	
75	07	06	AM	A	4060				37			2570	7.3	18.0		6.2	
75	13	06	AM	A	4330		8820	33	17			6960	7.2	17.6		6.2	
75	14	06	AM	A				29									
75	15	06	AM	A	4670		6910	26	29				7.2	17.0		6.9	
75	16	06	AM	A			6910	16									
75	16	06	AM	A	4950		6480	26	20				7.4	18.3		6.6	
75	17	06	AM	A	5050		7600	24	29				7.2	18.5		5.3	
75	18	06	AM	A	1710		2020	99	18				7.6	12.2		7.8	
75	22	06	AM	A	1950		2550	104	22				7.2	14.2		6.7	
75	28	06	AM	A				108									
75	29	06	AM	A				123									
75	30	06	AM	A	1300		1720	123	22				7.3	21.0		6.6	
75	30	06	AM	A	1160		1120	128	42	141							
75	01	07	AM	A	1260	928	1120	128	28	164		2740	7.3	21.0		6.1	
75	01	07	AM	A	1320	1050	1820	68	41	149		2140		21.0		5.3	
75	02	07	AM	A	2250	1050	3520	54	34	149		2220	7.3	21.0		5.3	
75	03	07	AM	A	1650	1340	1900	128	14			3080		20.8		4.0	
75	03	07	AM	A	1480							2770	7.5	21.0		5.0	
75	03	07	PM	A			2250	6				3270		21.0		5.3	
75	04	07	AM	A	1020												

OPERATOR ERROR
 DUE TO OPERATOR ON 02/07/75
 SHOWN, IS BASED ON 02/07/75
 THEREFORE THE VSS VALUE

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	HACH	NH3N	NO3N	PH	TEMP	MIN SET	OUR
73	22	11	AM	A1	5390								7.3	8.5		3.2
73	23	11	AM	A1	5550								7.3	8.5		3.2
73	24	11	AM	A1	4600											
73	25	11	AM	A1	5580											
73	26	11	AM	A1	5380	3900							7.2	5.5	410	5.8
73	27	11	AM	A1	5150	3690							7.4	5.5		6.6
73	28	11	PM	A1	5400								7.4	6.0		5.6
73	29	11	PM	A1	5020	3920							7.3	5.5	315	7.3
73	30	11	AM	A1	5215	3785							7.4	5.5	315	1.68
74	01	12	AM	A1	5540								7.4	5.5		7.3
74	02	12	AM	A1	7610								7.4	5.5		7.4
74	03	12	AM	A1	5320								7.5	9.3		1.6
74	04	12	PM	A1	4270								7.5	9.3		4.6
74	05	12	PM	A1	6910								7.4	10.5		6.1
74	06	12	PM	A1	4820								7.4	10.5		3.5
74	07	12	PM	A1	5890	3400							7.4	10.0	595	5.10
74	08	12	PM	A1	3370	4130							7.4	9.8		3.6
74	09	12	PM	A1	5760	4020							7.4	9.8	380	4.77
74	10	12	PM	A1	4310								7.1	10.0		2.7
74	11	12	PM	A1	4360								7.1	10.0		4.9
74	12	12	PM	A1	3960								7.1	10.0		4.9
74	13	01	AM	A1	3500	2570							7.2	10.0		7.3
74	14	01	AM	A1	3720	3070							7.2	10.0	350	4.3
74	15	01	AM	A1	4300								7.4	10.0		4.3
74	16	01	AM	A1	7410								7.2	10.0		4.6
74	17	01	AM	A1	5850								7.4	10.0		4.6
74	18	01	AM	A1	5160								7.4	10.0		4.6
74	19	01	AM	A1	5450								7.4	10.0		4.6
74	20	01	AM	A1	5660								7.2	10.0		4.6
74	21	01	AM	A1	4660								7.2	10.0	350	3.36
74	22	01	AM	A1	5790								7.4	10.0		4.6
74	23	01	AM	A1	4110								7.4	10.0		4.6
74	24	01	AM	A1	4840								7.4	10.0		4.6
74	25	01	AM	A1	4830								7.4	10.0		4.6
74	26	01	AM	A1	4510								7.4	10.0		4.6
74	27	01	AM	A1	4090								7.4	10.0		4.6
74	28	01	AM	A1	4660								7.3	10.0	340	5.72
74	29	01	AM	A1	5790								7.3	10.0		5.6
74	30	01	AM	A1	4110								7.4	10.0		5.6
74	31	01	AM	A1	4840								7.4	10.0		5.6
74	01	02	AM	A1	4830	1518							7.5	10.0		9.7
74	02	02	AM	A1	4510								7.5	10.0		7.1
74	03	02	AM	A1	4090	3080							7.5	10.0		8.1

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	-----EFFLUENT----- NH3N NO3N HACH	PH	TEMP	30 MIN SET	DO	OUR
74	09	03	AM	A1	3650					7.5	7.5	5.0		7.6	3.6
74	10	03	AM	A1	4490					7.4	7.4	5.0		7.6	3.5
74	11	03	AM	A1	3880					7.6	7.6	5.0		7.7	3.5
74	12	03	AM	A1	4630					7.6	7.6	10.3		7.7	3.6
74	13	03	AM	A1	4240					7.4	7.4	9.8		7.7	3.6
74	14	03	AM	A1	5530	4270				7.7	7.7	9.3		7.7	3.12
74	15	03	PM	A1	6220					7.6	7.6	9.5		7.6	3.4
74	16	03	AM	A1	4470					7.7	7.7	9.5		7.6	3.4
74	17	03	AM	A1	3190					7.7	7.7	10.0		7.6	3.4
74	18	03	AM	A1	3550					7.5	7.5	10.0		7.6	3.4
74	19	03	AM	A1	4940					7.8	7.8	10.0		7.6	3.4
74	20	03	AM	A1	4820					7.2	7.2	10.0		7.6	3.4
74	21	03	AM	A1	5520					7.9	7.9	11.5		7.6	3.4
74	22	03	AM	A1	7090	4910				7.9	7.9	11.5		7.6	3.35
74	23	03	AM	A1	5550					7.6	7.6	11.8		7.6	3.4
74	24	03	AM	A1	6340					7.5	7.5	10.8		7.6	3.4
74	25	03	AM	A1	6410					7.6	7.6	10.8		7.6	3.4
74	26	03	AM	A1	6210					7.6	7.6	15.0		7.6	3.4
74	27	03	AM	A1	6460					7.5	7.5	5.0		7.6	3.4
74	28	03	AM	A1	4290					7.3	7.3	11.0		7.6	3.4
74	29	03	AM	A1	5160					7.4	7.4	9.8		7.6	3.4
74	30	03	AM	A1	5510	3960				7.4	7.4	9.8		7.6	4.16
74	31	03	AM	A1	6790					7.4	7.4	9.8		7.6	3.20
74	01	04	AM	A1	6570	4480				7.4	7.4	9.5		7.6	3.20
74	02	04	AM	A1	7500					7.4	7.4	9.5		7.6	3.20
74	03	04	AM	A1	5280					7.3	7.3	13.5		7.6	3.20
74	04	04	AM	A1	5730	4990				7.3	7.3	14.5		7.6	3.20
74	05	04	AM	A1	7300					7.5	7.5	14.5		7.6	3.20
74	06	04	AM	A1	5730	3750				7.5	7.5	14.5		7.6	3.20
74	07	04	AM	A1	5690					7.5	7.5	14.5		7.6	3.20
74	08	04	AM	A1	5770					7.5	7.5	14.5		7.6	3.20
74	09	04	AM	A1	4530					7.5	7.5	14.5		7.6	3.20
74	10	04	AM	A1	5050	3410				7.5	7.5	14.5		7.6	3.20
74	11	04	AM	A1	6070					7.5	7.5	14.5		7.6	3.20
74	12	04	AM	A1	5420	3720				7.5	7.5	14.5		7.6	3.20
74	13	04	AM	A1	5230					7.5	7.5	14.5		7.6	3.20
74	14	04	AM	A1	4550					7.5	7.5	14.5		7.6	3.20
74	15	04	AM	A1	6670					7.2	7.2	14.8		7.6	3.20
74	16	04	AM	A1	4510					7.2	7.2	14.8		7.6	3.20

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	-----EFFLUENT----- NH3N NO3N HACH	PH	TEMP	MIN	30	DO	OUR
74	13	04	AM	A1	6040											
74	14	04	AM	A1	5440											
74	15	04	AM	A1	5300	4300					7.2	5.0			2.7	3.25
74	16	04	PM	A1	6100											
74	17	04	AM	A1	6040	4870					7.3	5.0			3.2	2.22
74	18	04	PM	A1	7010											
74	19	05	AM	A1	6040											
74	20	05	AM	A1	5000	2790					7.3	5.0	370		5.2	1.32
74	21	05	PM	A1	4520											
74	22	05	AM	A1	4730	3330					7.3	5.3	325		4.2	2.24
74	23	05	PM	A1	4390											
74	24	06	AM	A1	5460						7.4	6.0			4.6	
74	25	06	PM	A1	6470											
74	17	06	AM	A1	6120	4400					6.8	9.5	750		2.5	1.33
74	18	06	PM	A1	5910											
74	19	06	AM	A1	6120	4290					7.1	10.0	880		3.5	3.74
74	20	06	PM	A1	5920											
74	21	06	AM	A1	5870											
74	22	06	PM	A1	7430						6.8	11.0			2.1	
74	23	06	AM	A1	8060											
74	24	06	PM	A1	7730						6.9	16.0			4.8	
74	25	06	AM	A1	6400	4450					7.0	17.0	950		3.7	2.56
74	26	06	PM	A1	6470											
74	27	06	AM	A1	6720	4690					6.6	16.0	895		4.6	6.02
74	28	06	PM	A1	6640											
74	29	06	AM	A1	6970						7.1	15.0			2.1	
74	30	06	PM	A1	5910											
74	01	07	AM	A1	5770											
74	02	07	PM	A1	5060	3940					6.0					
74	03	07	AM	A1	5490											
74	04	07	PM	A1	5640						7.1	6.0			4.6	3.13
74	05	07	AM	A1	5870											
74	06	07	PM	A1	5670	4440					7.3	6.0			1.8	
74	07	07	AM	A1	6260											
74	08	07	PM	A1	6230						7.2	6.0	830		1.4	2.27
74	09	07	AM	A1	6000											
74	10	07	PM	A1	6570	3770					6.9	13.0	350			6.03
74	11	07	AM	A1	5290											
74	12	07	PM	A1	5790											
74	13	07	AM	A1	6720											
74	14	07	PM	A1	6090											
74	15	07	AM	A1	6280											
74	16	07	PM	A1	6400											
74	17	07	AM	A1	6090											
74	18	07	PM	A1	6090											
74	19	07	AM	A1	6090											
74	20	07	PM	A1	6090											
74	21	07	AM	A1	6090											
74	22	07	PM	A1	6090											
74	23	07	AM	A1	6090											
74	24	07	PM	A1	6090											
74	25	07	AM	A1	6090											
74	26	07	PM	A1	6090											
74	27	07	AM	A1	6090											
74	28	07	PM	A1	6090											
74	29	07	AM	A1	6090											
74	30	07	PM	A1	6090											

REACTOR OPERATING RESULTS

YEAR	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N HACH	PH	TEMP	MIN SET	DO	OUR
74	27	07	A1	6260										
74	28	07	A1	5389										
74	29	07	A1	5850	4160					7.1	20.0	850	1.9	4.06
74	30	07	A1	6040						6.7	21.0		3.2	
74	31	08	A1	91720						6.5	20.0			
74	01	08	A1	7730						7.2	20.5		4.2	
74	02	08	A1	6800										
74	03	08	A1	7150										
74	04	08	A1	7890	4720					6.7	20.0	920	3.1	4.24
74	05	08	A1	6890										
74	06	08	A1	6920	4450					6.6	20.5	925	3.2	9.97
74	07	08	A1	6850						6.9	21.0		4.0	
74	08	08	A1	7370										
74	08	08	A1	7680	4440					6.9	20.5	700	1.8	8.32
74	09	08	A1	7040										
74	17	09	A1	5640						6.5	20.0		3.2	
74	18	09	A1	5660										
74	18	09	A1	6030	4040					6.5	20.0	760	1.8	3.65
74	19	09	A1	6100										
74	20	09	A1	5910						6.5	22.5		3.2	
74	22	09	A1	7110										
74	22	09	A1	7580										
74	22	09	A1	5150	3980					6.6	20.0	700	5.5	3.67
74	22	09	A1	5940						6.6	21.0		4.0	
74	22	09	A1	5230										
74	22	09	A1	6760	3890					6.7	19.5	490	4.3	11.12
74	22	09	A1	5570						6.0	20.0		4.0	
74	23	09	A1	5940										
74	23	09	A1	5950						6.9	3.0		4.2	
74	23	10	A1	6200										
74	24	10	A1	2930						7.1	20.5		2.1	
74	24	10	A1	6130						7.2	20.0		2.7	
74	24	10	A1	6250										
74	24	10	A1	6290	3890					7.0	20.5	700	2.3	10.66
74	24	10	A1	5970						6.6	20.5		1.8	
74	24	10	A1	5940										
74	24	10	A1	5900						7.1	24.0		5.3	
74	24	10	A1	7190						7.0	25.0		3.5	
74	24	10	A1	6730						6.8	25.0		3.5	
74	25	10	A1	7200										
74	25	10	A1	7200						7.1	25.0	870	1.8	12.26

ERROR NO VSS WAS TAKEN, THEREFORE THE VSS VALUE VSS OF 54 PER CENT

OPERATOR A 74 DUE TO OPERATOR A WAS SHOWN /74

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL	SS ALK	EFFLUENT NO3N HACH	PH	TEMP	MIN SET	DO	OUR
74	07	02	07	AM	A2	5350		98200	22	32	2	7.5	10.3		5.8	
74	08	02	08	PM	A2	5410		99560	21		14	7.5	10.3		5.6	
74	09	02	09	PM	A2	4830		99800	23	21			10.0		5.1	
74	10	02	10	AM	A2	4770		89700	21	44			10.0		6.1	
74	11	02	11	AM	A2	5130	3640	11200	22	36	140	7.4	9.3	550	6.3	4.70
74	12	02	12	AM	A2	5520	3960	95800	24							
74	13	02	13	AM	A2	5520	3630	83500	26	89		7.4	10.3	560	6.1	4.90
74	14	02	14	AM	A2	5180		100200	33	122		7.8	9.5		6.2	
74	15	02	15	AM	A2	4980		98000	17	846		7.4	10.0		3.5	3.56
74	16	02	16	AM	A2	5080		92800	19	999		7.1	10.5		4.8	
74	17	02	17	AM	A2	5000		83700	18	81			10.3		4.2	
74	18	02	18	AM	A2	4970		82600	18	88			11.0		5.0	
74	19	02	19	AM	A2	4170	3020	85200	17	127		7.6	10.0		4.1	
74	20	02	20	AM	A2	4980		75300	50	57	143		9.3		5.8	
74	21	02	21	AM	A2	4690	3380	76100	40	39		8.1	9.3		4.4	
74	22	02	22	AM	A2	5060		72200	40			7.5	10.8		4.3	
74	23	02	23	AM	A2	4960		83900	40	23	100	7.7	10.3	355	4.0	3.18
74	24	02	24	AM	A2	5000		79500	40	33		7.2	15.0		2.6	
74	25	02	25	AM	A2	6540		96400	51	31			15.0		4.2	
74	26	02	26	AM	A2	4990		77200	28	52			14.8		4.1	
74	27	02	27	AM	A2	4770	3100	74300	40	38		7.5	14.5		3.8	
74	28	02	28	AM	A2	5250		76400	50	33	77	7.2	14.5	345	2.0	6.59
74	29	02	29	AM	A2	4700		71900	50	15		7.2	15.5		5.8	
74	30	02	30	AM	A2	4730	3140	73700	50	20	53	7.4	14.8		6.1	8.00
74	01	03	01	AM	A2	5810		59100	50	19			15.0		6.1	
74	02	03	02	AM	A2	4130		63300	50	16		7.4	14.5		7.8	
74	03	03	03	AM	A2	3690	2430	66000	50	51		7.5				
74	04	03	04	AM	A2	4560		79900	35	54		7.6	5.5		9.2	
74	05	03	05	AM	A2	4900		10430	60	57		7.9	5.0		10.0	
74	06	03	06	AM	A2	5150	1480	71000	40	66		7.6	5.5		8.1	
74	07	03	07	AM	A2	4320		71000	40	43		7.7	4.8		8.0	
74	08	03	08	AM	A2	5360	3560	62200	50	51						

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	---EFFLUENT--- NH3N NO3N HACH	PH	TEMP	SET	DC	JUR
74	07	04	07	PM	A2	5010	8950	11270	35	74	7.5	14.8	6.4			
74	08	04	08	AM	A2	5190	4410	11350	19							
74	09	04	09	AM	A2	4930	3060	10660	10							
74	09	04	09	AM	A2	4780	3060	11340								
74	09	04	09	AM	A2	4840		7020	20							
74	09	04	09	AM	A2	4770		9900								
74	10	04	10	AM	A2	5410	3580	11510		22	7.6	14.8	4.4	405	5.78	
74	10	04	10	AM	A2	5240		11540								
74	10	04	10	AM	A2	5270	3400	11280								
74	10	04	10	AM	A2	5080		11570	25							
74	10	04	10	AM	A2	4460		11260		33	7.1	14.8	4.1	6.84		
74	11	04	11	AM	A2	5660		11430	30	7						
74	11	04	11	AM	A2	4440		10770	20	4						
74	11	04	11	AM	A2	4450		10930	20	49						
74	11	04	11	AM	A2	5090		9140	10	46						
74	11	04	11	AM	A2	5550	3860	10760		17	7.4	5.3	3.9	655	2.86	
74	11	04	11	AM	A2	5670		10180	18							
74	11	04	11	AM	A2	6000		10190	27							
74	11	04	11	AM	A2	7130	4930	13780	36	15	7.2	5.0	4.1	800	3.15	
74	11	04	11	AM	A2	5680		9000	35	66						
74	11	04	11	AM	A2	5020		8290	35	22	7.3	5.3	7.8			
74	12	04	12	AM	A2	4140	2750	6270	30	22	7.3	5.3	6.1	380	2.67	
74	12	04	12	AM	A2	4400		8460	40	55						
74	12	04	12	AM	A2	4920	3230	10980	30	22	7.4	5.3	6.1	330	1.87	
74	12	04	12	AM	A2	5980		9810	30	22						
74	12	04	12	AM	A2	4640		10260	10	22	7.3	6.0	4.6			
74	12	04	12	AM	A2	5870		9930	30	10						
74	12	04	12	AM	A2	7490		10370	14	10	5.9	10.0	5.2			
74	12	06	12	AM	A2	5960	4300	10330	11	14	7.0	10.0	5.4	850	3.11	
74	12	06	12	AM	A2	5630		9190	20	18						
74	12	06	12	AM	A2	5510		10370	21	18	5.9	10.0	5.5			
74	12	06	12	AM	A2	5330	4130	10390	14	15	5.9	9.0	5.1	885	4.36	

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N	HACI	PH	TEMP	30 MIN SET	DO	OUR
74	20	06	PM	A2	5840		10130	25								
74	21	06	AM	A2	6200		9840	21	17			6.9	12.0			5.3
74	22	06	AM	A2	7270		12390	40	13			7.0	16.0			6.3
74	23	06	AM	A2	7650				9			7.2	17.5			5.6
74	24	06	AM	A2	7530		7780	40								
74	25	06	PM	A2			6510	50								
74	26	06	AM	A2	7150	4940	13210	20	12	5		6.5	15.0	910	6.2	1.91
74	27	06	PM	A2	6360		10100	37								
74	28	06	AM	A2	6430		8460	11	5			6.4	16.0			7.1
74	29	06	AM	A2	6380	4470	6980	20	26	40		7.1	17.3	850	4.2	4.49
74	30	06	AM	A2	6610		7330	40								
74	01	07	AM	A2	5560		6260	20	5							5.3
74	02	07	AM	A2	6080		9040	36	56			6.7	6.0			5.5
74	03	07	AM	A2	5700		9670	19	6			7.1	6.5			
74	04	07	AM	A2	5100	3690	5600	40	10	63		7.4	16.0			6.1 1.98
74	05	07	AM	A2	5500				8			7.2	6.0			4.4
74	06	07	AM	A2	6390				19	81		7.0	6.0	800	3.4	2.05
74	07	07	AM	A2	4670		3790	40								
74	08	07	AM	A2	6550		9090	50	15							
74	09	07	AM	A2	6330				14	52		6.9	13.0	330		4.95
74	10	07	AM	A2	6240		9830	50								
74	11	07	AM	A2	6240		9540	65								
74	12	07	AM	A2	5580		9540	65								
74	13	07	AM	A2	5180	3730	9930	30	73			7.1	20.0			6.5
74	14	07	AM	A2	5370											
74	15	07	AM	A2	5430											
74	16	07	AM	A2	7340			30								
74	17	07	AM	A2	6560		9900	45	33			7.1	21.0			1.9
74	18	07	AM	A2	6170		9450	39								
74	19	07	AM	A2	5770		13670	40	24							
74	20	07	AM	A2	5810		18580	45	13							
74	21	07	AM	A2	6166	4450	8480	45	12	6		7.1	20.5	810	5.7	5.06
74	22	07	AM	A2	5900		9650	35	100			6.3	20.5			5.6
74	23	07	AM	A2	8560		10050	35								
74	24	07	AM	A2	7800		12240	60	25			6.2	20.0			
74	25	07	AM	A2			11230	68	15			7.2	20.5			7.5

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	NH3N HACH	PH	TEMP	SET	30 MIN	DC	JUR
74	07	07	04	PM	A2	5010		11270	35	24			7.5	14.8				
74	08	08	04	AM	A2	5190	8950	11270	14									6.4
74	09	09	04	AM	A2	6670	4410	11350	19									
74	09	09	04	AM	A2	4930		10660	10									
74	09	09	04	AM	A2	4780	3060	11340										
74	09	09	04	AM	A2	4840		7020	20									
74	09	09	04	AM	A2	4770		9900										
74	10	10	04	AM	A2	4770		10610		22	76		7.6	14.8	405	4.4	5.76	
74	10	10	04	AM	A2	5410	3580	11510										
74	10	10	04	AM	A2	5270	3400	11540										
74	10	10	04	AM	A2	5080		11280										
74	10	10	04	AM	A2	4460		11570	25									
74	10	10	04	AM	A2	4460		9320		33	35		7.1	14.8		4.1	6.84	
74	11	11	04	AM	A2	5660		11430	30	7								
74	11	11	04	AM	A2	4440		10770	20	4								
74	11	11	04	AM	A2	4450		10930	20	49								
74	11	11	04	AM	A2	5450		9140	15	46								
74	11	11	04	AM	A2	5550	3860	10760	10	17	99		7.4	5.3	655	3.2	2.86	
74	11	11	04	AM	A2	5670		10180	18									
74	11	11	04	AM	A2	6000		10190	27	15	107		7.2	5.3	800	4.2	3.15	
74	11	11	04	AM	A2	7130	4930	10190	27									
74	11	11	04	AM	A2	5630		13780	36	68								
74	11	11	04	AM	A2	4680		9000	35	22								
74	11	11	04	AM	A2	5020		8290	35	22	165		7.3	5.3		7.8		
74	12	12	05	AM	A2	4140	2750	8270	30									
74	12	12	05	AM	A2	4420		8460	40	55								
74	12	12	05	AM	A2	4920	3280	10980	30	22	195		7.4	5.5	330	6.1	1.87	
74	12	12	05	AM	A2	5980		9810	30									
74	12	12	05	AM	A2	4840		10980	30	22								
74	12	12	05	AM	A2	5870		9810	30	10								
74	12	12	05	AM	A2	7490		10260	10	10								
74	12	12	06	AM	A2	5960	4300	9920	11									
74	12	12	06	AM	A2	5630		11530	21	14								
74	12	12	06	AM	A2	5510		10330	21	18								
74	12	12	06	AM	A2	5330	4130	10370	14									
74	12	12	06	AM	A2	5330		10390	14	15	39							

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N HACH	PH	TEMP	MIN SET	CC	OUR
74	02	08	PM	A2	7510		6290	52	25						
74	03	08	AM	A2	7000		11540	33							
74	04	08	AM	A2	6960		12690	40	8						
74	05	08	AM	A2	7050	4780	11120		56	10	6.8	20.0	920	3.6	4.04
74	06	08	AM	A2	6300		9100	25	100		6.4	20.5		4.8	
74	07	08	AM	A2	6720		13180	30			6.3	21.0	920	5.6	
74	08	08	AM	A2	7180	4720	12280	35	116	12	6.6	21.0	920	4.8	5.83
74	08	08	1900	A2	6810		11350	20			6.6	20.5		5.1	
74	09	08	AM	A2	7730		113590	20			6.9	20.5	670	6.6	
74	10	08	AM	A2	7340	4690	10740	30	18	21	6.6	20.0		3.9	7.41
74	11	09	AM	A2	5390		10620	50							
74	11	09	1645	A2	5550		110040	50	13		6.6	20.0		3.7	
74	11	09	AM	A2	5850	3960	10070	70	17	21	6.4	20.0	720	3.9	8.89
74	12	09	AM	A2	5880		9890	50						2.9	
74	20	09	AM	A2	5650		10480	55						4.9	
74	21	09	AM	A2	7050		12480	32	19						
74	22	09	AM	A2	7530		113610	40	24						
74	22	09	AM	A2	5980		12680	40	45		6.5	19.5		6.0	
74	23	09	AM	A2	11480	35	11910	30							
74	24	09	AM	A2	10800	30	11170	30	14	22	6.4	21.0	520	5.1	5.11
74	25	09	AM	A2	5640	3800	9190	55	34		6.6	19.5		3.8	
74	26	09	AM	A2	5710		11590	45						5.5	
74	27	09	AM	A2	5950	4030	10940	55	14	26	6.1	19.5	350	6.0	6.49
74	27	09	AM	A2	5330		9680	45				20.0		4.4	
74	27	09	AM	A2	5810		9770	80							
74	28	09	AM	A2	5770		10890	50			6.9	9.0		6.3	
74	30	09	AM	A2	6010		9440	80	15						
74	31	09	AM	A2	5120		10890	70	13					4.4	
74	15	10	AM	A2	4700		11390	30	24		7.1	20.5		4.7	
74	15	10	AM	A2	7170		12580	50	12		7.2	20.0		3.1	
74	16	10	AM	A2	6240		11610	35							
74	16	10	AM	A2	5250		12220	40	18		7.1	20.5		4.5	

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	NH3N	HACH	PH	TEMP	SET	MIN	DO	OUR
74	17	10	PM	A2	5880	3830	11580	30	56	62	6.6	20.0	740	2.2	12.25	3.2		
74	18	10	PM	A2	5970		12030	35										
74	19	10	AM	A2			10790	40										
74	20	10	AM	A2	6020		10060	70	31									
74	21	10	AM	A2				53										
74	22	10	PM	A2				80										
74	23	10	AM	A2	5850		10220	50	22		7.2	23.5		5.9				
74	24	10	AM	A2	6050		12610	80	15		7.1	25.5		6.3				
74	25	10	AM	A2	6690	4480	12550	50	31	77	7.0	24.5	820	6.5				
74	26	10	AM	A2	7590		14140	35	28		7.1	25.0		3.5				
74	27	10	AM	A2	6570		13320	75			7.0	24.5		1.1				
74	28	10	AM	A2	7940													
74	29	10	PM	A2	7460	4880			49	10	7.0	23.0	930	6.0				
74	30	10	AM	A2	7750		12180	40			7.1	24.0		5.0				
74	01	11	AM	A2	7570			35						7.2				
74	02	11	AM	A2			10900	35										
74	03	11	AM	A2	7010		10140	40	30					4.9				
74	04	11	AM	A2	6350				38		7.4	24.5		6.8				
74	05	11	AM	A2		4310	11560	35	29	13	6.6	24.0	870	4.8				
74	06	11	AM	A2	6400		11750	0	9					3.6				
74	07	11	AM	A2	6690		7650	35	8		6.9	11.0	955	3.8				
74	08	11	AM	A2	5640		10170	20						2.8				
74	09	11	AM	A2	5830	3960	9320	70						1.2				
74	10	11	AM	A2	5510		8610	30										
74	11	11	AM	A2			2310	50	136		8.1	9.0		6.3				
74	12	11	AM	A2	4700		5540	30	44		6.7	3.0		5.0				
75	01	12	AM	A2	5570		5610	50	13					5.0				
75	02	12	AM	A2	5570		5610	30						6.0				
75	03	12	AM	A2	5860		5840	30						4.4				
75	04	12	AM	A2	6020		5970	70	20		7.1	9.0	910	4.3				
75	05	12	AM	A2	5730		5730	40	27	57	8.0	9.0		4.3				
75	06	12	AM	A2	5630	3910	5680	40						4.7				
75	07	12	AM	A2	5310		3285	160	27	27	6.4	24.5	280	4.7				
75	08	12	AM	A2	3490				32					3.7				
75	09	12	AM	A2	2950													
75	10	12	AM	A2	3020													
75	11	12	AM	A2	4980													
75	12	12	AM	A2														
75	13	12	AM	A2														
75	14	12	AM	A2														
75	15	12	AM	A2														
75	16	12	AM	A2														
75	17	12	AM	A2														
75	18	12	AM	A2														
75	19	12	AM	A2														
75	20	12	AM	A2														
75	21	12	AM	A2														
75	22	12	AM	A2														
75	23	12	AM	A2														
75	24	12	AM	A2														
75	25	12	AM	A2														
75	26	12	AM	A2														
75	27	12	AM	A2														
75	28	12	AM	A2														
75	29	12	AM	A2														
75	30	12	AM	A2														
75	31	12	AM	A2														
75	32	12	AM	A2														
75	33	12	AM	A2														
75	34	12	AM	A2														
75	35	12	AM	A2														
75	36	12	AM	A2														
75	37	12	AM	A2														
75	38	12	AM	A2														
75	39	12	AM	A2														
75	40	12	AM	A2														
75	41	12	AM	A2														
75	42	12	AM	A2														
75	43	12	AM	A2														
75	44	12	AM	A2														
75	45	12	AM	A2														
75	46	12	AM	A2														
75	47	12	AM	A2														
75	48	12	AM	A2														
75	49	12	AM	A2														
75	50	12	AM	A2														
75	51	12	AM	A2														
75	52	12	AM	A2														
75	53	12	AM	A2														
75	54	12	AM	A2														
75	55	12	AM	A2														
75	56	12	AM	A2														
75	57	12	AM	A2														
75	58	12	AM	A2														
75	59	12	AM	A2														
75	60	12	AM	A2														

MLVSS A1=2310 A2=2158 B1=1577 B2=0.633 MG/L
 ASSUMED 3020 4980

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	HLSS	VSS	WASTE CONC	IGAL	SS	ALK	NH3N	HACH	PH	TEMP	MIN	DO	OU3
77	20	06	06	AM	A2	5390	345J	3330	25	22	30		6.4	19.0	508	3.5	7.68	
77	21	06	06	PM	A2	5430		5430	40	16				18.5		3.3		
77	22	06	06	PM	A2				80									
77	23	06	06	PM	A2				40	133			7.3	5.5	220	9.1		
77	09	11	11	0900	B1	6230	3950	20030	40									
77	10	11	11	1500	B1	5550	346J		40									
77	11	11	11	11 AM	B1	4240	3110		44	47			7.4	13.5	280	5.0		
77	12	11	11	11 AM	B1	5380	4130	16770	40	57			7.3	5.0	220	8.4		
77	13	11	11	11 AM	B1	5230	4110		40	81			7.4	5.0	205	8.7	1.56	
77	14	11	11	11 AM	B1	5400	3730	16550	44	81	189		7.4	5.0	205	8.7		
77	15	11	11	11 AM	B1	5750	4095	11080	44	63			7.5	4.5	165	11.6		
77	16	11	11	11 AM	B1	7430		16670	44	37								
77	17	11	11	11 AM	B1	4090			53									
77	18	11	11	11 AM	B1	5580			53									
77	19	11	11	11 AM	B1	5330	3740		60	65	214		7.4	4.5	235	9.6	2.22	
77	20	11	11	11 AM	B1	4980	3530		55									
77	21	11	11	11 AM	B1	4900			58									
77	22	11	11	11 AM	B1	4080			4									
77	23	11	11	11 AM	B1	4060			4									
77	24	11	11	11 AM	B1	4160			4									
77	25	11	11	11 AM	B1	3950			45									
77	26	11	11	11 AM	B1	3540			45									
77	27	11	11	11 AM	B1	4270			45									
77	28	11	11	11 AM	B1	4670			45									
77	29	11	11	11 AM	B1	3810			45									
77	30	11	11	11 AM	B1	4370			28									
77	31	11	11	11 AM	B1	4390			30									
77	01	12	12	11 AM	B1	3820			30									
77	02	12	12	11 AM	B1	4290			30									
77	03	12	12	11 AM	B1	4290			30									
77	04	12	12	11 AM	B1	4290			30									
77	05	12	12	11 AM	B1	4290			30									
77	06	12	12	11 AM	B1	4290			30									
77	07	12	12	11 AM	B1	4290			30									
77	08	12	12	11 AM	B1	4290			30									
77	09	12	12	11 AM	B1	4290			30									
77	10	12	12	11 AM	B1	4290			30									
77	11	12	12	11 AM	B1	4290			30									
77	12	12	12	11 AM	B1	4290			30									
77	13	12	12	11 AM	B1	4290			30									
77	14	12	12	11 AM	B1	4290			30									
77	15	12	12	11 AM	B1	4290			30									
77	16	12	12	11 AM	B1	4290			30									
77	17	12	12	11 AM	B1	4290			30									
77	18	12	12	11 AM	B1	4290			30									
77	19	12	12	11 AM	B1	4290			30									
77	20	12	12	11 AM	B1	4290			30									
77	21	12	12	11 AM	B1	4290			30									
77	22	12	12	11 AM	B1	4290			30									
77	23	12	12	11 AM	B1	4290			30									
77	24	12	12	11 AM	B1	4290			30									
77	25	12	12	11 AM	B1	4290			30									
77	26	12	12	11 AM	B1	4290			30									
77	27	12	12	11 AM	B1	4290			30									
77	28	12	12	11 AM	B1	4290			30									
77	29	12	12	11 AM	B1	4290			30									
77	30	12	12	11 AM	B1	4290			30									
77	31	12	12	11 AM	B1	4290			30									
77	01	01	01	11 AM	B1	4290			30									
77	02	01	01	11 AM	B1	4290			30									
77	03	01	01	11 AM	B1	4290			30									
77	04	01	01	11 AM	B1	4290			30									
77	05	01	01	11 AM	B1	4290			30									
77	06	01	01	11 AM	B1	4290			30									
77	07	01	01	11 AM	B1	4290			30									
77	08	01	01	11 AM	B1	4290			30									
77	09	01	01	11 AM	B1	4290			30									
77	10	01	01	11 AM	B1	4290			30									
77	11	01	01	11 AM	B1	4290			30									
77	12	01	01	11 AM	B1	4290			30									

MG/L BASED ON AVERAGE DAILY VALUE
 7.4 4.5 235 9.6 2.22
 7.4 4.5 205 9.6
 7.4 4.5 205 9.6
 7.3 5.5 170 6.8 2.13
 7.3 5.5 160 6.8
 7.4 6.5 6.5 6.5
 7.4 5.5 5.5 5.5
 7.2 4.8 200 5.5 2.44
 7.5 5.0 2.3

MG/L BASED ON AVERAGE DAILY VALUE
 7.4 4.5 214 9.6 2.22
 6.0 6.9 5.2 5.5 6.4
 5.3 5.8 4.1 4.7
 5.3 5.8 4.1 4.7
 9980 45
 11270 45
 13470 28
 10940 30
 13330 30
 13050 38
 13000 38
 14100 25
 12770 25
 12130 20
 11030 20
 112770 21
 121740 21
 5130 21
 5130 21

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N	PH	TEMP	MIN SET	DO	OUR
74	01	02	AM	31	4780		10980	20	14		7.6	4.0		2.6	
74	02	02	AM	31	4280	3150	6150	30	40						
74	03	02	AM	31	4280		6240								
74	04	02	0900	31	4660		8800								
74	04	02	1200	31	4620	3220	8800								
74	04	02	1800	31	4190		10440								
74	04	02	2100	31	4368		17360								
74	04	02	AM	31	4310		12310	22	55	7.2	4.5	210	5.0	3.72	
74	05	02	0300	31	4210		10210	50	325	7.2	4.5		5.1		
74	05	02	AM	31	3990		8850	25	343	7.6	9.0		6.3		
74	06	02	AM	31	6220		11480	45	53	7.6	10.0		6.8		
74	07	02	AM	31	5090		12310	30	31	7.2	10.0		4.7		
74	08	02	AM	31	3700		7820	58	14	7.6	10.0		5.1		
74	09	02	AM	31	4300	3170	8540	62	30	7.6	9.5	200	5.1	5.91	
74	11	02	AM	31	5050	3640	3940	37	30	7.4	10.0		5.1	5.37	
74	11	02	AM	31	3780	3020	8050	45	28	8.2	9.5	230	6.1		
74	13	02	AM	31	4250		10500	33		7.5	10.0		4.4	3.14	
74	14	02	AM	31	4230		9850	70	49	7.3	10.0		4.5		
74	15	02	AM	31	470		11640	63	412	7.4	10.0		3.0		
74	16	02	AM	31	4100		8990	80	18	7.4	10.0		4.0		
74	17	02	AM	31	4040		8580	100	49	7.4	10.0		4.0		
74	18	02	AM	31	3270	2470	8790	80	73	7.4	10.0		2.9		
74	19	02	AM	31	3420		8110	40	64	8.1	7.0		4.2		
74	20	02	AM	31	5010		5010		38	7.4	10.5		2.6		
74	22	02	AM	31	4420	3220	9250	80	34	7.6	10.0	230	3.5	2.66	
74	22	02	AM	31	4900		8520	20		7.3	15.5		2.0		
74	22	02	AM	31	6490		7730	40	31	7.3	15.5		2.0		
74	23	02	AM	31	7110		10610	60	35		14.8		3.1		
74	24	02	AM	31	3450		8120	80	37		15.3		3.5		
74	24	02	AM	31	6700		6700	80	30	7.5	14.8		3.1		
74	25	02	AM	31	8630		8630	20	27	7.6	15.0	235	3.7	7.14	
74	26	02	AM	31	11250	3780	11250	50	32	7.4	14.5		4.0		
74	27	02	AM	31	9060		9060	40	10	7.3	15.5		3.7		
74	28	02	AM	31	10570	3570	10570	30	25	7.6	14.8	260	4.1	7.51	
74	28	02	AM	31	11860		11860	30							

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N HACH	PH	IF 1P	MIN SET	DC	CUR
74	28	04	04	PM	B1	3170		1350	75			7.3	20.5			4.1
74	29	04	04	AM	B1	2340		3100	40	29						
74	30	04	04	AM	B1		1350	2220	35							
74	30	04	04	AM	B1	2160		6040								
74	30	04	04	AM	B1	1880		2710								
74	30	04	04	AM	B1	2940	1990	3960								
74	30	04	04	AM	B1	1970		2120	6							
74	30	04	04	AM	B1	1950		3720								
74	01	05	05	AM	B1			7500	80	23		7.4	20.5	80	5.5	7.74
74	01	05	05	AM	B1	2770	2050	6280								
74	01	05	05	AM	B1	2980		4460	20							
74	01	05	05	AM	B1	3250	2350	4060								
74	01	05	05	AM	B1	2370		16270	1							
74	01	05	05	AM	B1	2570		4930								
74	01	05	05	AM	B1			5260								
74	02	05	05	AM	B1	4020	2980	7490		74		7.3	20.5	150	5.3	10.94
74	03	05	05	AM	B1				40	34						
74	04	05	05	AM	B1				40							
74	05	05	05	AM	B1				40							
74	06	05	05	AM	B1	3830		6330		14		7.4	14.3			3.5
74	06	05	05	AM	B1	5250		7320								
74	07	05	05	AM	B1			4270		35		7.4	14.5			3.6
74	08	05	05	AM	B1	(NO MLSS TAKEN)				40						
74	08	05	05	AM	B1			1390								
74	09	05	05	AM	B1	2120		17290		38		7.5	15.2			7.3
74	09	05	05	AM	B1	2060		6160		18						
74	10	05	05	AM	B1			13230								
74	11	05	05	AM	B1			12630								
74	12	05	05	AM	B1	1950		9180		49		8.2	15.0			8.3
74	13	05	05	AM	B1	2480				52						
74	14	05	05	AM	B1	1210	910	31090	15	33		7.7	15.0	45	4.3	21.32
74	15	05	05	AM	B1	2510										
74	15	05	05	AM	B1	4080				27		7.9	14.8			6.1
74	16	05	05	AM	B1	3430	2100	26240	17	33		7.6	15.0	120	7.3	
74	17	05	05	AM	B1	3800		24920	20							
74	17	05	05	AM	B1	4840		5750	35	33		7.6	6.5			4.5
74	18	05	05	AM	B1	2720		2350	50	68						

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N HACH	PH	TEMP	30 MIN SET	DC	CUR
74	20	05	AM	B1	2270		1960	50	51	7.5	7.5	5.0		6.4	
74	21	05	PM	B1	2090	1600	6170	35	64	7.6	7.6	5.0	100	9.2	2.19
74	22	05	AM	B1	2560				69	7.6	7.6	5.0		9.7	
74	23	05	AM	B1	3730	2920	13020	5	51	7.5	7.5	5.0	160	6.1	2.10
74	24	05	AM	B1	3970		9850	70	55	7.4	7.4	6.5		5.9	
74	25	05	AM	B1	4870		8950	50	24	7.4	7.4	6.5		4.4	
74	26	05	AM	B1	5170		9500	42	53						
74	27	05	AM	B1	4890		9640	55							
74	28	05	AM	B1											
74	29	05	AM	B1	5970		10340	4	86	7.1	7.1	5.0		9.5	
74	30	05	AM	B1	4680		10730	40	93	7.5	7.5	5.5		5.3	
74	31	05	AM	B1	9020		119860	30	88	7.5	7.5	6.0		5.9	
74	01	06	AM	B1	3460		9350	80	19	7.2	7.2	6.0		5.6	
74	02	06	AM	B1	2340		9240	40	64	7.4	7.4	5.5	165	3.9	2.34
74	03	06	AM	B1	2940	2240	43220	20	68	7.4	7.4	5.3		8.7	
74	04	06	AM	B1	4340		62800	30	56	7.4	7.4	6.5	120	5.3	2.35
74	05	06	AM	B1	3450		48900	40	63	7.4	7.4	6.6		4.6	
74	06	06	AM	B1	3320	2500	10250	30							
74	07	06	AM	B1	2680		71500	40							
74	08	06	AM	B1	4480		5270	30							
74	09	06	AM	B1			6210	70							
74	10	06	AM	B1	3430		6110	30	51	7.2	7.2	10.0	225	4.0	4.93
74	11	06	AM	B1	4380		10400	10	36	7.5	7.5	9.5		1.0	
74	12	06	AM	B1	5220		17880	30	16	7.2	7.2	10.0		0.5	
74	13	06	AM	B1	5640		8960	41	21	7.1	7.1	10.0	28	4.2	1.79
74	14	06	AM	B1	5130	3980	8540	30		7.0	7.0	10.0		4.0	
74	15	06	AM	B1	5410		10890	60		6.9	6.9	10.0		1.0	
74	16	06	AM	B1	3540			70							
74	17	06	AM	B1	3810		8690	80	10	7.1	7.1	9.5		6.5	
74	18	06	AM	B1	3500	2920	7470	40	31	7.2	7.2	9.0	210	5.4	3.60
74	19	06	AM	B1	3670		9930	45							

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N HACH	PH	TEMP	MIN SET	CC	CUR
74	13	06	AM	B1	3590		7370	35	14	7.2	7.2	3.5		5.5	
74	19	06	PM	B1			7300	5							
74	20	06	AM	B1	3840	2630	6600	40	5		7.2	8.5	145	5.5	2.15
74	22	06	AM	B1	3860		5530	40							
74	22	06	AM	B1			7200	20							
74	22	06	AM	B1				55							
74	22	06	AM	B1	6550		12480	9	13	5.9	16.0			3.7	
74	22	06	AM	B1	6630		11160	5	9	7.1	17.0			2.5	
74	22	06	AM	B1	7090		12980	3	11	5.7	15.0		850	2.1	2.46
74	22	06	AM	B1	6210	4300	13860	3	8	6.8	16.0			2.5	
74	22	06	AM	B1	6970		19240	3	25	7.5	16.0		600	2.7	4.82
74	22	06	AM	B1	5940		3890	3	16						
74	22	06	AM	B1	7050	5070	7760	3	16						
74	22	06	AM	B1	6220		7550	3							
74	22	06	AM	B1	6210		8320	7							
74	30	07	AM	B1	4140			7							
74	01	07	AM	B1			6030	7							
74	02	07	PM	B1			5030	7							
74	02	07	AM	B1			3150	3							
74	02	07	AM	B1	4030	1360	4050	3	31	6.9	14.5		135	3.3	5.70
74	02	07	AM	B1	2650		10160	3	21	7.5	15.5			6.8	
74	03	07	AM	B1			3040	3							
74	03	07	AM	B1	2930		8580	3	29	7.0	13.5			7.4	
74	04	07	AM	B1			6050	3							
74	05	07	AM	B1	2950		12010	3	44	7.3	13.5		75	7.2	2.23
74	05	07	AM	B1	2710			3							
74	05	07	AM	B1	2250			4							
74	06	07	AM	B1	3290		9150	4	13	7.2	5.0			6.3	
74	08	07	AM	B1	1960		7160	3	79	7.3	6.0			6.3	
74	09	07	AM	B1			11000	4							
74	09	07	AM	B1	1320	1760	8210	1	120	7.5	6.0			4.9	1.60
74	10	07	AM	B1	3470		5600	3	79	7.4	5.0			2.1	
74	11	07	AM	B1	3990	3100		3	86	7.3	5.5		175	2.1	2.24
74	11	07	AM	B1	3940		12840	3							
74	11	07	AM	B1	3960		3330	3	18	7.3	14.5			3.0	
74	11	07	AM	B1	1720		32283	1	62						

REACTOR OPERATING RESULTS

YEAR	JAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	WASTE GAL	IGAL	SS ALK	EFFLUENT NH3N HACH	PH	TEMP	MIN SET	DO	DO2		
74	16	07	16	AM	B1	4000	280J	3180	30	30	46	7.4	14.0	110	4.5	3.04			
74	16	07	16	PM	B1	3620		25240	39	30	24	7.0	14.0	110	2.3				
74	17	07	17	AM	B1	3680		5280	30	30	49	7.4	15.0	115	4.5	4.09			
74	18	07	18	AM	B1	3490	2610	20240	20	20	50	7.4	14.0	115	4.5	4.09			
74	18	07	18	PM	B1	2330		19370	20	20		7.2	14.5		3.2				
74	19	07	19	AM	B1	6560		11050	30	30									
74	19	07	19	PM	B1	4650		19090	30	30	9								
74	22	07	22	AM	B1	2260		13350	20	20	51	7.2	13.0	90		5.08			
74	22	07	22	PM	B1	2560	2010	14730	30	30									
74	23	07	23	AM	B1	2400		14430	30	30									
74	23	07	23	PM	B1	3590		18330	30	30									
74	24	07	24	AM	B1	3820		15620	30	30	44	7.3	20.0		4.1				
74	25	07	25	AM	B1	7570	23520	13300	70	70	78	7.3	20.5		1.3				
74	26	07	26	AM	B1	3010		12810	30	30	39								
74	27	07	27	AM	B1	2030		10110	30	30									
74	28	07	28	PM	B1	2600		45490	30	30	32	7.2	20.5	90	4.7	4.00			
74	29	07	29	AM	B1	2920	2190	7820	30	30	23	7.2	20.0		5.2				
74	30	07	30	AM	B1	2930	10460	3390	16	16	116	7.3	20.0		5.2				
74	31	07	31	AM	B1	9130		13790	30	30	30	7.0							
74	01	08	01	AM	B1	5190		17800	14	14	38	7.3	20.5		6.0				
74	01	08	01	PM	B1	3350		19120	30	30	1								
74	02	08	02	AM	B1	4000		12090	40	40	30								
74	02	08	02	PM	B1	4220		12090	30	30									
74	03	08	03	AM	B1	4280	3200	6070	30	30	23	7.1	20.5	245	4.7	4.84			
74	03	08	03	PM	B1	4010		7070	40	40	28	7.2	20.5		5.0				
74	04	08	04	AM	B1	4630	4220	118470	40	40	21	7.3	21.0	175	4.3	3.32			
74	04	08	04	PM	B1	6560	4220	118470	40	40									
74	05	08	05	AM	B1	4950		20310	40	40									
74	05	08	05	PM	B1	7440			30	30									
74	06	08	06	AM	B1	4490		9060	30	30									
74	06	08	06	PM	B1	3490		11270	30	30	13	7.2	21.0		5.7				

Y

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	EFFLUENT NH ₃ N HACH	PH	TEMP	MIN SET	DC	CUR
74	13	03	AM	B11	4730	2800	12500	30	24			7.1	21.0	120	3.1	7.17
74	14	08	PM	B11	3480				21			6.9	22.0		3.1	
74	15	08	AM	B11	4530				20			7.0	19.5	100	5.5	5.67
74	16	08	PM	B11	4266	2890	15350	30	20			6.9	22.0		3.7	
74	17	08	AM	B11	2590				20						6.8	
74	18	08	AM	B11	4230			30	43							
74	19	08	AM	B11	2170			45	62			7.5	19.0	70	8.7	7.14
74	20	08	AM	B11	1700	1810	2970	17	41			7.1	19.0		7.0	
74	21	08	AM	B11	2330		5890	40	29			7.2	19.0	100	5.1	3.26
74	22	08	AM	B11	1770		16750		30						6.1	
74	23	08	AM	B11	2990	3820	23070	35	30			7.1	11.5		6.1	
74	24	08	AM	B11	5350										6.1	
74	25	08	AM	B11	2750										6.1	
74	26	08	AM	B11	4410											
74	27	08	AM	B11	4370		9720	40	56				4.5			
74	28	08	AM	B11	10940			56								
74	29	08	AM	B11	3470		6570	11	142			7.4	7.6		6.8	
74	30	08	AM	B11	4640	3330	5050	30	136			7.3	20.0	270	16.4	
74	31	08	AM	B11	5040		19350		198			7.4	6.8		6.7	
74	01	09	AM	B11	4700		8650								4.7	
74	02	09	AM	B11	5710		11120	30				7.1	7.6		5.9	
74	03	09	AM	B11	7010		10230	48								
74	04	09	AM	B11	3000		10470	85	122			6.5	25.0		3.0	
74	05	09	AM	B11	3720		18020	10	34							
74	06	09	AM	B11	3000		2120	30	32			7.2	26.0	0	4.5	
74	07	09	AM	B11	5150		16040	30	17			5.7	21.6	310	2.8	9.83
74	08	09	AM	B11	5500	3730	20940	30	12							
74	09	09	AM	B11	4270		17330	25								
74	10	09	AM	B11	6570		13870	50	19							
74	11	09	AM	B11	5150		6320	14	10							
74	12	09	AM	B11	21860		21860	35								
74	13	09	AM	B11	7000		7000	10	19							
74	14	09	AM	B11	5850	3740	22060	45	19							
74	15	09	AM	B11	3780		6480	10								
74	16	09	AM	B11	5610		1180	55	19							

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N	HACH	PH	TEMP	MLT	DO	OUR
72	11	12	9:30 AM	11	6700	3200	1180	45	21	2.1	2.1	7.0	23.0	250	2.1	1.37
74	11	13	9:30 AM	11	6100	3100	10840	45				7.0	23.0			
74	11	14	9:30 AM	11	6300			70								
74	11	15	9:30 AM	11	7890		12010	70	30			7.0	21.0		2.1	
74	11	16	9:30 AM	11	3470		13260	53	25							
74	11	17	9:30 AM	11	5000	3600	10390	70	92			7.0	21.0	500	1.7	1.75
74	11	18	9:30 AM	11	5290		12110	60								
74	11	19	9:30 AM	11	4700		10070	60	20			7.1	22.0		1.7	
74	11	20	9:30 AM	11	5000	3570	9750	60								
74	11	21	9:30 AM	11	3520		9420	60	24			7.1	20.0	175	1.0	7.64
74	11	22	9:30 AM	11	4930		16030	58								
74	11	23	9:30 AM	11			2170	15				7.0	23.0		1.0	
74	11	24	9:30 AM	11	6160		21540	50	19							
74	11	25	9:30 AM	11	6770		24200	50								
74	11	26	9:30 AM	11	5970		16340	50	18			7.1	20.0		2.2	
74	11	27	9:30 AM	11	6430	4380	10270	50								
74	11	28	9:30 AM	11	5690		20470	50	14			7.1	23.5	360	1.4	1.93
74	11	29	9:30 AM	11	6130		24500	55	26			7.2	20.0		1.0	
74	11	30	9:30 AM	11	5380	3770	17330	50								
74	11	31	9:30 AM	11	5240		19230	50	22			6.8	19.5	270	1.0	1.34
74	11	32	9:30 AM	11	5730		16710	50								
74	11	33	9:30 AM	11			11040	50								
74	11	34	9:30 AM	11	5610		13620	50				7.0	7.5		1.0	
74	11	35	9:30 AM	11	5330		10410	50	106			7.0	5.5		1.0	
74	11	36	9:30 AM	11	4210		13750	50								
74	11	37	9:30 AM	11	3830		14500	50								
74	11	38	9:30 AM	11	4630	7340	11120	50	112			7.2	5.0	190	1.0	1.30
74	11	39	9:30 AM	11	4160		14420	50	92			7.2	6.0		1.0	
74	11	40	9:30 AM	11	5510		14410	50								
74	11	41	9:30 AM	11	6310	4420	14410	50				7.2	6.0		1.0	
74	11	42	9:30 AM	11	5350		1870	50								
74	11	43	9:30 AM	11	6350		6450	50	100			7.0	6.5		1.0	
74	11	44	9:30 AM	11	3460	3780	2490	50								
74	11	45	9:30 AM	11	4100		3930	50	114			7.2	6.5	350	1.0	1.04
74	11	46	9:30 AM	11	4720		8470	50								
74	11	47	9:30 AM	11	5110	3710	12580	50	88			7.2	6.5		1.0	
74	11	48	9:30 AM	11	5110		13220	50								
74	11	49	9:30 AM	11			11000	50	94			7.1	7.0		1.0	1.74

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3-N	HACH	PH	TEMP	MIN SET	DO	OUR
74	10	10	PM	B1	4310		3060	500				6.9				
74	11	10	AM	B1	5610			500								
74	11	10	AM	B1				350	12							
74	12	10	AM	B1				350	34							
74	13	10	AM	B1	6390		11620					7.2	20.6		2.9	
74	14	10	AM	B1	5330		19110						20.5		2.9	
74	15	10	AM	B1	4650											
74	16	10	AM	B1	5540		13250	900	26			7.3	20.5		2.8	
74	17	10	AM	B1	4770		14580	350					20.5		3.1	
74	18	10	AM	B1	4810		16790	350					20.5		3.1	
74	19	10	AM	B1	3950	2670	113820	415	416			2.1	20.5	180	5.2	10.61
74	20	10	AM	B1	3160		9550	425					20.5		1.7	
74	21	10	AM	B1	3990		16530	475	22							
74	22	10	AM	B1				490								
74	23	10	AM	B1	5110		15350	300								
74	24	10	PM	B1	5170		17370	330	46			7.2	24.0		5.7	
74	25	10	AM	B1				330	25				26.0			
74	26	10	AM	B1				330								
74	27	10	AM	B1	4610		18160	430								
74	28	10	AM	B1			19770	430	25			7.1	25.5		2.7	
74	29	10	AM	B1	4620		8940	330								
74	30	10	AM	B1	4360		8110	330	30			7.5	25.5	350	2.3	13.06
74	31	10	AM	B1	4280		18150	330					25.0		2.1	
74	32	10	AM	B1	4570		18360	330					25.0			
74	33	10	AM	B1	3950		13300	330	59			7.4	25.0	295	2.1	15.50
74	34	10	AM	B1	5280	278		330	28			7.3	25.0		3.1	
74	35	10	AM	B1				330								
74	36	10	AM	B1	5220		14370	330				7.0	25.0		4.2	
74	37	10	AM	B1	4840		14350	330	22				25.0			
74	38	10	AM	B1	4480		11890	330								
74	39	10	AM	B1	4230		14350	330	28			7.4	25.0	130	4.7	19.17
74	40	10	AM	B1	3930		11700	330								
74	41	10	AM	B1	3310		14060	330	30			7.2	25.0		2.8	
74	42	10	AM	B1	3500		13380	330								
74	43	10	AM	B1	2710		13780	330	16							
74	44	10	AM	B1	2710		13780	330								
74	45	10	AM	B1	3370		13780	330								
74	46	10	AM	B1	3370		13780	330								
74	47	10	AM	B1	3370		13780	330								
74	48	10	AM	B1	3370		13780	330								
74	49	10	AM	B1	3370		13780	330								
74	50	10	AM	B1	3370		13780	330								
74	51	10	AM	B1	3370		13780	330								
74	52	10	AM	B1	3370		13780	330								
74	53	10	AM	B1	3370		13780	330								
74	54	10	AM	B1	3370		13780	330								
74	55	10	AM	B1	3370		13780	330								
74	56	10	AM	B1	3370		13780	330								

ERROR OF VSS WASS TAKEN, THEREFORE THE VSS VALUE
 WAS CENT
 PER
 7.1

DUE TO OPERASH
 WAS BASED
 SHOWN

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	NH3N HACH	NH3N	PH	TEMP	MIN SET	DO	CUP
74	00	11	PM	B1	2790			56					7.3	22.0	30	2.3	
74	07	11	AM	B1	3720			77						25.0		2.3	
74	08	11	AM	B1			16330	770	35					25.0		2.0	
74	09	11	AM	B1			4640	70	40					25.0		4.5	
74	10	11	AM	B1											100		
74	11	11	PM	B1	5100	2210	19590	35	24				7.6	25.0		5.7	
74	12	11	PM	B1	3850		17510	20	24				7.6	25.0		3.1	
74	01	11	PM	B1	2130		5270	33	24				7.6	24.5		0.3	
74	02	11	PM	B1			3750	33									
74	03	11	PM	B1	2390		15540	33									
74	04	11	PM	B1	2020	1800	12570	25	11				7.6	25.0	120	4.7	1.59
74	05	11	PM	B1	2640		12570	25					7.6	25.0		2.3	
74	06	11	PM	B1	2020		15230	40									
74	07	11	PM	B1				55									
74	08	11	PM	B1	3860		19370	83	44				7.3	12.5		7.9	
74	09	11	PM	B1			15980	30									
74	10	11	PM	B1	2430		3540	30	28				7.6	19.0		8.3	
74	11	11	PM	B1			16040	30									
74	12	11	PM	B1	3060		3340	30	12				7.6	10.0		6.0	
74	01	11	PM	B1			14000	30									
74	02	11	PM	B1	3330		17500	30	16				7.5	10.0		7.4	
74	03	11	PM	B1			17500	30									
74	04	11	PM	B1	2960	2060	17250	30	26				7.5	13.0	170	5.0	4.95
74	05	11	PM	B1	2840		4290	30									
74	06	11	PM	B1	3020		17350	35	58								
74	07	11	PM	B1	2400		9360	43	23								
74	08	11	PM	B1	3170		16750	43	32				7.5	11.0	120	8.3	4.21
74	09	11	PM	B1	2130												
74	10	11	PM	B1			15560	5	22				7.5	12.0		3.3	
74	11	11	PM	B1	2820	1980	15520	19	52								
74	12	11	PM	B1	3290		4180	13					7.5	10.0	195	5.7	4.32
74	01	11	PM	B1			16300	15									
74	02	11	PM	B1			15710	15									
74	03	11	PM	B1	2490		13610	19									
74	04	11	PM	B1	3050		12460	15	15				7.2				
74	05	11	PM	B1			16010	30	60								
74	06	11	PM	B1	5110		12340	30	18								
74	07	11	PM	B1			15750	35									
74	08	11	PM	B1				5									
74	09	11	PM	B1				5									
74	10	11	PM	B1				5									
74	11	11	PM	B1				5									
74	12	11	PM	B1				5									
74	01	11	PM	B1				5									
74	02	11	PM	B1				5									
74	03	11	PM	B1				5									
74	04	11	PM	B1				5									
74	05	11	PM	B1				5									
74	06	11	PM	B1				5									
74	07	11	PM	B1				5									
74	08	11	PM	B1				5									
74	09	11	PM	B1				5									
74	10	11	PM	B1				5									
74	11	11	PM	B1				5									
74	12	11	PM	B1				5									

3.8
3.0
5.3

13.5
11.0
10.0
10.5

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	NH3N HACH	NO3N	PH	TEMP	MIN	DO	CUR
74	07	12	12	AM	01	3550		14300	33	15			7.2	4.5		4.7	
74	08	12	12	AM	01	2040		8610	30	21							
74	09	12	12	PM	01			8710	45								
74	10	12	12	AM	01	2190		11590	35	43			7.4	4.5		3.7	
74	11	12	12	AM	01	2030		8310	30	36			7.4	4.5		3.7	
74	12	12	12	AM	01	1930		5630	30	66			6.6	5.0		4.7	
74	13	12	12	AM	01	1830		5790	44	44			7.5	4.5		3.7	
74	14	12	12	AM	01	2590			33								
74	15	12	12	AM	01	2960		14900	33	22			10.5	10.5		6.5	
74	16	12	12	AM	01			2810	30								
74	17	12	12	PM	01	3160		3970	40	22			7.5	9.5		6.5	
74	18	12	12	PM	01	2390		6940	40	22			7.6	10.0		6.5	
74	19	12	12	PM	01	4040		6310	40	15			7.5	11.0		4.7	
74	20	12	12	PM	01	3720		14840	30	14			7.5	10.0		3.7	
74	21	12	12	PM	01			13640	30								
74	22	12	12	PM	01	3640		10350	30	48			7.4				
74	23	12	12	PM	01			3310	38	38							
74	24	12	12	PM	01	4150			30	21							
75	01	01	01	AM	01	3030		2300	30	29			7.0	17.0		1.4	
75	02	01	01	AM	01	3340		32600	30				7.3	14.0		5.4	
75	03	01	01	AM	01	3030		308400	30	17			6.9	14.5		3.9	
75	04	01	01	AM	01	2730		15100	30	8							
75	05	01	01	AM	01	1460		120100	30	15							
75	06	01	01	AM	01	1690		121100	30	15							
75	07	01	01	AM	01	3900		15800	30	31			7.1	8.5		6.9	
75	08	01	01	AM	01	2500		22000	30	38			7.2	8.0		2.7	
75	09	01	01	AM	01	2850		22000	30	38			7.1	9.0		2.7	
75	10	01	01	AM	01	3120		3120	30	33			7.3	9.5		2.2	
75	11	01	01	AM	01	7500		3500	30	5							
75	12	01	01	AM	01	2800	1910	2280	35	17							
75	13	01	01	AM	01	2090			30								
75	14	01	01	AM	01	2010			30								
75	15	01	01	AM	01	2180			30								
75	16	01	01	AM	01	2430			30								
75	17	01	01	AM	01	2230			30								

DO IN 01 INCREASED BUT NOT CHECKED AFTER

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	HACH	NH ₃ N	NO ₃ N	EFFLUENT	PH	TEMP	SET	MIN	30	DC	CUR
77	29	01	01	00	BI	2360	140	2360	140	6								9.5				
77	01	01	01	00	BI	2210																
77	02	01	01	00	BI	2210																
77	03	01	01	00	BI	2210																
77	04	01	01	00	BI	2210																
77	05	01	01	00	BI	2210																
77	06	01	01	00	BI	2210																
77	07	01	01	00	BI	2210																
77	08	01	01	00	BI	2210																
77	09	01	01	00	BI	2210																
77	10	01	01	00	BI	2210																
77	11	01	01	00	BI	2210																
77	12	01	01	00	BI	2210																
77	13	01	01	00	BI	2210																
77	14	01	01	00	BI	2210																
77	15	01	01	00	BI	2210																
77	16	01	01	00	BI	2210																
77	17	01	01	00	BI	2210																
77	18	01	01	00	BI	2210																
77	19	01	01	00	BI	2210																
77	20	01	01	00	BI	2210																
77	21	01	01	00	BI	2210																
77	22	01	01	00	BI	2210																
77	23	01	01	00	BI	2210																
77	24	01	01	00	BI	2210																
77	25	01	01	00	BI	2210																
77	26	01	01	00	BI	2210																
77	27	01	01	00	BI	2210																
77	28	01	01	00	BI	2210																
77	29	01	01	00	BI	2210																
77	30	01	01	00	BI	2210																
77	31	01	01	00	BI	2210																

Vertical text on the far right edge of the page, possibly a page number or reference.

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N HACH	PH	TEMP	30 MIN SET	DO	OUR
75	18	02	AM	B1	3780		3780	96	34	7.0	8.5		6.5		
75	19	02	AM	B1	3520		3370	48	28	7.2	8.5	230	6.0		
75	20	02	AM	B1	3520	2530	3520	102	54	5.9	8.5		5.8		4.45
75	21	02	AM	B1	3520		3060	96	36		8.5		4.5		
75	22	02	AM	B1	3620		5230	35							
75	23	02	AM	B1	3490		4950	35							
75	24	02	AM	B1	3470		3490	40	23		16.0		4.5		
75	25	02	AM	B1	3470		9520	32	24		14.7		4.5		
75	26	02	AM	B1	3180		11680	27							
75	27	02	AM	B1	2970		11650	32	26		15.0		5.8		
75	28	02	AM	B1	2050		13730	27	33		15.0		6.9		
75	29	02	AM	B1	880		1930	6	17						
75	30	02	AM	B1	2330	1440	2720	35					50	6.5	5.53
75	31	02	AM	B1	1510		2330	240	24					1.8	
75	01	03	AM	B1	1020		1510	240	19					5.5	
75	02	03	AM	B1	920	640	1020	300	19					4.9	
75	03	03	AM	B1	740		920	260	18					5.5	
75	04	03	AM	B1	1090	690	870	250	19	24.0				4.9	
75	05	03	AM	B1	1230	690	1105	250	19					5.5	
75	06	03	AM	B1	1030	690	1070	260	36					5.5	
75	07	03	AM	B1	1170	730	1010	270	44					5.5	
75	08	03	AM	B1	1050	660	990	270	28					4.9	
75	09	03	AM	B1	1910		910	286	40					4.1	
75	10	03	AM	B1	1690	1280	7780	286	25					4.7	
75	11	03	AM	B1	1460		1110	300	123	27.0				2.7	
75	12	03	AM	B1	1100		5140	2560	123					4.6	
75	13	03	AM	B1	1270	1270	1280	260	36	35.0				5.9	
75	14	03	AM	B1	1420	950	3020	300	78					3.6	
75	15	03	AM	B1	1040	500	4700	1723	60					6.3	
75	16	03	AM	B1	1320	870	3380	43	26	23.0				4.6	
75	17	03	AM	B1	1130	1020	4900	505	55					5.1	
75	18	03	AM	B1	1130		7230	505	28					5.4	
75	19	03	AM	B1	6130		6130	6130	28	24.5				4.1	

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N HACH	PH	TEMP	MIN SET	DC	OUR
75	17	4	1964	1000	B1	1150	1180	4920	78	41		7.3	11.5		6.3	
75	18	4	1964	1600	B1	1450	1160	7000	89	206		7.6	12.0		6.3	
75	19	4	1964	1830	B1	1600	820			228		7.1	12.05		7.0	
75	20	4	1964	1930	B1	1400				224	166	7.1	14.0		7.7	
75	22	4	1964	1300	B1	1060	1420	6660	78	303		7.0	10.5		7.7	
75	22	4	1964	1345	B1	1870				238		7.5	10.5		2.5	
75	22	4	1964	1630	B1	1270	970	6000	68	233		7.4	13.5		6.7	
75	22	4	1964	1600	B1	11080	1540	5300	93	235		7.4	12.0		6.4	
75	22	4	1964	1900	B1	21850	860	4030	73	228		7.4	11.5		4.5	
75	22	4	1964	1600	B1	1240				42		7.3	11.0		5.8	
75	22	4	1964	1900	B1	1150	1250	5550		42		7.3	11.0		6.2	
75	22	4	1964	10AM	B1	1080			108							
75	22	4	1964	AM	B1	360			360							
75	22	4	1964	AM	B1	280			280							
75	22	4	1964	AM	B1	300			300							
75	22	4	1964	AM 300	B1	1269			1269							
75	23	5	1964	00AM	B1	2280	560	5370		30		7.3	24.0		2.6	
75	23	5	1964	00AM	B1	3370		3370		19		7.3	24.5		1.2	
75	23	5	1964	00AM	B1	3370		5310								
75	23	5	1964	00AM	B1	1260			1260							
75	23	5	1964	00AM	B1	116			116							
75	23	5	1964	00AM	B1	1770	560	4380		37		7.7	24.5	60	6.6	17.14
75	23	5	1964	00AM	B1	240			240	30		7.5	25.9		2.0	
75	23	5	1964	00AM	B1	3350			3350	30		7.5	25.9		2.0	
75	23	5	1964	00AM	B1	2340			2340							
75	23	5	1964	00AM	B1	2500	1577			39		7.5	25.0		4.7	15.21
75	23	5	1964	00AM	B1	2210			2210	22		7.5	25.0		1.6	
75	23	5	1964	00AM	B1	2140			2140	22		7.5	25.0		3.1	
75	23	5	1964	00AM	B1	8000			8000	22		7.4	25.0		6.0	
75	23	5	1964	00AM	B1	6110			6110	14						
75	23	5	1964	00AM	B1	1360			1360							

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	ICAL	WASTE	SS	ALK	EFFLUENT	RETURN SLUDGE	PH	TEMP	30 MIN SET	DO	OUR
75	12	05	12	AM	81	1400	1158	5660	66		22			5300	7.5	12.0		5.5	
75	12	05	12	PM	81	1270					9			3860		11.7		3.2	
75	13	05	13	AM	81	890					48			4040		12.2		3.2	
75	13	05	13	PM	81	780	630	3950	83		17				7.5	12.5		4.8	
75	14	05	14	AM	81	1190	850	4130	100		45			3940	7.5	11.9		4.6	
75	14	05	14	PM	81	1270					74			4310		12.0		5.4	
75	15	05	15	AM	81	2130	1540	6240	137		27				7.4	12.0		4.2	
75	15	05	15	PM	81	1670		4610	72		58			7550		12.0		2.3	
75	16	05	16	AM	81	1400	1000				44			4930					
75	17	05	17	AM	81														
75	18	05	18	AM	81														
75	19	05	19	AM	81														
75	20	05	20	AM	81														
75	21	05	21	AM	81														
75	22	05	22	AM	81	910		3800			37								
75	23	05	23	AM	81	630	550	2120	72		29				7.7	11.6		6.0	
75	24	05	24	AM	81	740					34							6.3	
75	25	05	25	AM	81	710	540	2510	70		39			4560	7.6	11.7		3.8	
75	26	05	26	AM	81						40								
75	27	05	27	AM	81														
75	28	05	28	AM	81	520	600	2950	48		59			5700		13.0		4.3	
75	29	05	29	AM	81	630					47			1560		12.0		7.2	
75	30	05	30	AM	81	700	1040	5620	84		46			3570	7.6	12.0			
75	31	05	31	AM	81	1300					46			2720	7.2	11.7		4.9	
75	01	06	01	AM	81	1290	890	4210	126		42			1110				3.4	
75	02	06	02	AM	81	1150					54			7620		12.0		1.3	
75	03	06	03	AM	81	510	410	2220	47		22			6590					
75	04	06	04	AM	81	520					41								
75	05	06	05	AM	81	910	470	3020	54		49			2750	7.7	12.4		5.7	
75	06	06	06	AM	81	590					35			3420	7.7	12.3		5.4	
75	07	06	07	AM	81	680	615	2340	54		52			4750				1.1	
75	08	06	08	AM	81	770					45			3330	7.8	11.8		9.2	
75	09	06	09	AM	81	830					43			2340		11.9		9.2	
75	10	06	10	AM	81									2480					

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL	SS	ALK	NH3N	HACH	PH	TEMP	MIN	SET	DO	OUR
74	05	02	0900	B2	3170		5060		74				7.2	6.0			5.7	
74	06	02	AM	B2	3455				324				7.5	9.8			5.7	
74	07	02	AM	B2	4070		3850	8	334				7.5	11.0			4.6	
74	08	02	AM	B2	3850				335				7.5	10.5			4.6	
74	09	02	AM	B2	3950				44				7.5	11.0			3.7	
74	10	02	AM	B2	3560				19				7.5	10.8			4.1	
74	11	02	AM	B2	4240	3070			29	145			7.5	9.8	205		4.4	5.88
74	12	02	AM	B2	3220	2560			38				7.2	11.0			3.4	
74	13	02	AM	B2	3310	4360			44				7.8	10.0	210		6.1	5.31
74	14	02	AM	B2	43070		4434	14	24				7.4	10.5			3.5	
74	15	02	AM	B2	4690				58				7.0	10.8			3.6	
74	16	02	AM	B2	4240		9310	22	20				7.0	11.0			3.6	
74	17	02	AM	B2	4890		8750	15	9				7.4	10.0			3.9	
74	18	02	AM	B2	4080		7340	47	70				7.4	10.0			3.9	
74	19	02	AM	B2	3860	2790			35	141			7.8	8.5			5.0	
74	20	02	AM	B2	3970				25				7.4	9.5			4.0	
74	21	02	AM	B2	5750		8430	25	23	100			7.4	11.3			2.6	
74	22	02	AM	B2	460	3200			30				7.4	11.0	300		3.0	4.55
74	23	02	AM	B2	5150		8010	10	30				7.1	15.3			2.7	
74	24	02	AM	B2	5210		3410	25	38					15.3			3.5	
74	25	02	AM	B2	3870		5430	16	12					15.5			4.2	
74	26	02	AM	B2	2870		5560	13	51				7.5	15.0			3.9	
74	27	02	AM	B2	2090	1360	4440		47	76			7.3	15.0	130		3.2	
74	28	02	AM	B2	2460				57				7.5	15.3			3.2	
74	29	02	AM	B2	2300	760			42				7.4	16.0			6.1	114.40
74	30	02	AM	B2	4350				39	80			7.5	15.0	80		6.5	131.69
74	31	02	AM	B2	1130				61				7.6	15.0	75		6.2	
74	01	03	AM	B2	1130				47				7.6	15.0			8.6	
74	02	03	AM	B2	1420	1288			96				7.8	6.0			4.0	
74	03	03	AM	B2	1230				96				8.2	5.0			10.9	
74	04	03	AM	B2	1360	1260			83				7.8	6.0			10.3	
74	05	03	AM	B2	1370				45				7.8	10.8			10.8	
74	06	03	AM	B2	1850				75				7.8	5.5			10.1	
74	07	03	AM	B2	1800				75				7.8	5.5			10.1	
74	08	03	AM	B2	13420				138				7.8	10.5			4.4	
74	09	03	AM	B2	13420				138				7.8	10.5			4.4	
74	10	03	AM	B2	13420				138				7.8	10.5			4.4	
74	11	03	AM	B2	13420				138				7.8	10.5			4.4	
74	12	03	AM	B2	13420				138				7.8	10.5			4.4	
74	13	03	AM	B2	13420				138				7.8	10.5			4.4	
74	14	03	AM	B2	13420				138				7.8	10.5			4.4	
74	15	03	AM	B2	13420				138				7.8	10.5			4.4	
74	16	03	AM	B2	13420				138				7.8	10.5			4.4	
74	17	03	AM	B2	13420				138				7.8	10.5			4.4	
74	18	03	AM	B2	13420				138				7.8	10.5			4.4	
74	19	03	AM	B2	13420				138				7.8	10.5			4.4	
74	20	03	AM	B2	13420				138				7.8	10.5			4.4	
74	21	03	AM	B2	13420				138				7.8	10.5			4.4	
74	22	03	AM	B2	13420				138				7.8	10.5			4.4	
74	23	03	AM	B2	13420				138				7.8	10.5			4.4	
74	24	03	AM	B2	13420				138				7.8	10.5			4.4	
74	25	03	AM	B2	13420				138				7.8	10.5			4.4	
74	26	03	AM	B2	13420				138				7.8	10.5			4.4	
74	27	03	AM	B2	13420				138				7.8	10.5			4.4	
74	28	03	AM	B2	13420				138				7.8	10.5			4.4	
74	29	03	AM	B2	13420				138				7.8	10.5			4.4	
74	30	03	AM	B2	13420				138				7.8	10.5			4.4	
74	31	03	AM	B2	13420				138				7.8	10.5			4.4	

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	HACH	NO3N	PH	TEMP	MIN SET	DO	OUR
74	14	03	AM	02	2100				54		14	5	7.6	9.8		4.6	
74	15	03	AM	02	1540	1380			88				7.6	9.8		5.2	3.30
74	16	03	AM	02	1970				88				7.8	10.0		9.3	
74	17	03	AM	02	30380				80				7.6	10.5		8.2	
74	18	03	AM	02	33680				75				7.5	9.0		7.7	
74	19	03	AM	02	26890				27				7.4	10.8		5.1	
74	20	03	AM	02				10	33		9	6	7.4	10.5		6.7	
74	21	03	AM	02	6090			20	51				7.3	12.0		6.3	
74	22	03	AM	02				10	64					10.8		6.5	
74	23	03	AM	02	4580			10	70					12.0		7.0	
74	24	03	AM	02	22370	1820		110	86	131			7.6	10.0	100	8.1	7.34
74	25	03	AM	02	6150				38				7.4	13.3		4.4	0
74	26	03	AM	02				20	43				7.4	12.3		5.5	
74	27	03	AM	02	1470				46				7.5	6.5		3.7	
74	28	03	AM	02	3090				65					11.3		6.5	4.88
74	29	03	AM	02	2590				27				7.5	10.5	195	3.8	
74	30	03	AM	02	2570	2040		3	20	120			7.5	10.5		6.5	
74	31	03	AM	02	2460				147				7.9	10.5	190	6.1	6.20
74	01	04	AM	02	2460	2190		6	22	161			7.5	10.5		6.5	
74	02	04	AM	02	2280				39					11.1		6.2	
74	03	04	AM	02	2670			63	28				7.6	13.0		5.5	
74	04	04	AM	02	2400				16								
74	05	04	AM	02	2370	1930											
74	06	04	AM	02	2350	1610											
74	07	04	AM	02	2350												
74	08	04	AM	02	2350	1970			36	70			7.7	15.0	180	3.6	4.46
74	09	04	AM	02	2350												
74	10	04	AM	02	2310	1920											
74	11	04	AM	02	22450												
74	12	04	AM	02	22450												
74	13	04	AM	02	22450				24	41			7.5	15.3	175	3.5	2.84
74	14	04	AM	02	22450												
74	15	04	AM	02	22450				29	15							
74	16	04	AM	02	22450			2									
74	17	04	AM	02	22450												
74	18	04	AM	02	22450												
74	19	04	AM	02	22450												
74	20	04	AM	02	22450												
74	21	04	AM	02	22450												
74	22	04	AM	02	22450												
74	23	04	AM	02	22450												
74	24	04	AM	02	22450												
74	25	04	AM	02	22450												
74	26	04	AM	02	22450												
74	27	04	AM	02	22450												
74	28	04	AM	02	22450												
74	29	04	AM	02	22450												
74	30	04	AM	02	22450												
74	31	04	AM	02	22450												

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	NH3N HACH	NO3N HACH	PH	TEMP	MIN	DO	OUR
74	14	04	AM	B2	3380				42							
74	15	04	AM	B2	3710				32							
74	16	04	PM	B2	3920	2470	5810	40	93			7.4	6.3	280	2.4	2.94
74	17	04	PM	B2	3480		6740	3				7.3	6.5		4.4	
74	18	04	PM	B2	5470		5990	5				7.5	5.3	325	8.6	4.11
74	19	04	AM	B2	4280	2940			13	87						
74	20	04	PM	B2	4520		6640	10				7.3	12.0		1.9	
74	21	04	AM	B2	4190		6470	6	18							
74	22	04	AM	B2	5170		11650	16	20							
74	23	04	PM	B2	4030	2840			10	66		7.3	11.8	320	2.1	6.05
74	24	04	PM	B2	5100				16			7.3	11.0		3.5	
74	25	04	PM	B2	4710		3460	9	12	99		7.3	11.0	275	7.9	3.44
74	26	04	PM	B2	3760	2540	4350	10	8			7.4	20.8		5.7	
74	27	04	PM	B2	3270				21							
74	28	04	AM	B2	3060	2440	8290									
74	29	04	AM	B2	4030	2840	7210									
74	30	04	AM	B2	4310		7380									
74	31	04	AM	B2	3590		7080									
74	01	05	AM	B2	3490		6330		23	47		7.2	20.8	290	4.3	3.93
74	02	05	AM	B2	3770	2550	6960									
74	03	05	AM	B2	4010		7540									
74	04	05	AM	B2	4490	2910										
74	05	05	AM	B2	3160		4380									
74	06	05	AM	B2	3160		7210									
74	07	05	AM	B2	4760	3030	6760		34	15		6.4	20.5	280	2.8	5.84
74	08	05	AM	B2			7310		47				15.0		4.9	
74	09	05	AM	B2												
74	10	05	AM	B2	3410											
74	11	05	AM	B2	3550											
74	12	05	AM	B2	3840		4330	5	25			7.3	15.0		7.3	
74	13	05	AM	B2	2620		4900	5	25			7.3	15.0		6.4	
74	14	05	AM	B2	2630				37			7.2	15.0		4.7	
74	15	05	AM	B2	2850		6830	0	36							
74	16	05	AM	B2	2910			2	31			7.5	15.8		6.2	

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	NO3M HACH	PH	TEMP	MIN SET	DO	OUR
74	14	05	AM	B2	4450	3100	6620	5	33	140	7.4	15.3	185	4.6	12.22
74	15	05	AM	B2	4170				26		7.2	15.5		3.1	
74	15	05	AM	B2	4150				20	97	7.3	14.5	175	8.5	
74	16	05	AM	B2	3130	2140	4620	2	30		7.4	10.0		6.1	
74	17	05	AM	B2	3100			0	61						
74	18	05	AM	B2	4600				29		7.3	6.3		6.8	
74	19	05	AM	B2	3660				31	188	7.4	6.5	170	8.5	2.62
74	20	05	AM	B2	3990		4710	5	28		7.5	5.5		6.9	
74	21	05	AM	B2	2860	2020			46	191	7.3	6.5	230	3.9	3.53
74	22	05	AM	B2	3550				33		7.2	7.0		4.4	
74	22	05	AM	B2	5090	3570	6460	2	46		7.3	6.5	230	3.9	3.53
74	23	05	AM	B2	4270		6940	9	33		7.2	7.0		4.4	
74	24	05	AM	B2	5290			10	8		7.3	7.8		5.5	
74	25	05	AM	B2	6060				13						
74	26	05	AM	B2	5440										
74	27	05	AM	B2			9790	21							
74	27	05	AM	B2			18480	16							
74	28	05	AM	B2				10							
74	29	05	AM	B2			8200	20							
74	30	05	AM	B2			8070	20							
74	31	05	AM	B2				20							
74	31	05	AM	B2			7260	5							
74	01	06	AM	B2			7970	10							
74	02	06	AM	B2			7830	10							
74	03	06	AM	B2											
74	03	06	AM	B2			14280	10							
74	04	06	AM	B2			8470	8							
74	05	06	AM	B2			9890	10							
74	06	06	AM	B2			8010	10							
74	06	06	AM	B2											
74	07	06	AM	B2			6050	15							
74	08	06	AM	B2			9290	10							
74	09	06	AM	B2			8760	20							
74	11	06	AM	B2											
74	11	06	AM	B2			5460	10							
74	12	06	AM	B2											

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	NO3H	HACH	PH	TEMP	MIN SET	DO	OUR
74	13	06	PM	B2	4630	3740	9030	27					6.7	10.0	30	2.6	
74	14	06	AM	B2	4650								6.8	10.0		3.5	
74	15	06	PM	B2				13									
74	16	06	PM	B2				13									
74	17	06	AM	B2	3640		5570	8	10				7.0	10.5		6.5	
74	18	06	PM	B2	4090		6650	8	12				6.9	10.0	265	5.5	5.18
74	19	06	AM	B2	3390	2840	6360	15	10				5.8	10.5		3.1	
74	20	06	PM	B2	3610		6370	15	18				6.9	9.0	240	3.5	4.72
74	21	06	PM	B2	2140	2370	5410	8	6	33			6.8	10.5		3.7	
74	22	06	AM	B2	2960		4680	9	30				7.2	17.0		6.6	
74	23	06	PM	B2	2840				22				7.2	18.5		4.7	
74	24	06	AM	B2	2650				58								
74	25	06	PM	B2	2580		13390	3	21	9			6.4	15.5	220	6.6	3.12
74	26	06	AM	B2	2160	1910			25				5.3	17.0		5.8	
74	27	06	PM	B2	3330				24	24			7.0	16.0	190	1.9	5.96
74	28	06	AM	B2	2550	2180											
74	29	06	PM	B2	2210				16				5.6	15.0	180	3.8	2.34
74	30	06	AM	B2	2200				27	18			5.7	16.0		4.3	
74	01	07	PM	B2	2390	1283			33								
74	02	07	AM	B2	2350		5020	6	16				6.1	15.0		5.0	
74	03	07	PM	B2	2840				24								
74	04	07	AM	B2	2740		3910	12	24				5.7	15.0	200	5.6	5.71
74	05	07	PM	B2	2840		4110	12	30	13			7.0	15.0		1.0	
74	06	07	AM	B2	2660												
74	07	07	PM	B2	3570		5910	12	20				7.0	8.0		2.8	
74	08	07	AM	B2	4060			15	11				7.0	10.0		6.1	
74	09	07	PM	B2	4290	3190	7620	6	27	71			7.0	9.0		3.1	4.09
74	10	07	AM	B2	4360		6910	15	25				7.1	8.0		1.4	
74	11	07	PM	B2	5090		8740	6	17	70			7.0	8.0	400	3.0	4.56
74	12	07	AM	B2	5810	3840											
74	13	07	PM	B2	4940		9200	18	20								
74	14	07	AM	B2	4310		8220	24	17								
74	15	07	PM	B2	4560		8010	21	17				7.0	15.5		3.6	

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT NH3N HACH	NO3N	PH	TEMP	30 MIN SET	DO	OUR
74	21	08	AM	B2	3190		5790	6	29	6.9	11.5	6.8	14.0	240	2.1	
74	22	08	AM	B2	3160	2340	5870	6	40	6.8	14.0	6.8	14.0	240	4.4	11.10
74	23	08	AM	B2	3110								13.5		1.2	
74	24	08	AM	B2	3480					6.5	13.0	6.5	13.0		3.9	
74	25	08	AM	B2	3010			6	56				6.5			
74	26	08	AM	B2	9750			25	32	7.1	10.0	7.1	10.0		4.4	
74	27	08	AM	B2	5190		8030	56	148	7.3	8.0	7.3	8.0		7.6	
74	28	08	AM	B2	5940				9							
74	28	08	AM	B2	5410	3580	9900	20	28	7.2	8.5	7.2	8.5	745	3.4	
74	29	08	AM	B2	5490		9530	20	82							
74	30	08	AM	B2	5940		9430	20		7.0	9.5	7.0	9.5		3.3	
74	31	08	AM	B2	5160			16								
74	01	09	AM	B2	4750		9110	6	37	7.2	25.0	7.2	25.0		6.5	
74	02	09	AM	B2	4910		6420	9	18							
74	03	09	AM	B2	4100		7810	15	19	7.2	25.0	7.2	25.0		4.8	
74	04	09	AM	B2	4190		7330	10	18	7.3	25.0	7.3	25.0		3.9	
74	05	09	AM	B2	3730	2430	7390	10	37	6.7	24.5	6.7	24.5	370	2.3	17.17
74	06	09	AM	B2	3820				8						0.5	
74	07	09	AM	B2	3680				20							
74	08	09	AM	B2	3560		7090	6								
74	09	09	AM	B2	3440				13	7.0	25.0	7.0	25.0	400	4.6	51.96
74	10	09	AM	B2	3540	2370	6800	10	25	6.5	25.0	6.5	25.0		0.7	
74	11	09	AM	B2	3530		6790	3	20	5.8	25.0	5.8	25.0		3.4	
74	11	09	AM	B2	3980	2720	6790	3	26	6.0	25.5	6.0	25.5	625	4.1	17.22
74	12	09	AM	B2	4380		7780	10							0.5	
74	13	09	AM	B2	5470			20	19	6.8	24.5	6.8	24.5		0.2	
74	14	09	AM	B2	5770				21	7.0	21.0	7.0	21.0		4.2	
74	15	09	AM	B2	5290	3360	15180	22	8	6.9	21.0	6.9	21.0	570	0.9	10.68
74	16	09	AM	B2	4740		10110	40	41							
74	17	09	AM	B2	5480		9260	25	11	6.8	20.5	6.8	20.5		2.1	
74	18	09	AM	B2	8920		8920	20	14	6.5	20.0	6.5	20.0	710	1.4	13.25
74	19	09	AM	B2	4600	3040	8650	10	26						0.3	
74	20	09	AM	B2	4910											
74	21	09	AM	B2	4600											
74	22	09	AM	B2	4630		7490	10	17	6.8	21.0	6.8	21.0		0.3	
74	22	09	AM	B2				25								

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	NH3N HACH	NO3N	PH	TEMP	MIN SET	DC	OUR
74	23	09	AM	B2	3650		8960	10	15								
74	24	09	AM	B2	5560		6450	12	30				5.0	20.0		4.7	
74	25	09	AM	B2	3120	2190	7190	18	30	6			5.6	22.0	290	5.9	13.10
74	26	09	AM	B2	2580		6250	16	33				6.3	20.0		4.2	
74	27	08	AM	B2	2720	2020		95	44	8			5.4	20.0	220	5.5	5.58
74	28	09	AM	B2	2290												
74	30	10	AM	B2	2430				32				7.0	8.5		5.0	
74	01	10	AM	B2	33780		6330	8	53				6.9	7.5		5.0	
74	02	10	AM	B2	3710				84	64			7.2	7.5		6.0	8.84
74	03	10	AM	B2	4230	3360			21				7.0	8.0	725	1.0	
74	04	10	AM	B2	5140												
74	05	10	AM	B2	5140	3600	7300	10					7.0	7.5		3.8	
74	06	10	AM	B2	5820	4950	8640						6.9	8.5		8.0	
74	07	10	AM	B2	5430		9730	12	21								
74	08	10	AM	B2	5150	4660	9050	20	18	50			5.9	8.5	910	8.1	6.01
74	09	10	AM	B2	5070		8540	10	23				6.6	8.5		6.3	
74	10	10	AM	B2	4940	3570	8770		21	52			6.7	8.5		6.7	3.10
74	11	10	AM	B2	5110		8000	16					6.8			3.0	
74	12	10	AM	B2	4530												
74	13	10	AM	B2	4430		7970	20	11								
74	14	10	AM	B2	4370				15				7.1	20.0		7.3	
74	15	10	AM	B2	4530		8550	20	42							6.1	
74	16	10	AM	B2	3980		7150	8	20							2.5	
74	17	10	AM	B2	4870				28				7.1	20.0		4.1	
74	18	10	AM	B2	3440	2350	6200	10	34	51			6.6	20.0	310	2.8	20.27
74	19	10	AM	B2	3220		5630	15								1.3	
74	20	10	AM	B2	3260		5750	17	44								
74	21	10	AM	B2													
74	22	10	AM	B2	5350		9840	15	54				7.3	24.0		6.1	

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	NH3N	NO3N	HACH	PH	TEMP	30 MIN SET	DO	OUR
74	23	10	AM	B2	5000		10630	15	11		7.0	26.0		7.0	26.0	4.0	4.0	
74	23	10	AM	B2	5570		10540	20	14		6.9	25.0		6.9	25.0		4.5	
74	24	10	AM	B2	6140	4020	12020	18	19	60	7.3	25.5	695	7.3	25.5		0.5	17.51
74	25	10	AM	B2	5286		11890	120									2.3	
74	25	10	AM	B2	5350		11070	20									3.3	
74	26	10	AM	B2	6310		11060	20	17	65	7.2	25.0		7.2	25.0		3.3	
74	27	10	AM	B2	5320	3590	13020	15	32		6.9	25.0	750	6.9	25.0		2.1	12.89
74	28	10	AM	B2	4780		10470	15	32		7.0	25.0		7.0	25.0		1.8	
74	29	10	AM	B2	3430			15			7.0	25.0		7.0	25.0		6.0	
74	30	10	AM	B2	2900			10	22		6.9	25.0		6.9	25.0		6.0	
74	31	10	AM	B2	3330				18									
74	01	11	AM	B2	2500				21									
74	02	11	AM	B2	2370				25	61	7.2	25.0	140	7.2	25.0		3.8	31.03
74	03	11	AM	B2	1950		5940	4	32		7.2	25.0		7.2	25.0		7.6	
74	04	11	AM	B2	11950		6860	5										
74	05	11	AM	B2	1660				29	12	7.0	24.0	120	7.0	24.0		4.3	
74	06	11	AM	B2	1660				45		6.7	25.0		6.7	25.0		5.0	
74	07	11	AM	B2	2210				10		7.0	25.0		7.0	25.0		6.5	
74	08	11	AM	B2	2330				16		7.0	25.0		7.0	25.0		4.0	
74	09	11	AM	B2	2330				28	37	7.0	25.0	170	7.0	25.0		3.4	26.41
74	10	11	AM	B2	2130				29		6.7	24.0		6.7	24.0		3.0	
74	11	11	AM	B2	1720				36	3	6.7	24.0	130	6.7	24.0		5.0	
74	12	11	AM	B2	1660				10		7.0	25.0		7.0	25.0		9.0	
74	13	11	AM	B2	1680				19		7.0	25.0		7.0	25.0		7.7	
74	14	11	AM	B2	12850				4		7.4	10.5		7.4	10.5		7.7	
74	15	11	AM	B2	3100				5	41	7.0	11.0	640	7.0	11.0		7.0	31.38
74	16	11	AM	B2	2800				17		7.1	11.0		7.1	11.0		1.0	
74	17	11	AM	B2	2790				18								1.8	
74	18	11	AM	B2	2850				24	17	6.8	11.0	290	6.8	11.0		4.0	11.07
74	19	11	AM	B2	2690				24	17								
74	20	11	AM	B2	2710				24	17								

ERROR NO VSS WAS TAKEN, THEREFORE THE VSS VALUE
 VSS OF 70 PER CENT

ERROR NO VSS WAS TAKEN, THEREFORE THE VSS VALUE
 VSS OF 65 PER CENT

OPERATOR A
 DUE TO OPERATOR A
 WAS BASED ON

OPERATOR A
 DUE TO OPERATOR A
 WAS BASED ON

REACTOR OPERATING RESULTS

YEAR	DAY	MON	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	NH3	HACH	PH	TEMP	MIN SET	DO	OUR
74	25	11	AM	B2	2710				31	9			6.7	12.0		5.0	
74	26	11	AM	B2	2890				32				7.0	11.0	330	5.1	9.57
74	27	11	AM	B2	3140											2.3	
74	27	11	AM	B2	3190											2.1	
74	29	11	AM	B2				10									
74	30	11	AM	B2	2810		6960	10									
74	01	12	AM	B2	3000		4640	7					7.3				
74	02	12	AM	B2	3000				34								
74	03	12	AM	B2	2980		4490	12									
74	03	12	AM	B2					39								
74	04	12	AM	B2										14.5		4.7	
74	05	12	AM	B2										12.5		3.2	
74	06	12	AM	B2										11.0		4.3	
74	06	12	AM	B2	2840		2840	20	37								
74	07	12	AM	B2													
74	08	12	AM	B2	2810		2400	15	15								
74	09	12	AM	B2	2870		4350	10	40				7.2	6.0		6.3	
74	09	12	AM	B2	2670		4770	10	33				7.4	6.5		4.9	
74	10	12	AM	B2	2950		4990	10	29				7.2	7.0		4.0	
74	11	12	AM	B2	3400		5610	7	12				7.3	6.5		4.1	
74	11	12	AM	B2	3640		5940	10									
74	11	12	AM	B2	3640		5940	10	26					12.0		5.6	
74	13	12	AM	B2	3800		5930	7	29								
74	15	12	AM	B2	3580		6640	10	20				7.1	11.0		6.9	
74	17	12	AM	B2	3060				20				7.5	10.0		2.7	
74	17	12	AM	B2	3270				20				7.4	11.5		5.7	
74	18	12	AM	B2	3240				20				7.3	11.5		4.4	
74	19	12	AM	B2			5580	5	25								
74	20	12	AM	B2	3180		5410	5	24				7.2				
74	20	12	AM	B2	3200												
74	21	12	AM	B2	4380												
74	21	12	AM	B2	3660												
74	21	12	AM	B2													
74	21	12	AM	B2	2740		2660	25	64	7.3			7.2	18.0		5.9	
74	21	12	AM	B2	2400		2740	60	35				15.5	5		7.3	
74	21	12	AM	B2	1820		2400	60	40				7.2	15.5		7.1	
74	21	12	AM	B2			1820	15	52								

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS	ALK	NH3N	HACH	NO3N	PH	TEMP	30 MIN SET	DO	QJR
75	24	03	03	0900	B2	1270	930			24	82	0.5			7.7	13.5		7.4	
75	25	03	03	0900	B2	1230	930			49	88				7.8	14.5		8.7	
75	26	03	03	1030	B2	1240	1030			51		6.8			7.5	14.5		9.0	
75	27	03	03	1030	B2	1120	720			38		0.5			7.7	14.5		8.8	
75	28	03	03	1030	B2	1107	720			36	43	86			7.7	15.0		8.8	
75	29	03	03	1030	B2	1150	830			46					7.5	15.5		7.9	
75	30	03	03	1030	B2	1119	830			42					7.6	15.5		7.7	
75	31	03	03	1030	B2	1138									7.7	15.5		8.0	
75	01	04	04	0900	B2	1156	1170			36	83	0.5			7.7	15.5		8.0	
75	02	04	04	0900	B2	1146	950			47	98	24.0			7.7	15.5		7.7	
75	03	04	04	0900	B2	1127	1060			53		0.1			7.5	15.5		8.0	
75	04	04	04	0900	B2	1119	1060			51	81	0.1			7.5	15.5		8.0	
75	05	04	04	0900	B2	1129	1020			54	79	0.5			7.5	15.5		8.0	
75	06	04	04	0900	B2	1114	890			56					7.6	15.5		8.0	
75	07	04	04	0900	B2	1135	990			3					7.3	15.5		8.0	
75	08	04	04	0900	B2	1155	990			47					7.5	15.5		8.0	
75	09	04	04	0900	B2	1126	1000			52					7.5	15.5		8.0	
75	10	04	04	0900	B2	1117	1000			34					7.2	15.5		8.0	
75	11	04	04	0900	B2	1134	890			37					7.2	15.5		8.0	
75	12	04	04	0900	B2	1155	990			47					7.3	15.5		8.0	
75	13	04	04	0900	B2	1126	990			52					7.5	15.5		8.0	
75	14	04	04	0900	B2	1117	1000			34					7.2	15.5		8.0	
75	15	04	04	0900	B2	1134	1320			47	153				7.2	15.5		8.0	
75	16	04	04	0900	B2	1155	1750			47	178				7.2	15.5		8.0	
75	17	04	04	0900	B2	1126	1000			34	157				7.3	15.5		8.0	
75	18	04	04	0900	B2	1134	1750			47	151				7.2	15.5		8.0	
75	19	04	04	0900	B2	1155	1000			52	143				7.3	15.5		8.0	
75	20	04	04	0900	B2	1126	1070	6090	58	44					7.0	15.5		8.0	
75	21	04	04	0900	B2	1134	1130			47	159				7.2	15.5		8.0	
75	22	04	04	0900	B2	1155	1250			52	170				7.0	15.5		8.0	
75	23	04	04	0900	B2	1126	970			34	141				7.1	15.5		8.0	
75	24	04	04	0900	B2	1134	970			47	165				7.3	15.5		8.0	
75	25	04	04	0900	B2	1155	1100			52					7.1	15.5		8.0	
75	26	04	04	0900	B2	1126	870			34	81				7.3	15.5		8.0	
75	27	04	04	0900	B2	1134				47					7.0	24.0	75	4.6	4.56
75	28	04	04	0900	B2	1155				52					7.3	25.0		4.1	

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT		PH	TEMP	MIN SET	DO	OUR
											NH3N	NO3N					
75	06	05	05	AM	02	850				54			5.8	23.5		3.5	4.5
75	07	05	05	AM	02	1850	638			71			6.7	25.0		4.3	5.88
75	08	05	05	AM	02	850							7.2	24.3		3.3	5.6
75	09	05	05	AM	02	600								26.0		5.6	
75	11	05	05	AM	02	1360				40				13.6			

REACTOR OPERATING RESULTS

YEAR	DAY	MON	DATE	TIME	REACTOR TYPE	MLVSS MG/L	VSS PER-CENT	WASTE CONC 1350	IGAL WASTE	EFFLUENT		RETURN SLUDGE	PH	TEMP	MIN SET	DO	OUR
										SS	ALK						
75	1	2	05	11	82	1360				22	163		7.4	13.8	30	6.8	
75	2	3	05	11	82	1340				46	212	2790	7.4	13.5		4.8	
75	3	4	05	11	82	1120	865			40		2730		13.2		4.5	
75	4	5	05	11	82	1190				74		1920		13.0		5.7	
75	5	6	05	11	82	1140	860			59		2210		12.8		5.3	
75	6	7	05	11	82	1290	950			74	208	1980		12.8		5.3	
75	7	8	05	11	82	1330	1020			66	222	3350		12.6		5.3	
75	8	9	05	11	82	1430				90		2270					
75	9	0	05	11	82	1200				76		1560					
75	10	1	05	11	82	1200	935			64	123	3640		13.4		8.6	
75	11	2	05	11	82	1230				74							
75	12	3	05	11	82	1200	935			40	135	2430		13.3		7.1	
75	13	4	05	11	82	1360	1160			40	152	1890		13.5		6.3	
75	14	5	05	11	82	1520	1250			40	152	2090		13.0		7.1	
75	15	6	05	11	82	1420	1180			56	143	3800		13.0		6.4	
75	16	7	05	11	82	1540	1230			74		1960		13.0		4.1	
75	17	8	05	11	82	1520				20		2640					
75	18	9	05	11	82	1440	1280			46	161	2800		0.9		5.4	
75	19	0	05	11	82	1520	1230			43	179	2960		2.0		5.4	
75	20	1	05	11	82	1510	1280			40	179	2510		3.0		5.4	
75	21	2	05	11	82	1540	1270			42	101	4470		2.0		4.4	
75	22	3	05	11	82	1440	1190			44	63	3030		0.0		8.3	
75	23	4	05	11	82	1450	930			30		3380		0.0		8.3	
75	24	5	05	11	82	1500				42		1610		0.7		8.3	
75	25	6	05	11	82	1600				40		1610		0.0		8.3	
75	26	7	05	11	82	1560				40		1610		0.0		8.3	
75	27	8	05	11	82	1440				38		1610		0.8		8.3	
75	28	9	05	11	82	1500				34		1610		0.0		8.3	
75	29	0	05	11	82	2270	1720			36	18	1610		0.0	185	7.3	18.85
75	30	1	05	11	82	2280				34				0.0		7.6	
75	31	2	05	11	82	2480				45				0.0		7.6	
75	32	3	05	11	82	2280		1370	45	44				0.0		7.6	
75	33	4	05	11	82	2410								0.0		7.0	
75	34	5	05	11	82	2390				44				0.0		10.1	
75	35	6	05	11	82	1570		2680	104	38				0.0		8.6	
75	36	7	05	11	82	1630			94					0.0		8.7	
75	37	8	05	11	82	1510			94					0.0		8.7	

REACTOR OPERATING RESULTS

YEAR	DAY	DATE	TIME	REACTOR	MLSS	VSS	WASTE CONC	IGAL WASTE	SS ALK	EFFLUENT	RETURN SLUDGE	PH	TEMP	30 MIN SET	DO	CUR
75	30	08	AM	01	1340							7.4	21.0	6.1	4.1	
75	30	08	AM	03	1090							7.6	21.0	8.7	3.8	
75	30	08	AM	05	1090		2350	109	36			7.7	21.0	7.5	3.8	
75	01	07	AM	07	1130							7.3	21.0	7.3	3.3	
75	01	07	AM	09	1100		1160	109	26	142	1490	7.4	21.0	7.4	3.3	
75	01	07	PM	01	1130								21.0	6.4	4.4	
75	01	07	PM	03	1070								21.0	6.4	4.3	
75	01	07	PM	05	1110	870			42				21.0	6.4	4.3	
75	02	07	AM	01	1150	890						7.4	21.0	6.4	4.3	
75	02	07	AM	03	1080	860	1400	59	36	194	2090	7.5	21.0	6.4	4.3	
75	02	07	PM	01	1290								21.0	6.5	4.1	
75	02	07	PM	03	1320								21.0	6.5	4.1	
75	02	07	PM	05	1140	1160	2270	51	52		2170		21.0	3.0	7.4	
75	03	07	AM	01	1300	1140						7.9	21.8	3.0	5.5	
75	03	07	AM	03	1300	1260	1600	114	36	153	2670	7.6	21.0	3.0	5.5	
75	03	07	PM	01	1360								21.0	3.0	5.5	
75	03	07	PM	03	1370								21.0	3.0	5.5	
75	03	07	PM	05	1120				34		1910		21.0	3.0	5.5	
75	04	07	AM	01	1300								21.0	3.0	5.5	
75	04	07	AM	03	1300								21.0	3.0	5.5	
75	04	07	AM	05	1300								21.0	3.0	5.5	
75	04	07	AM	07	1300								21.0	3.0	5.5	
75	04	07	AM	09	1300								21.0	3.0	5.5	
75	04	07	AM	11	1300								21.0	3.0	5.5	
75	04	07	AM	13	1300								21.0	3.0	5.5	
75	04	07	AM	15	1300								21.0	3.0	5.5	
75	04	07	AM	17	1300								21.0	3.0	5.5	
75	04	07	AM	19	1300								21.0	3.0	5.5	
75	04	07	AM	21	1300								21.0	3.0	5.5	
75	04	07	AM	23	1300								21.0	3.0	5.5	
75	04	07	AM	25	1300								21.0	3.0	5.5	
75	04	07	AM	27	1300								21.0	3.0	5.5	
75	04	07	AM	29	1300								21.0	3.0	5.5	
75	04	07	AM	31	1300								21.0	3.0	5.5	

ANALYSES

YEAR	DAY	MON	DEF	SAMPLE SIGHATION	UNFILTERED	FILTERED	COD	BOD	FEC	NH3N	NO2N	NO3N	TKN
74	30	04	RF	C5	201	56.1	114	22	53	47.4	0.0	0.0	47.4
74	01	05	RF	C6	37	48.5	152	30	25	43.4	0.0	0.0	43.4
74	01	05	RF	C7	76	33.8	54	15	15	36.4	0.0	0.0	36.4
74	03	05	RF	C8	17	55.1	78	12	85	42.6	0.0	0.0	42.6
74	01	05	RF	C9	12	67.1	54	12	85	42.6	0.0	0.0	42.6
74	01	05	RF	C10	28	77.7	75	12	85	42.6	0.0	0.0	42.6
74	01	05	RF	C11	28	62.7	66	12	85	42.6	0.0	0.0	42.6
74	01	05	RF	C12	29	85.7	66	12	85	42.6	0.0	0.0	42.6
74	02	05	RF	C13	47	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C14	57	85.4	66	12	85	42.6	0.0	0.0	42.6
74	02	05	RF	C15	88	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C16	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C17	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C18	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C19	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C20	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C21	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C22	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C23	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C24	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C25	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C26	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C27	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C28	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C29	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C30	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C31	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C32	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C33	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C34	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C35	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C36	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C37	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C38	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C39	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C40	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C41	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C42	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C43	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C44	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C45	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C46	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C47	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C48	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C49	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C50	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C51	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C52	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C53	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C54	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C55	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C56	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C57	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C58	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C59	97	44.0	113	10	00	0.0	0.0	0.0	0.0
74	02	05	RF	C60	97	44.0	113	10	00	0.0	0.0	0.0	0.0

REPRESENTS TO SAMPLER TO SAMPLER ERROR

OTHER 12 SAMPLES MISSING

9-2307

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED	FILTERED	COD	BOD	NO2N	NO3N	TKN
75	29	01	RF-0600	264	18.6	62	2.3	0.4	0.8	14.4
75	29	01	RF-0700	160	15.0	63	2.1	0.4	1.3	12.0
75	29	01	RF-0800	178	17.0	55	2.8	0.4	1.9	12.4
75	29	01	RF-0900	150	19.0	55	2.8	0.5	1.9	14.7
75	29	01	RF-1000	228	17.0	55	2.7	0.3	0.5	15.7
75	29	01	RF-1100	384	22.0	55	2.7	0.3	0.5	20.6
75	29	01	RF-1200	370	20.0	79	2.7	0.4	0.6	18.7
75	29	01	RF-1300	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-1400	334	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-1500	372	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-1600	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-1700	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-1800	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-1900	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2000	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2100	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2200	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2300	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2400	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2500	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2600	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2700	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2800	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-2900	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3000	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3100	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3200	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3300	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3400	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3500	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3600	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3700	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3800	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-3900	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4000	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4100	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4200	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4300	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4400	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4500	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4600	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4700	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4800	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-4900	352	20.0	183	2.7	0.5	0.6	22.7
75	29	01	RF-5000	352	20.0	183	2.7	0.5	0.6	22.7

192
198
194
115
114

NO NITRATE
ANALYTICAL
ERRORS
368
368
384
414

RESULT
706
578

80
20

SAMPLE MISSED DUE TO AUTO

NO NITRATE
ANALYTICAL
ERRORS
368
368
384
414

RESULT
706
578

80
20

SAMPLE MISSED DUE TO AUTO

NO NITRATE
ANALYTICAL
ERRORS
368
368
384
414

RESULT
706
578

80
20

SAMPLE MISSED DUE TO AUTO

ANALYSES

YEAR	DAY	MON.	SAMPLE MON.	DESIGNATION	COD	BOD	UNFILTERED	IKN	COD	300	FOC	NH3N	FILTERED	N02N	N03N	TKN
75	1	3	03	PF-0300					67			1.9	1.4	0.0	0.0	4.5
75	1	3	03	PF-0600					58			1.7	1.3	0.0	0.0	2.4
75	1	3	03	PF-1200					37			1.6	1.1	0.0	0.0	5.5
75	1	3	03	PF-1500					72			1.8	1.0	0.0	0.0	5.5
75	1	3	03	PF-1800					28			1.7	1.0	0.0	0.0	5.5
75	1	3	03	PF-2100					48			1.1	0.5	0.0	0.0	5.5
75	1	3	03	PF-2300					43			1.5	0.8	0.0	0.0	5.5
75	1	3	03	PF-0900					57			2.6	0.0	0.0	0.0	0.0
75	1	3	03	PF-1100					27			2.2	0.0	0.0	0.0	0.0
75	1	3	03	PF-1300					92			2.2	0.0	0.0	0.0	0.0
75	1	3	03	PF-1500					62			1.6	0.0	0.0	0.0	0.0
75	1	3	03	PF-1700					57			1.4	0.0	0.0	0.0	0.0
75	1	3	03	PF-1900					7			1.1	0.0	0.0	0.0	0.0
75	1	3	03	PF-2100					62			1.5	0.0	0.0	0.0	0.0
75	1	3	03	PF-2300					7			1.2	0.0	0.0	0.0	0.0
75	1	3	03	PF-0100					157			1.2	0.0	0.0	0.0	0.0
75	1	3	03	PF-0300					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-0500					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-0700					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-0900					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1100					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1300					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1500					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1700					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1900					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-2100					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-2300					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-0100					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-0300					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-0500					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-0700					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-0900					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1100					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1300					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1500					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1700					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-1900					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-2100					22			1.3	0.0	0.0	0.0	0.0
75	1	3	03	PF-2300					22			1.3	0.0	0.0	0.0	0.0

ANALYSES

YEAR	DAY	MON	SAMPLE SIGNALION	UNFILTERED COD	YKN	COD	FILT: REF FOC NH3N	N02N	N03N	TKN
75	19	3	RF-0300	130	10.3	2	17.2	0.4	3.0	13.6
75	19	3	RF-0600	178	11.2	17	8.3	0.5	0.6	9.4
75	22	3	RF-0000	124	14.1	4	9.3	0.7	1.2	8.1
75	22	3	RF-0100	224	14.1	4	12.6	0.2	1.7	11.4
75	22	3	RF-0200	246	23.0	7	15.7	0.7	1.3	15.7
75	22	3	RF-0300			4	15.7	0.8	1.7	15.7
75	22	3	RF-0400			5	9.7	0.8	1.7	9.7
75	22	3	RF-0500			5	7.7	0.8	1.7	7.7
75	22	3	RF-0600			5	7.7	0.8	1.7	7.7
75	22	3	RF-0700			5	7.7	0.8	1.7	7.7
75	22	3	RF-0800			5	7.7	0.8	1.7	7.7
75	22	3	RF-0900			5	7.7	0.8	1.7	7.7
75	22	3	RF-1000			5	7.7	0.8	1.7	7.7
75	22	3	RF-1100			5	7.7	0.8	1.7	7.7
75	22	3	RF-1200			5	7.7	0.8	1.7	7.7
75	22	3	RF-1300			5	7.7	0.8	1.7	7.7
75	22	3	RF-1400			5	7.7	0.8	1.7	7.7
75	22	3	RF-1500			5	7.7	0.8	1.7	7.7
75	22	3	RF-1600			5	7.7	0.8	1.7	7.7
75	22	3	RF-1700			5	7.7	0.8	1.7	7.7
75	22	3	RF-1800			5	7.7	0.8	1.7	7.7
75	22	3	RF-1900			5	7.7	0.8	1.7	7.7
75	22	3	RF-2000			5	7.7	0.8	1.7	7.7
75	22	3	RF-2100			5	7.7	0.8	1.7	7.7
75	22	3	RF-2200			5	7.7	0.8	1.7	7.7
75	22	3	RF-2300			5	7.7	0.8	1.7	7.7
75	22	3	RF-2400			5	7.7	0.8	1.7	7.7
75	22	3	RF-2500			5	7.7	0.8	1.7	7.7
75	22	3	RF-2600			5	7.7	0.8	1.7	7.7
75	22	3	RF-2700			5	7.7	0.8	1.7	7.7
75	22	3	RF-2800			5	7.7	0.8	1.7	7.7
75	22	3	RF-2900			5	7.7	0.8	1.7	7.7
75	22	3	RF-3000			5	7.7	0.8	1.7	7.7
75	22	3	RF-3100			5	7.7	0.8	1.7	7.7
75	22	3	RF-3200			5	7.7	0.8	1.7	7.7
75	22	3	RF-3300			5	7.7	0.8	1.7	7.7
75	22	3	RF-3400			5	7.7	0.8	1.7	7.7
75	22	3	RF-3500			5	7.7	0.8	1.7	7.7
75	22	3	RF-3600			5	7.7	0.8	1.7	7.7
75	22	3	RF-3700			5	7.7	0.8	1.7	7.7
75	22	3	RF-3800			5	7.7	0.8	1.7	7.7
75	22	3	RF-3900			5	7.7	0.8	1.7	7.7
75	22	3	RF-4000			5	7.7	0.8	1.7	7.7
75	22	3	RF-4100			5	7.7	0.8	1.7	7.7
75	22	3	RF-4200			5	7.7	0.8	1.7	7.7
75	22	3	RF-4300			5	7.7	0.8	1.7	7.7
75	22	3	RF-4400			5	7.7	0.8	1.7	7.7
75	22	3	RF-4500			5	7.7	0.8	1.7	7.7
75	22	3	RF-4600			5	7.7	0.8	1.7	7.7
75	22	3	RF-4700			5	7.7	0.8	1.7	7.7
75	22	3	RF-4800			5	7.7	0.8	1.7	7.7
75	22	3	RF-4900			5	7.7	0.8	1.7	7.7
75	22	3	RF-5000			5	7.7	0.8	1.7	7.7
75	22	3	RF-5100			5	7.7	0.8	1.7	7.7
75	22	3	RF-5200			5	7.7	0.8	1.7	7.7
75	22	3	RF-5300			5	7.7	0.8	1.7	7.7
75	22	3	RF-5400			5	7.7	0.8	1.7	7.7
75	22	3	RF-5500			5	7.7	0.8	1.7	7.7
75	22	3	RF-5600			5	7.7	0.8	1.7	7.7
75	22	3	RF-5700			5	7.7	0.8	1.7	7.7
75	22	3	RF-5800			5	7.7	0.8	1.7	7.7
75	22	3	RF-5900			5	7.7	0.8	1.7	7.7
75	22	3	RF-6000			5	7.7	0.8	1.7	7.7
75	22	3	RF-6100			5	7.7	0.8	1.7	7.7
75	22	3	RF-6200			5	7.7	0.8	1.7	7.7
75	22	3	RF-6300			5	7.7	0.8	1.7	7.7
75	22	3	RF-6400			5	7.7	0.8	1.7	7.7
75	22	3	RF-6500			5	7.7	0.8	1.7	7.7
75	22	3	RF-6600			5	7.7	0.8	1.7	7.7
75	22	3	RF-6700			5	7.7	0.8	1.7	7.7
75	22	3	RF-6800			5	7.7	0.8	1.7	7.7
75	22	3	RF-6900			5	7.7	0.8	1.7	7.7
75	22	3	RF-7000			5	7.7	0.8	1.7	7.7
75	22	3	RF-7100			5	7.7	0.8	1.7	7.7
75	22	3	RF-7200			5	7.7	0.8	1.7	7.7
75	22	3	RF-7300			5	7.7	0.8	1.7	7.7
75	22	3	RF-7400			5	7.7	0.8	1.7	7.7
75	22	3	RF-7500			5	7.7	0.8	1.7	7.7
75	22	3	RF-7600			5	7.7	0.8	1.7	7.7
75	22	3	RF-7700			5	7.7	0.8	1.7	7.7
75	22	3	RF-7800			5	7.7	0.8	1.7	7.7
75	22	3	RF-7900			5	7.7	0.8	1.7	7.7
75	22	3	RF-8000			5	7.7	0.8	1.7	7.7
75	22	3	RF-8100			5	7.7	0.8	1.7	7.7
75	22	3	RF-8200			5	7.7	0.8	1.7	7.7
75	22	3	RF-8300			5	7.7	0.8	1.7	7.7
75	22	3	RF-8400			5	7.7	0.8	1.7	7.7
75	22	3	RF-8500			5	7.7	0.8	1.7	7.7
75	22	3	RF-8600			5	7.7	0.8	1.7	7.7
75	22	3	RF-8700			5	7.7	0.8	1.7	7.7
75	22	3	RF-8800			5	7.7	0.8	1.7	7.7
75	22	3	RF-8900			5	7.7	0.8	1.7	7.7
75	22	3	RF-9000			5	7.7	0.8	1.7	7.7
75	22	3	RF-9100			5	7.7	0.8	1.7	7.7
75	22	3	RF-9200			5	7.7	0.8	1.7	7.7
75	22	3	RF-9300			5	7.7	0.8	1.7	7.7
75	22	3	RF-9400			5	7.7	0.8	1.7	7.7
75	22	3	RF-9500			5	7.7	0.8	1.7	7.7
75	22	3	RF-9600			5	7.7	0.8	1.7	7.7
75	22	3	RF-9700			5	7.7	0.8	1.7	7.7
75	22	3	RF-9800			5	7.7	0.8	1.7	7.7
75	22	3	RF-9900			5	7.7	0.8	1.7	7.7
75	22	3	RF-0000			5	7.7	0.8	1.7	7.7

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD	BOO	UNFILTERED	TKN	COD	BOO	FOC	FILTERED	NH3N	NO2N	NO3N	TKN
77	16	04	RF-0100	130	8	76	76	148	8	76	76	12	00	00	12
77	16	04	RF-0300	138	8	65	65	137	8	65	65	11	00	00	11
77	16	04	RF-0500	128	8	55	55	122	8	55	55	10	00	00	10
77	16	04	RF-0700	128	8	59	59	128	8	59	59	10	00	00	10
77	16	04	RF-1100	130	8	37	37	116	8	37	37	7	00	00	7
77	16	04	RF-1300	130	8	35	35	115	8	35	35	7	00	00	7
77	16	04	RF-1500	130	8	27	27	102	8	27	27	5	00	00	5
77	16	04	RF-1700	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-2100	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-2300	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-2500	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-2700	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-2900	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-3100	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-3300	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-3500	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-3700	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-3900	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-4100	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-4300	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-4500	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-4700	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-4900	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-5100	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-5300	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-5500	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-5700	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-5900	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-6100	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-6300	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-6500	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-6700	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-6900	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-7100	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-7300	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-7500	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-7700	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-7900	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-8100	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-8300	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-8500	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-8700	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-8900	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-9100	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-9300	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-9500	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-9700	130	8	20	20	92	8	20	20	4	00	00	4
77	16	04	RF-9900	130	8	20	20	92	8	20	20	4	00	00	4

ANALYSES

YEAR	DAY	MON	SAMPLE	SIGNATION	COD	BOD	FOG	NR3N	NR2N	NR3N	IKN	IKN
75	20	04	RF	-0800	67	4	53	4	0	0	8	8
75	20	04	RF	-1100	57	4	4	1	0	0	2	2
75	20	04	RF	-1700	7	4	4	2	0	0	6	6
75	20	04	RF	-2300	7	4	4	2	0	0	5	5
75	21	00	RF	-0500	8	5	5	2	0	0	10	10
75	21	00	RF	-0800	9	4	4	6	0	0	8	8
75	21	00	RF	-1100	2	4	4	1	0	0	1	1
75	21	00	RF	-1500	5	4	4	3	0	0	6	6
75	21	00	RF	-2300	5	4	4	3	0	0	7	7
75	22	00	RF	-0200	5	4	4	3	0	0	2	2
75	22	00	RF	-0500	4	4	4	2	0	0	2	2
75	22	00	RF	-0800	4	4	4	2	0	0	2	2
75	22	00	RF	-1100	4	4	4	2	0	0	2	2
75	22	00	RF	-1700	4	4	4	2	0	0	2	2
75	22	00	RF	-2300	4	4	4	2	0	0	2	2
75	23	00	RF	-0200	4	4	4	2	0	0	2	2
75	23	00	RF	-0500	4	4	4	2	0	0	2	2
75	23	00	RF	-0800	4	4	4	2	0	0	2	2
75	23	00	RF	-1100	4	4	4	2	0	0	2	2
75	23	00	RF	-1700	4	4	4	2	0	0	2	2
75	23	00	RF	-2300	4	4	4	2	0	0	2	2
75	24	00	RF	-0200	4	4	4	2	0	0	2	2
75	24	00	RF	-0500	4	4	4	2	0	0	2	2
75	24	00	RF	-0800	4	4	4	2	0	0	2	2
75	24	00	RF	-1100	4	4	4	2	0	0	2	2
75	24	00	RF	-1500	4	4	4	2	0	0	2	2
75	24	00	RF	-2300	4	4	4	2	0	0	2	2
75	25	00	RF	-0200	4	4	4	2	0	0	2	2
75	25	00	RF	-0500	4	4	4	2	0	0	2	2
75	25	00	RF	-0800	4	4	4	2	0	0	2	2
75	25	00	RF	-1100	4	4	4	2	0	0	2	2
75	25	00	RF	-1700	4	4	4	2	0	0	2	2
75	25	00	RF	-2300	4	4	4	2	0	0	2	2
75	26	00	RF	-0200	4	4	4	2	0	0	2	2
75	26	00	RF	-0500	4	4	4	2	0	0	2	2
75	26	00	RF	-0800	4	4	4	2	0	0	2	2
75	26	00	RF	-1100	4	4	4	2	0	0	2	2
75	26	00	RF	-1500	4	4	4	2	0	0	2	2
75	26	00	RF	-2300	4	4	4	2	0	0	2	2
75	27	00	RF	-0200	4	4	4	2	0	0	2	2
75	27	00	RF	-0500	4	4	4	2	0	0	2	2
75	27	00	RF	-0800	4	4	4	2	0	0	2	2
75	27	00	RF	-1100	4	4	4	2	0	0	2	2
75	27	00	RF	-1700	4	4	4	2	0	0	2	2
75	27	00	RF	-2300	4	4	4	2	0	0	2	2
75	28	00	RF	-0200	4	4	4	2	0	0	2	2
75	28	00	RF	-0500	4	4	4	2	0	0	2	2
75	28	00	RF	-0800	4	4	4	2	0	0	2	2
75	28	00	RF	-1100	4	4	4	2	0	0	2	2
75	28	00	RF	-1500	4	4	4	2	0	0	2	2
75	28	00	RF	-2300	4	4	4	2	0	0	2	2
75	29	00	RF	-0200	4	4	4	2	0	0	2	2
75	29	00	RF	-0500	4	4	4	2	0	0	2	2
75	29	00	RF	-0800	4	4	4	2	0	0	2	2
75	29	00	RF	-1100	4	4	4	2	0	0	2	2
75	29	00	RF	-1500	4	4	4	2	0	0	2	2
75	29	00	RF	-2300	4	4	4	2	0	0	2	2
75	30	00	RF	-0200	4	4	4	2	0	0	2	2
75	30	00	RF	-0500	4	4	4	2	0	0	2	2
75	30	00	RF	-0800	4	4	4	2	0	0	2	2
75	30	00	RF	-1100	4	4	4	2	0	0	2	2
75	30	00	RF	-1700	4	4	4	2	0	0	2	2
75	30	00	RF	-2300	4	4	4	2	0	0	2	2
75	31	00	RF	-0200	4	4	4	2	0	0	2	2
75	31	00	RF	-0500	4	4	4	2	0	0	2	2
75	31	00	RF	-0800	4	4	4	2	0	0	2	2
75	31	00	RF	-1100	4	4	4	2	0	0	2	2
75	31	00	RF	-1500	4	4	4	2	0	0	2	2
75	31	00	RF	-2300	4	4	4	2	0	0	2	2

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD	BOD	UNFILTERED TKN	COD	BOD	FILTERED FOC	NH3N	NQ2N	NQ3N	TKN
75	25	04	RF-19CB				53	38	7.2	2.9	1.9		9.8
75	25	04	RF-1100										
75	25	04	RF-11300										
75	25	04	RF-11500										
75	25	04	RF-11700										
75	25	04	RF-11900										
75	25	04	RF-12100										
75	25	04	RF-12300										
75	25	04	RF-12500										
75	25	04	RF-12700										
75	25	04	RF-12900										
75	25	04	RF-13100										
75	25	04	RF-13300										
75	25	04	RF-13500										
75	25	04	RF-13700										
75	25	04	RF-13900										
75	25	04	RF-14100										
75	25	04	RF-14300										
75	25	04	RF-14500										
75	25	04	RF-14700										
75	25	04	RF-14900										
75	25	04	RF-15100										
75	25	04	RF-15300										
75	25	04	RF-15500										
75	25	04	RF-15700										
75	25	04	RF-15900										
75	25	04	RF-16100										
75	25	04	RF-16300										
75	25	04	RF-16500										
75	25	04	RF-16700										
75	25	04	RF-16900										
75	25	04	RF-17100										
75	25	04	RF-17300										
75	25	04	RF-17500										
75	25	04	RF-17700										
75	25	04	RF-17900										
75	25	04	RF-18100										
75	25	04	RF-18300										
75	25	04	RF-18500										
75	25	04	RF-18700										
75	25	04	RF-18900										
75	25	04	RF-19100										
75	25	04	RF-19300										
75	25	04	RF-19500										
75	25	04	RF-19700										
75	25	04	RF-19900										

FOLLOWING ARE THE 2 HR RESULTS FROM 19/4 1100 HRS AS INTERPRETED FROM A CONTINUOUS RECORD DURING THIS PERIOD BASED ON 3 HP SAMPLES

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COO	BOD	UNFILTERED TKN	COD	BOD	FOC	PH	NO2N	NO3N	TKN
75	23	04	RF-0300				58		16	13.5		1.0	16.5
75	23	04	RF-0500				54		15	12.0		1.3	14.5
75	23	04	RF-0900				40		15	18.0		0.5	20.0
75	23	04	RF-1100				36		13	11.0		2.0	13.0
75	05	05	ND OFC						29	5.0		1.4	5.5
75	07	05	REF-0900	344	97	69.7	66	26	27	4.4		1.0	15.3
75	12	05	REF-0900	264	64	59.3	71	18	31	3.8		1.0	25.5
75	15	05	REF-0900	344	114	33.3	71	33	10	10.9		1.3	13.7
75	15	05	REF-0900	344	112	33.4	78	37	34	9.6		0.5	16.7
75	15	05	REF-0900	302	193	25.1	153	39	44	8.8		0.4	20.0
75	15	05	REF-0900	416	108	35.1	153		42	10.8		0.7	15.3
75	15	05	REF-0900				18		45	8.9		0.0	15.3
75	15	05	REF-0900				8		52	7.8		0.0	11.4
75	15	05	REF-0900				13		27	8.2		0.0	11.4
75	15	05	REF-0900				15		25	7.5		0.0	11.4
75	15	05	REF-0900				15		22	6.9		0.0	11.4
75	15	05	REF-0900				15		21	6.2		0.0	11.4
75	15	05	REF-0900				15		19	5.8		0.0	11.4
75	15	05	REF-0900				15		17	5.4		0.0	11.4
75	15	05	REF-0900				15		15	4.9		0.0	11.4
75	15	05	REF-0900				15		13	4.5		0.0	11.4
75	15	05	REF-0900				15		12	4.2		0.0	11.4
75	15	05	REF-0900				15		11	3.8		0.0	11.4
75	15	05	REF-0900				15		10	3.4		0.0	11.4
75	15	05	REF-0900				15		9	3.0		0.0	11.4
75	15	05	REF-0900				15		8	2.6		0.0	11.4
75	15	05	REF-0900				15		7	2.2		0.0	11.4
75	15	05	REF-0900				15		6	1.8		0.0	11.4
75	15	05	REF-0900				15		5	1.4		0.0	11.4
75	15	05	REF-0900				15		4	1.0		0.0	11.4
75	15	05	REF-0900				15		3	0.6		0.0	11.4
75	15	05	REF-0900				15		2	0.2		0.0	11.4
75	15	05	REF-0900				15		1	0.0		0.0	11.4
75	15	05	REF-0900				15		0	0.0		0.0	11.4

INTERPRETED RECORD

336 106
 446 157
 464 163
 558 120

ANALYSES

YEAR	DAY	MON	SAMPLE NO	SIGNATION	COD	BOO	UNFILTERED	TKN	COD	BOO	FOC	FILTERED	NH3N	N02N	N03N	TKN
75	26	0	1	PF-0900	548				229		2	10.2	0.0	3.1	13.9	
75	26	0	2	RF-1200	598				150		1	26.9	0.0	1.7	27.0	
75	26	0	3	RF-1500	135				567		3	22.3	0.0	0.0	25.1	
75	26	0	4	RF-1800	173				338		3	17.7	0.0	0.0	18.7	
75	27	0	1	RF-2100	707				338		3	14.0	0.0	0.0	16.4	
75	27	0	2	RF-0000	486				149		1	19.6	0.0	0.0	14.4	
75	27	0	3	RF-1200	161				785		7	12.3	0.0	0.0	14.9	
75	27	0	4	RF-1500	178				859		8	12.4	0.0	0.0	15.5	
75	27	0	5	RF-1800	125				109		1	12.7	0.0	0.0	12.9	
75	27	0	6	RF-2100	258				778		7	12.2	0.0	0.0	12.1	
75	28	0	1	RF-0000	130				629		6	12.5	0.0	0.0	12.6	
75	28	0	2	RF-0900	170				742		4	18.0	0.0	0.0	11.0	
75	28	0	3	RF-1200	225				782		8	15.0	0.0	0.0	10.7	
75	28	0	4	RF-1500	135				778		7	13.3	0.0	0.0	10.9	
75	28	0	5	RF-1800	110				742		4	12.9	0.0	0.0	11.4	
75	28	0	6	RF-2100	95				693		3	12.5	0.0	0.0	11.7	
75	29	0	1	RF-0000	109				593		5	16.0	0.0	0.0	11.8	
75	29	0	2	RF-0900	66				567		3	12.9	0.0	0.0	11.5	
75	29	0	3	RF-1200	66				593		5	12.6	0.0	0.0	11.1	
75	29	0	4	RF-1500	150				674		6	12.8	0.0	0.0	11.4	
75	29	0	5	RF-1800	111				512		2	10.3	0.0	0.0	11.7	
75	29	0	6	RF-2100	75				427		2	10.3	0.0	0.0	11.4	
75	30	0	1	RF-0000	67				265		2	13.9	0.0	0.0	10.8	
75	30	0	2	RF-0900	67				337		3	14.8	0.0	0.0	10.8	
75	30	0	3	RF-1200	76				447		4	11.1	0.0	0.0	10.2	
75	30	0	4	RF-1500	44				454		4	12.6	0.0	0.0	10.5	
75	30	0	5	RF-1800	44				454		4	11.7	0.0	0.0	10.0	
75	30	0	6	RF-2100	88				337		3	11.8	0.0	0.0	10.0	
75	31	0	1	RF-0000	17				693		6	11.2	0.0	0.0	10.0	
75	31	0	2	RF-0900	57				337		3	11.7	0.0	0.0	10.0	
75	31	0	3	RF-1200	54				337		3	11.2	0.0	0.0	10.0	
75	31	0	4	RF-1500	102				257		2	38.0	0.0	0.0	10.0	
75	31	0	5	RF-1800	102				575		5	46.0	0.0	0.0	10.0	
75	31	0	6	RF-2100	122				560		5	46.0	0.0	0.0	10.0	

39
48
35

26.4
251.3
57.3
40.2

296 102
287 87
162 91
277 106

(INTERPRETED)

ANALYSES

YEAR	DAY	MON	SAMPLE SIGNATION	UNFILTERED COD BOD	TKN	COD	BOD	FOC	FILTERED NH3N	NO2N	NO3N	TKN
75	03	06	RF-2400			97		28	45	0	0	5
75	04	06	RF-0300			51		25	38	0	0	5
75	04	06	RF-0900			40		33	37	0	0	5
75	04	06	RF-1200			33		16	37	0	0	10
75	04	06	RF-1500			58		15	36	0	0	20
75	04	06	RF-2400			79		45	40	0	0	6
75	05	06	RF-0300			47		32	37	0	0	1
75	05	06	RF-0900			44		25	37	0	0	0
75	05	06	RF-1300			44		16	36	0	0	0
75	05	06	RF-1500			44		33	49	0	0	0
75	05	06	RF-2400			48		45	49	0	0	0
75	05	06	RF-0300			52		32	48	0	0	0
75	05	06	RF-0900			62		44	35	0	0	0
75	05	06	RF-1300			28		35	35	0	0	0
75	05	06	RF-1500			67		48	45	0	0	0
75	05	06	RF-2400			18		35	45	0	0	0
75	06	07	RF-0300		59.7	26		35	45	0	0	0
75	06	07	RF-0900		28.0	11		41	28	0	0	0
75	06	07	RF-1300		38.0	63		43	15	0	0	0
75	06	07	RF-1500		27.5	56		24	11	0	0	0
75	06	07	RF-2400			106		42	11	0	0	0
75	06	07	RF-0300			95		38	11	0	0	0
75	06	07	RF-0900			118		46	11	0	0	0
75	06	07	RF-1300			118		37	11	0	0	0
75	06	07	RF-1500			140		22	11	0	0	0
75	06	07	RF-2400			140		22	11	0	0	0
75	06	07	RF-0300			140		22	11	0	0	0
75	06	07	RF-0900			140		22	11	0	0	0
75	06	07	RF-1300			140		22	11	0	0	0
75	06	07	RF-1500			140		22	11	0	0	0
75	06	07	RF-2400			140		22	11	0	0	0
75	06	07	RF-0300			140		22	11	0	0	0
75	06	07	RF-0900			140		22	11	0	0	0
75	06	07	RF-1300			140		22	11	0	0	0
75	06	07	RF-1500			140		22	11	0	0	0
75	06	07	RF-2400			140		22	11	0	0	0

ANALYSES

YEAR	DAY	MON	DES	SAMPLE SIGNATION	COD	BOD	UNFILTERED	KY	COD	200	F0C	NH3N	N02N	H03N	IKN
74	10	04	EA22-C4	EA22-C4	53	7	5.7	27	3	10	4.3	2.9	29.1	5.1	
74	11	04	EA22-C5	EA22-C5	41	6	4.3	25	2	10	4.7	2.6	27.4	4.3	
74	11	04	EA22-C6	EA22-C6	43	6	4.4	33	2	11	2.8	3.7	26.3	4.2	
74	11	04	EA22-C7	EA22-C7	44	5	4.3	29	2	11	2.9	3.1	20.9	4.5	
74	11	04	EA22-C8	EA22-C8	45	5	4.3	29	2	11	2.4	1.9	26.1	3.1	
74	11	04	EA22-C9	EA22-C9	45	6	4.7	29	2	18	3.2	2.6	25.4	4.7	
74	16	04	MLA11-GAM	MLA11-GAM			257.9		36	4	11	3.1	0.5	3.7	3.4
74	16	04	MLA12-GAM	MLA12-GAM	52	11	260.0								
74	18	04	MLA21-GAM	MLA21-GAM	48	6	257.0		32	3	10	10.4	0.3	8.6	10.4
74	18	04	MLA22-GAM	MLA22-GAM			153.0								
74	21	05	MLA11-GAM	MLA11-GAM	50	13	180.8		33	7	10	8.0	1.4	11.3	8.1
74	21	05	MLA21-GAM	MLA21-GAM			209.0								
74	22	05	MLA22-GAM	MLA22-GAM	62	14	110.0		55	6	18	14.3	0.4	2.0	14.3
74	23	05	MLA11-GAM	MLA11-GAM			296.0								
74	23	05	MLA21-GAM	MLA21-GAM	46	6	4.0	27	3	11	3.3	0.5	18.0	3.3	
74	23	05	MLA22-GAM	MLA22-GAM	46	7	4.0	25	4	10	1.0	0.5	15.5	1.3	
74	23	05	EA22-C9	EA22-C9	36	5	4.2	44	4	15	3.6	1.5	19.5	3.6	
74	26	06	EA22-C9	EA22-C9			51.0								
74	26	06	MLA11-GAM	MLA11-GAM	66	7	329.0		37	4	13	3.3	4.5	27.5	3.3
74	26	06	MLA12-GAM	MLA12-GAM	70	8	293.0		51	6	18	8.8	0.3	5.1	8.8
74	26	06	MLA21-GAM	MLA21-GAM			38.0								
74	26	06	MLA22-GAM	MLA22-GAM			4.0								
74	28	06	EA22-C9	EA22-C9	79	7	48.0		34	5	16	7.7	0.2	4.7	7.7
74	28	06	MLA11-GAM	MLA11-GAM			310.0								
74	28	06	MLA12-GAM	MLA12-GAM			280.0								
74	28	06	MLA21-GAM	MLA21-GAM	38	9	9.0		34	7	14	6.7	1.7	11.3	8.0
74	28	06	MLA22-GAM	MLA22-GAM			302.9								
74	28	06	EA22-C9	EA22-C9	33	6	22.9		25	5	10	7.0	0.5	28.5	7.6
74	30	06	MLA11-GAM	MLA11-GAM			312.0								
74	30	06	MLA12-GAM	MLA12-GAM	60	9	15.0		16	4	10	1.6	0.4	25.1	3.9
74	30	06	MLA21-GAM	MLA21-GAM			335.0								
74	30	06	MLA22-GAM	MLA22-GAM			378.0								
74	08	08	EA22-C9	EA22-C9	108	13	269.0		16	5	12	3.5	0.2	33.8	3.9
74	08	08	MLA11-GAM	MLA11-GAM			269.0								
74	08	08	MLA12-GAM	MLA12-GAM			269.0								
74	08	08	MLA21-GAM	MLA21-GAM			269.0								
74	08	08	MLA22-GAM	MLA22-GAM			269.0								
74	09	08	EA22-C9	EA22-C9	44	58	14.1		32	4	12	12.0	0.8	30.3	1.8
74	09	08	MLA11-GAM	MLA11-GAM			14.1		31	4	12	12.0	0.8	24.7	14.8

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED COD	BOD	TKN	COD	BOD	FOC	PH3N	NO2N	NO3N	TKN
74	17	09	MLA1-GAM	306.0									
74	17	09	MLA2-GAM	302.5	45	5	37	53	12	10.7	0.5	31.0	11.9
74	19	09	MLA1-GAM	112.0									
74	19	09	MLA2-GAM	280.0	43	5	34	4	15	7.9	0.8	28.7	9.0
74	22	09	MLA1-GPM	191.0									
74	22	09	MLA2-GPM	203.0	51	7	30	4	15	11.0	0.4	30.6	12.0
74	22	09	MLA1-GPM	155.6									
74	22	09	MLA2-GPM	304.0	94	10	52	4	17	18.0	1.5	23.5	18.3
74	18	10	MLA1-GAM	278.0									
74	18	10	MLA2-GAM	210.0	55	7	38	4	20	5.6	0.5	30.5	6.0
74	22	09	MLA1-GAM	338.0									
74	22	09	MLA2-GAM	378.0	33	6	33	3	13	1.0	0.0	39.0	2.1
74	06	09	MLA1-GAM	423.5									
74	06	09	MLA2-GAM	315.0	58	7	33	3	13	5.6	0.5	46.5	6.0
74	13	09	MLA1-GAM	367.0									
74	13	09	MLA2-GAM	290.0	25	4	25	3	8	5.6	0.5	25.0	5.6
74	15	09	MLA1-GAM	323.0									
74	15	09	MLA2-GAM	287.0	62	6	55	6	18	12.5	0.8	31.2	14.2
74	22	09	MLA1-GAM	162.0									
74	22	09	MLA2-GAM	189.0	88	13	49	6	14	1.3	1.0	36.0	2.7
74	07	09	MLA1-GAM	211.0									
74	07	09	MLA2-GAM	121.0	54	13	43	3	14	1.9	2.8	65.2	4.3
74	09	09	MLA1-GAM	203.0									
74	09	09	MLA2-GAM	269.0	120.0		37.6			12.4	1.2	11.8	12.8
74	09	09	MLA1-1900	14.0	175.0		36.5			14.3	1.0	9.6	14.3
74	09	09	MLA2-1500	217.0			45.8			21.0	0.5	4.1	21.0
74	09	09	MLA1-1075	216.0									
74	09	09	MLA2-1075	172.0	129.0		51.3			16.3	1.9	18.1	16.9
74	11	11	MLA1-GAM	172.0			41.3			17.4	0.3	2.8	17.4
74	11	11	MLA2-GAM	130.0			50.9		16	16.1	1.0	10.1	15.1
74	14	11	MLA1-GAM	141.0	141.0	50	48.6	10	16	11.4	0.2	2.3	11.4
74	14	11	MLA2-GAM	156.0			50.9						
74	14	11	MLA1-GAM	215.0			50.9	17	25	12.8	0.5	10.5	12.8

2

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED		FILTERED		COD	TOD	FOC	NH3N	NO2N	NO3N	TKN
				COD	BOO	COD	BOO							
73	20	11	EA-C	193.0	16.7	46.7	16	13.4	0.2	3.9	13.4			
73	20	11	EA-GAM	124.0	12.5									
73	21	11	MLA-GPH		237.7									
73	22	11	EA-C	178.0	230.0									
74	28	01	MLA-GAM	48.2	11.7	41.3	18	13.7	0.1	2.6	13.7			
74	29	01	EA-C	61.8	119.0	31.8	7	5.2	0.2	4.1	5.3			
74	31	01	MLA-GAM		184.0	39.3	6	10.0	0.2	0.9	10.0			
74	31	01	MLA-1800		198.0									
74	31	01	MLA-2100		122.1									
74	31	01	EA-CI	5.0	0.8	33.8	8	9.0	0.3	2.5	9.0			
74	31	01	EA-C2	5.2	1.4	38.0	16	5.7	0.4	3.3	5.7			
74	31	01	EA-C3	5.5	1.2	40.0	11	11.6	0.5	4.8	11.6			
74	31	01	EA-C4	5.6	1.5	49.0	12	7.9	0.3	5.5	7.9			
74	31	01	EA-C5	5.9	1.5	59.0	13	9.9	0.3	6.9	9.9			
74	31	01	EA-C6	6.3	2.0	63.0	15	9.0	0.3	8.0	9.0			
74	31	01	EA-C7	6.5	2.6	65.0	17	8.0	0.4	8.9	8.0			
74	31	01	EA-C8	8.0	3.6	80.0	21	6.0	0.3	10.5	6.0			
74	31	01	EA-C9	8.2	4.1	82.0	22	7.4	0.4	11.5	7.4			
74	31	01	EA-C10	8.6	4.9	86.0	24	7.4	0.3	12.5	7.4			
74	31	01	EA-C11	7.4	4.4	74.0	23	8.7	0.4	11.3	8.7			
74	31	01	EA-C12	7.4	4.4	74.0	23	7.7	0.3	11.3	7.7			
74	31	01	EA-C13	7.4	4.4	74.0	23	8.2	0.4	11.3	8.2			
74	31	01	EA-C14	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C15	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C16	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C17	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C18	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C19	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C20	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C21	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C22	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C23	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C24	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C25	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C26	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C27	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C28	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C29	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C30	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C31	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C32	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C33	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C34	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C35	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C36	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C37	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C38	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C39	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			
74	31	01	EA-C40	7.4	4.4	74.0	23	7.4	0.3	11.2	7.4			

ANALYSES

YEAR	DAY	MOH	MONTH	SIGNATURE	UNFILTERED			FILTERED				NO2N	NO3N	TKN
					COD	BOD	TKN	COD	BOD	TKN	FOC			
74	30	04	04	EA-C4	56	25	3	36	9	1.4	2.4	32.6	4.7	
74	31	04	05	EA-C5	60	6	3	40	10	1.7	2.2	34.3	5.2	
74	01	05	07	EA-C7	55	6	3	36	9	1.7	1.9	35.6	5.2	
74	01	05	08	EA-C8	56	6	3	36	9	1.8	1.7	35.6	5.2	
74	01	05	09	EA-C9	54	6	3	47	10	1.2	1.1	37.4	4.5	
74	01	05	09	MLA-0900										
74	01	05	10	MLA-1500										
74	01	05	10	EA-C10	55	6	3	30	9	1.0	1.0	28.5	6.7	
74	01	05	11	EA-C11	53	7	3	37	9	1.5	1.0	34.5	1.7	
74	01	05	12	EA-C12	90	4	3	37	13	1.4	1.0	37.0	1.4	
74	01	05	13	EA-C13	74	8	3	37	10	1.8	1.0	37.0	1.4	
74	01	05	15	EA-C15	86	9	3	37	11	1.6	1.5	36.0	1.4	
74	01	05	16	EA-C16	86	9	3	56	10	1.6	1.5	34.0	1.4	
74	01	05	16	EA-C16	67	14	3	41	10	1.5	2.0	29.0	1.5	
74	01	05	16	EA-C16	67	14	3	41	10	1.5	2.0	29.0	1.5	
74	01	05	16	MLA-0900										
74	01	05	16	MLA-1500										
74	01	05	16	EA-C16	45	13	3	28	6	9.6	1.0	22.0	9.6	
74	01	05	16	EA-C16	46	13	3	17	6	6.5	1.5	22.0	6.5	
74	01	06	06	MLA-C-GAM	56	8	5	39	18	13.0	0.5	5.9	13.0	
74	01	06	06	MLA-C-GAM	70	12	6	45	17	18.3	0.6	5.5	18.3	
74	01	06	07	MLA-C-GAM	42	4	4	44	10	15.1	1.4	11.6	15.1	
74	01	06	07	MLA-C-GAM	46	4	4	33	8	1.8	1.0	23.5	1.8	
74	01	06	07	EA-C-GAM	39	7	1	30	12	3.0	0.5	22.5	3.0	
74	01	06	07	MLA-C-GPM	55	7	2	38	14	9.8	2.2	12.2	11.0	
74	01	06	07	EA-C-GAM	55	7	2	38	12	4.9	1.0	17.0	6.1	
74	01	06	07	MLA-C-GAM	28	4	3	20	10	5.8	0.4	30.1	6.6	
74	01	06	08	MLA-(0900)-1700	28	5	4	29	10	6.2	0.2	29.3	7.0	
74	01	06	08	EA-C-GAM	37	5	2	26	10	6.2	0.2	29.3	7.0	
74	01	06	08	MLA-C-GAM	29	6	7	25	11	1.4	0.8	15.7	2.1	
74	01	06	08	EA-C-GAM	29	6	7	25	11	1.4	0.8	15.7	2.1	
74	01	06	08	MLA-C-GAM	41	15	6	25	13	6.7	2.7	14.8	8.0	
74	01	06	08	EA-C-GAM	41	15	6	25	13	6.7	2.7	14.8	8.0	
74	01	06	08	MLA-C-GAM	41	35	4	33	11	13.7	0.8	31.2	14.1	
74	01	06	09	MLA-C-GAM	65	6	5	37	14	14.0	0.2	28.8	14.7	

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD	BOD	UNFILTERED TKN	COD	300	FOC	FILTERED NH3N	NO2N	NO3N	TKN
74	19	12	EA-0600	52		19.8	45			8.0	0.0	10.9	8.6
74	19	12	EA-0900	54		7.7	47			5.9	0.0	10.9	7.7
74	19	12	EA-1200	43		7.2	48			5.4	0.0	10.8	6.7
74	19	12	EA-1800	44		6.4	40			5.0	0.0	11.4	7.3
74	19	12	EA-2100	49		17.9	44			11.2	0.0	11.4	16.9
74	20	12	EA-0300	65		15.7	44			11.0	0.0	11.0	11.4
74	20	12	EA-0600	63		19.2	42			14.7	0.0	11.9	18.7
74	20	12	EA-0900	61		7.7	44			5.2	0.0	11.0	7.7
74	20	12	EA-1500	66		5.4	45			3.2	0.0	11.3	5.4
74	20	12	EA-1800	61		5.6	48			4.2	0.0	11.3	5.4
74	20	12	EA-2100	65		5.4	45			4.2	0.0	11.3	5.4
74	20	12	EA-0300	66		5.5	45			4.4	0.0	11.3	5.5
74	20	12	EA-0600	64		5.5	45			4.4	0.0	11.3	5.5
74	20	12	EA-0900	69		5.5	45			4.4	0.0	11.3	5.5
74	21	12	EA-0300	57		4.4	44			2.2	0.0	11.6	4.4
74	21	12	EA-0600	54		3.7	47			1.5	0.0	11.6	3.7
75	01	12	EA-0900	17		11.0	10			1.0	0.0	11.2	11.0
75	01	12	EA-1200	16		11.0	10			1.0	0.0	11.2	11.0
75	01	12	EA-1500	15		11.0	10			1.0	0.0	11.2	11.0
75	01	12	EA-1800	15		11.0	10			1.0	0.0	11.2	11.0
75	01	12	EA-2100	16		11.0	10			1.0	0.0	11.2	11.0
75	02	12	EA-0300	16		11.0	10			1.0	0.0	11.2	11.0
75	02	12	EA-0600	17		11.0	10			1.0	0.0	11.2	11.0
75	02	12	EA-0900	17		11.0	10			1.0	0.0	11.2	11.0
75	02	12	EA-1200	17		11.0	10			1.0	0.0	11.2	11.0
75	02	12	EA-1500	17		11.0	10			1.0	0.0	11.2	11.0
75	02	12	EA-1800	17		11.0	10			1.0	0.0	11.2	11.0
75	02	12	EA-2100	17		11.0	10			1.0	0.0	11.2	11.0
75	03	12	EA-0300	17		11.0	10			1.0	0.0	11.2	11.0
75	03	12	EA-0600	17		11.0	10			1.0	0.0	11.2	11.0
75	03	12	EA-0900	17		11.0	10			1.0	0.0	11.2	11.0
75	03	12	EA-1200	17		11.0	10			1.0	0.0	11.2	11.0
75	03	12	EA-1500	17		11.0	10			1.0	0.0	11.2	11.0
75	03	12	EA-1800	17		11.0	10			1.0	0.0	11.2	11.0
75	03	12	EA-2100	17		11.0	10			1.0	0.0	11.2	11.0
75	04	12	EA-0300	17		11.0	10			1.0	0.0	11.2	11.0
75	04	12	EA-0600	17		11.0	10			1.0	0.0	11.2	11.0
75	04	12	EA-0900	17		11.0	10			1.0	0.0	11.2	11.0
75	04	12	EA-1200	17		11.0	10			1.0	0.0	11.2	11.0
75	04	12	EA-1500	17		11.0	10			1.0	0.0	11.2	11.0
75	04	12	EA-1800	17		11.0	10			1.0	0.0	11.2	11.0
75	04	12	EA-2100	17		11.0	10			1.0	0.0	11.2	11.0

ANALYSES

YEAR	DAY	MON	SAMP DESIGNATION	COD	TKN	UNFILTERED 800	TKN	COD	800	FOC	NH3-N	FILTERED		NO3-N	TKN
												NO2-N	NO3-N		
77	29	01	FA-1500	65	3.1		3.1	46		11	1.0	0.9	13.0	2.0	
77	29	01	FA-1600	66	3.1		3.1	52		10	0.8	0.7	12.0	2.0	
77	29	01	FA-1700	257	3.2		3.2	81		13	0.9	0.7	12.0	2.0	
77	29	01	FA-1800	81	2.0		2.0	55		9	0.7	0.6	11.0	1.9	
77	29	01	FA-1900	71	2.0		2.0	55		9	0.8	0.7	11.0	1.9	
77	29	01	FA-2000	73	2.0		2.0	55		9	0.7	0.6	11.0	1.9	
77	29	01	FA-2100	66	3.3		3.3	45		9	0.6	0.6	11.0	1.9	
77	29	01	FA-2200	69	3.3		3.3	45		9	0.6	0.6	11.0	1.9	
77	29	01	FA-2300	63	3.5		3.5	47		9	0.6	0.6	11.0	1.9	
77	29	01	FA-2400	63	3.7		3.7	33		15	0.5	0.5	11.0	1.9	
77	29	01	FA-0100	63	2.2		2.2	33		17	0.3	0.3	11.0	1.9	
77	29	01	FA-0200	56	1.6		1.6	35		14	0.2	0.2	11.0	1.9	
77	29	01	FA-0300	55	1.4		1.4	37		12	0.2	0.2	11.0	1.9	
77	29	01	FA-0400	55	1.6		1.6	37		12	0.2	0.2	11.0	1.9	
77	29	01	FA-0500	55	2.0		2.0	37		14	0.2	0.2	11.0	1.9	
77	29	01	FA-0600	55	2.2		2.2	37		14	0.2	0.2	11.0	1.9	
77	29	01	FA-0700	47	2.2		2.2	35		14	0.2	0.2	11.0	1.9	
77	29	01	FA-0800	47	2.2		2.2	35		14	0.2	0.2	11.0	1.9	
77	29	01	FA-0900	50	2.5		2.5	35		17	0.2	0.2	11.0	1.9	
77	29	02	FA-0100	58	12.5	8	12.5	6	6	17	9.2	9.2	52.0	5.0	
77	29	02	FA-0200	95	4.8	6	4.8	47	4	14	2.5	1.0	32.0	3.0	
77	29	02	FA-0300	70	3.1	9	3.1	47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-0400	100	4.0	16	4.0	56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-0500	125	3.4	19	3.4	57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-0600	125	1.9	14	1.9	57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-0700	125	1.6	14	1.6	55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-0800	125	17.3	17	17.3	37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-0900		69.3		69.3	47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-1000					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-1100					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-1200					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-1300					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-1400					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-1500					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-1600					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-1700					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-1800					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-1900					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-2000					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-2100					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-2200					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-2300					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-2400					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-2500					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-2600					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-2700					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-2800					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-2900					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-3000					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-3100					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-3200					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-3300					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-3400					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-3500					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-3600					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-3700					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-3800					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-3900					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-4000					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-4100					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-4200					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-4300					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-4400					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-4500					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-4600					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-4700					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-4800					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-4900					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-5000					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-5100					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-5200					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-5300					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-5400					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-5500					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-5600					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-5700					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-5800					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-5900					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-6000					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-6100					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-6200					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-6300					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-6400					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-6500					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-6600					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-6700					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-6800					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-6900					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-7000					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-7100					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-7200					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-7300					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-7400					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-7500					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-7600					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-7700					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-7800					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-7900					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-8000					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-8100					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-8200					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-8300					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-8400					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-8500					37	3	17	12.0	0.5	4.3	1.2	
77	29	03	FA-8600					47	4	13	0.6	0.2	30.8	1.4	
77	29	03	FA-8700					47	3	13	0.6	0.2	30.8	1.4	
77	29	03	FA-8800					56	5	12	5.6	1.0	10.9	0.7	
77	29	03	FA-8900					57	5	15	9.8	1.3	10.4	0.7	
77	29	03	FA-9000					57	6	15	9.0	0.3	6.0	1.2	
77	29	03	FA-9100					55	5	17	12.0	0.5	4.3	1.2	
77	29	03	FA-9200					37	3	17	12.0	0.5	4.3	1.2	

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED		FILTERED		TKN	COD	BOD	FOC	NH3N	NO2N	NO3N	TKN
				COD BOD	TKN	COD	TKN								
77	05	03	A-0300					54							11.2
77	05	03	A-0600	92	8	3.0		54							11.2
77	05	03	A-0900	121	15	14.0		54	7	17	9.1	0.9	9.2		11.2
77	05	03	A-1200	276	47	27.0		69	21	30	16.0	0.6	1.2		19.2
77	05	03	A-1500	125	19	20.5		68	8	20	15.0	0.5	2.2		17.4
77	05	03	A-1800	95	12	11.0		63	4	16	12.6	0.3	3.3		15.3
77	05	03	A-2100	63	6	10.3		40	6	14	9.7	0.7	7.7		10.7
77	05	03	A-2400	72	7	11.7		53	3	17	5.3	1.2	14.3		7.2
77	05	03	A-2700	76	8	10.5		52	3	16	2.0	1.3	15.7		3.1
77	05	03	A-3000			149.7		48							8
77	05	03	A-3300			141.0		47							9
77	05	03	A-3600					43							9
77	05	03	A-3900					34							9
77	05	03	A-4200					34							9
77	05	03	A-4500					34							9
77	05	03	A-4800					34							9
77	05	03	A-5100					34							9
77	05	03	A-5400					34							9
77	05	03	A-5700					34							9
77	05	03	A-6000					34							9
77	05	03	A-6300					34							9
77	05	03	A-6600					34							9
77	05	03	A-6900					34							9
77	05	03	A-7200					34							9
77	05	03	A-7500					34							9
77	05	03	A-7800					34							9
77	05	03	A-8100					34							9
77	05	03	A-8400					34							9
77	05	03	A-8700					34							9
77	05	03	A-9000					34							9
77	05	03	A-9300					34							9
77	05	03	A-9600					34							9
77	05	03	A-9900					34							9

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED	COD	800	F0C	NH3N	FILTERED	NO2N	NO3N	IKN
77	1	3	AA-2400	1	5	5	1	7	1	2	6	2
77	1	3	AA-0300	1	3	3	0	5	1	4	6	1
77	1	3	AA-0600	1	3	3	0	5	1	4	6	1
77	1	3	AA-1200	1	3	3	0	5	1	4	6	1
77	1	3	AA-1500	1	3	3	0	5	1	4	6	1
77	1	3	AA-1800	1	3	3	0	5	1	4	6	1
77	1	3	AA-2100	1	3	3	0	5	1	4	6	1
77	1	3	AA-2400	1	3	3	0	5	1	4	6	1
77	1	3	AA-0300	1	3	3	0	5	1	4	6	1
77	1	3	AA-0600	1	3	3	0	5	1	4	6	1
77	1	3	AA-1200	1	3	3	0	5	1	4	6	1
77	1	3	AA-1500	1	3	3	0	5	1	4	6	1
77	1	3	AA-1800	1	3	3	0	5	1	4	6	1
77	1	3	AA-2100	1	3	3	0	5	1	4	6	1
77	1	3	AA-2400	1	3	3	0	5	1	4	6	1
77	1	3	AA-0300	1	3	3	0	5	1	4	6	1
77	1	3	AA-0600	1	3	3	0	5	1	4	6	1
77	1	3	AA-1200	1	3	3	0	5	1	4	6	1
77	1	3	AA-1500	1	3	3	0	5	1	4	6	1
77	1	3	AA-1800	1	3	3	0	5	1	4	6	1
77	1	3	AA-2100	1	3	3	0	5	1	4	6	1
77	1	3	AA-2400	1	3	3	0	5	1	4	6	1
77	1	3	AA-0300	1	3	3	0	5	1	4	6	1
77	1	3	AA-0600	1	3	3	0	5	1	4	6	1
77	1	3	AA-1200	1	3	3	0	5	1	4	6	1
77	1	3	AA-1500	1	3	3	0	5	1	4	6	1
77	1	3	AA-1800	1	3	3	0	5	1	4	6	1
77	1	3	AA-2100	1	3	3	0	5	1	4	6	1
77	1	3	AA-2400	1	3	3	0	5	1	4	6	1
77	1	3	AA-0300	1	3	3	0	5	1	4	6	1
77	1	3	AA-0600	1	3	3	0	5	1	4	6	1
77	1	3	AA-1200	1	3	3	0	5	1	4	6	1
77	1	3	AA-1500	1	3	3	0	5	1	4	6	1
77	1	3	AA-1800	1	3	3	0	5	1	4	6	1
77	1	3	AA-2100	1	3	3	0	5	1	4	6	1
77	1	3	AA-2400	1	3	3	0	5	1	4	6	1
77	1	3	AA-0300	1	3	3	0	5	1	4	6	1
77	1	3	AA-0600	1	3	3	0	5	1	4	6	1
77	1	3	AA-1200	1	3	3	0	5	1	4	6	1
77	1	3	AA-1500	1	3	3	0	5	1	4	6	1
77	1	3	AA-1800	1	3	3	0	5	1	4	6	1
77	1	3	AA-2100	1	3	3	0	5	1	4	6	1
77	1	3	AA-2400	1	3	3	0	5	1	4	6	1

FILT COD RESULT ELIMINATED DUE TO ANALYTICAL ERROR

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED	FILTERED	COD	800	FOC	NH3N	NO2N	NO3N	TKN
75	17	3	EA-2100			43			6.2	1.4	13.6	3.7
75	17	3	EA-2400			47			4.8	1.1	13.8	6.6
75	18	3	EA-0300			35			3.3	1.1	18.9	6.4
75	18	3	EA-0900			43			3.0	1.0	16.0	4.5
75	18	3	EA-1200			43			4.4	0.4	17.6	7.6
75	18	3	EA-1500			49			2.7	2.5	20.8	2.9
75	18	3	EA-1800			46			2.7	2.9	20.1	3.7
75	18	3	EA-2100			47			2.6	1.1	20.3	4.7
75	18	3	EA-2400			47			2.6	1.1	20.7	4.7
75	19	3	EA-0300			43			3.3	1.0	18.0	2.1
75	19	3	EA-0900			43			3.3	1.0	18.0	2.1
75	19	3	EA-1200			43			3.3	1.0	18.0	2.1
75	19	3	EA-1500			43			3.3	1.0	18.0	2.1
75	19	3	EA-1800			43			3.3	1.0	18.0	2.1
75	19	3	EA-2100			43			3.3	1.0	18.0	2.1
75	19	3	EA-2400			43			3.3	1.0	18.0	2.1
75	24	3	MLA-C GAM	4	12	4						
75	24	3	MLA-C GAM	8	11	3			1.4	0.6	7.2	1.9
75	25	3	MLA-C GAM	7	11	3			0.6	0.7	8.6	1.1
75	26	3	MLA-C GAM	8	12	3			1.1	0.6	7.3	1.2
75	27	3	MLA-C GAM			35			1.1	0.6	7.3	1.2
75	27	3	EA-0300			29			7.9	0.7	8.9	1.7
75	27	3	EA-0900			22			1.1	0.9	9.1	1.1
75	27	3	EA-1200			22			1.1	1.1	9.1	1.1
75	27	3	EA-1500			22			1.1	1.1	9.1	1.1
75	27	3	EA-1800			22			1.1	1.1	9.1	1.1
75	27	3	EA-2100			22			1.1	1.1	9.1	1.1
75	27	3	EA-2400			22			1.1	1.1	9.1	1.1
75	27	3	EA-0300			22			1.1	1.1	9.1	1.1
75	27	3	EA-0900			22			1.1	1.1	9.1	1.1
75	27	3	EA-1200			22			1.1	1.1	9.1	1.1
75	27	3	EA-1500			22			1.1	1.1	9.1	1.1
75	27	3	EA-1800			22			1.1	1.1	9.1	1.1
75	27	3	EA-2100			22			1.1	1.1	9.1	1.1
75	27	3	EA-2400			22			1.1	1.1	9.1	1.1
75	27	3	EA-0300			22			1.1	1.1	9.1	1.1
75	27	3	EA-0900			22			1.1	1.1	9.1	1.1
75	27	3	EA-1200			22			1.1	1.1	9.1	1.1
75	27	3	EA-1500			22			1.1	1.1	9.1	1.1
75	27	3	EA-1800			22			1.1	1.1	9.1	1.1
75	27	3	EA-2100			22			1.1	1.1	9.1	1.1
75	27	3	EA-2400			22			1.1	1.1	9.1	1.1
75	27	3	EA-0300			22			1.1	1.1	9.1	1.1
75	27	3	EA-0900			22			1.1	1.1	9.1	1.1
75	27	3	EA-1200			22			1.1	1.1	9.1	1.1
75	27	3	EA-1500			22			1.1	1.1	9.1	1.1
75	27	3	EA-1800			22			1.1	1.1	9.1	1.1
75	27	3	EA-2100			22			1.1	1.1	9.1	1.1
75	27	3	EA-2400			22			1.1	1.1	9.1	1.1

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD	UNFILTERED TKN	COD	BOD	FOC	FILTERED NH3N	FILTERED NO2N	N03N	TKN
75	27	03	EA-1200	56		1.1			1.1	0.2	8.2	1.8
75	27	03	EA-1500	55		1.0			1.0	0.3	8.6	1.7
75	27	03	EA-1800	55		0.7			0.7	1.4	10.0	1.6
75	27	03	EA-2400	53		0.7			0.7	1.6	9.2	1.6
75	27	03	EA-0300	30		0.8			0.8	0.4	8.9	1.5
75	27	03	EA-0600	29		1.0			1.0	0.3	9.2	1.5
75	27	03	EA-C	4	3.9			15	0.9	0.1	13.7	3.3
75	07	04	MLA-C	57	75.0				8.9	1.8	13.4	10.0
75	08	04	MLA-C	80	12.0				0.7	0.3	13.7	0.8
75	09	04	MLA-C	57	1.0				0.7	0.3	13.7	0.8
75	09	04	MLA-C	63	108.0			14	0.8	0.3	13.8	1.9
75	10	04	MLA-C		107.0							
75	11	04	MLA-C		191.0							
75	17	04	EA-0900	58		0.5			0.5	0.0	5.7	1.0
75	17	04	EA-1200	37		0.6			0.6	0.0	7.7	1.1
75	17	04	EA-1500	43		0.4			0.4	0.0	5.9	1.1
75	17	04	EA-1800	44		0.4			0.4	0.0	5.6	1.1
75	17	04	EA-2100	40		0.5			0.5	0.0	5.4	1.1
75	17	04	EA-0300	38		0.8			0.8	0.0	5.8	1.0
75	17	04	EA-0600	35		0.4			0.4	0.0	5.4	1.0
75	17	04	EA-0900	57	19.5				19.5	1.2	2.8	6.6
75	17	04	EA-1200	15		0.7			0.7	2.0	2.0	2.0
75	17	04	EA-1500	6		0.7			0.7	2.7	2.0	1.7
75	17	04	EA-1800	4		0.9			0.9	0.0	4.9	1.9
75	17	04	EA-2100	20		0.1			0.1	0.0	2.0	0.5
75	17	04	EA-0300	36		0.4			0.4	0.0	0.7	1.1
75	17	04	EA-0600	34		0.0			0.0	0.0	3.9	1.1
75	17	04	EA-0900	40		0.0			0.0	0.0	3.5	1.1
75	17	04	EA-1200	22		0.0			0.0	0.0	3.6	1.1
75	17	04	EA-1500	48		0.0			0.0	0.0	3.3	1.1
75	17	04	EA-1800	24		0.0			0.0	0.0	3.2	1.1
75	17	04	EA-2100	20		0.0			0.0	0.0	3.4	1.1
75	17	04	EA-0300	22		0.0			0.0	0.0	3.2	1.1
75	17	04	EA-0600	40		0.0			0.0	0.0	3.5	1.1
75	17	04	EA-0900	22		0.0			0.0	0.0	3.4	1.1
75	17	04	EA-1200	44		0.0			0.0	0.0	3.4	1.1
75	17	04	EA-1500	40		0.0			0.0	0.0	3.3	1.1
75	17	04	EA-1800	40		0.0			0.0	0.0	3.2	1.1
75	17	04	EA-2100	46		0.0			0.0	0.0	3.1	1.1
75	17	04	EA-0300	49		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0600	33		0.0			0.0	0.0	2.5	1.1
75	17	04	EA-0900	43		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1200	38		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1500	43		0.0			0.0	0.0	2.5	1.1
75	17	04	EA-1800	49		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-2100	44		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0300	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0600	33		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0900	44		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1200	44		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1500	43		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1800	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-2100	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0300	44		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0600	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0900	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1200	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1500	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1800	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-2100	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0300	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0600	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0900	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1200	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1500	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1800	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-2100	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0300	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0600	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0900	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1200	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1500	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1800	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-2100	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0300	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0600	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0900	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1200	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1500	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1800	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-2100	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0300	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0600	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0900	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1200	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1500	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1800	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-2100	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0300	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0600	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0900	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1200	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1500	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1800	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-2100	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0300	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0600	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-0900	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1200	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1500	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-1800	48		0.0			0.0	0.0	2.4	1.1
75	17	04	EA-2100	48		0.0			0.0	0.0	2.4	1.1

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED	FILTERED	COD	800	FOC	NH3N	NO2N	NO3N	TKN	IKN
75	15	04	EA-C	104	15	67	12	21	1.0	1.8	4.8	6.9	1.7
75	16	04	MLA-C	13	114.0	77	6	22	8.7	2.4	5.8	9.2	
75	17	04	MLA-C	79	97.0	47	4	13	5.0	3.8	5.3	7.5	
75	18	04	MLA-C	9	118.0	41	3	12	4.2	3.1	4.6	6.1	
75	19	04	MLA-C	67	124.0	36	3	11	1.8	1.1	8.6	3.0	
75	20	04	MLA-C	10	87.0								
75	21	04	EA-C	68	2.7	30	3	10	0.4	0.3	4.6	1.4	
75	22	04	EA-C	66	8.6	39	3	10	4.4	1.4	15.2	7.0	
75	23	04	EA-C	83	107.0	48	3	10	11.6	1.5	15.5	13.3	
75	24	04	EA-C	83	93.0	37	3	10	3.6	0.6	13.9	4.8	
75	25	04	EA-C	110	86.4	42	5	15	5.5	0.3	10.9	7.4	
75	26	04	EA-C		134.0								
75	27	04	EA-C		111.3								
75	28	04	EA-C		142.0								
75	29	04	EA-C										
75	30	04	EA-C										
75	31	04	EA-C										
75	15	04	EA-C	104	15	67	12	21	1.0	1.8	4.8	6.9	1.7
75	16	04	MLA-C	13	114.0	77	6	22	8.7	2.4	5.8	9.2	
75	17	04	MLA-C	79	97.0	47	4	13	5.0	3.8	5.3	7.5	
75	18	04	MLA-C	9	118.0	41	3	12	4.2	3.1	4.6	6.1	
75	19	04	MLA-C	67	124.0	36	3	11	1.8	1.1	8.6	3.0	
75	20	04	MLA-C	10	87.0								
75	21	04	EA-C	68	2.7	30	3	10	0.4	0.3	4.6	1.4	
75	22	04	EA-C	66	8.6	39	3	10	4.4	1.4	15.2	7.0	
75	23	04	EA-C	83	107.0	48	3	10	11.6	1.5	15.5	13.3	
75	24	04	EA-C	83	93.0	37	3	10	3.6	0.6	13.9	4.8	
75	25	04	EA-C	110	86.4	42	5	15	5.5	0.3	10.9	7.4	
75	26	04	EA-C		134.0								
75	27	04	EA-C		111.3								
75	28	04	EA-C		142.0								
75	29	04	EA-C										
75	30	04	EA-C										
75	31	04	EA-C										

62 SAMPLES HAVE BEEN ADJUSTED FOR DILUTION ON NO3 ANALYSIS FOR THESE VALUES

EA-C100, 3300, 0500 HRS. THESE VALUES

EA-C100, 3300, 0500 HRS. THESE VALUES

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD	BOD	FOC	FILTERED NH3N	NO2N	NO3N	TKN	AS
77	2	04	EA-1400	39		10	12.7	2.1	7.9	4.4	
77	2	04	EA-1700	42		11	12.9	1.6	3.4	4.8	
77	2	04	EA-2300	45		10	13.5	1.5	3.4	5.6	
77	2	04	EA-0500	47		13	18.6	1.4	5.6	7.0	
77	2	04	EA-0800	33		11	8.5	2.2	6.0	9.9	
77	2	04	EA-1100	36		11	8.5	1.3	7.7	16.1	
77	2	04	EA-1500	35		11	8.4	1.3	7.8	10.9	
77	2	04	EA-1700	35		11	10.5	2.3	7.6	10.9	
77	2	04	EA-2300	33		11	10.0	2.0	7.4	10.0	
77	3	04	EA-0100	32		11	0.0	0.0	3.4	3.7	
77	3	04	EA-0300	35		11	2.5	1.6	3.5	2.7	
77	3	04	EA-0500	36		11	5.5	2.2	3.5	2.8	
77	3	04	EA-0700	37		11	5.5	2.2	3.5	2.8	
77	3	04	EA-1100	34		11	6.6	2.3	3.4	2.3	
77	3	04	EA-1700	37		11	6.6	2.2	3.5	2.6	
77	3	04	EA-1900	37		11	6.5	2.2	3.5	2.6	
77	3	04	EA-2300	44		11	6.5	2.2	3.5	2.6	
77	3	04	EA-0100	44		11	4.4	2.2	3.5	2.6	
77	3	04	EA-0300	47		11	4.4	2.2	3.5	2.6	
77	3	04	EA-0500	43		11	4.4	2.2	3.5	2.6	
77	3	04	EA-0700	46		11	5.5	2.3	3.4	2.4	
77	3	04	EA-1100	42		11	5.5	2.3	3.4	2.4	
77	3	04	EA-1700	46		11	5.5	2.3	3.4	2.4	
77	3	04	EA-1900	46		11	5.5	2.3	3.4	2.4	
77	3	04	EA-2300	42		11	5.5	2.3	3.4	2.4	
77	5	04	EA-0100	40		12	8.6	2.4	3.6	2.0	
77	5	04	EA-0300	40		12	8.6	2.4	3.6	2.0	
77	5	04	EA-0500	40		12	8.6	2.4	3.6	2.0	
77	5	04	EA-0700	40		12	8.6	2.4	3.6	2.0	
77	5	04	EA-1100	40		12	8.6	2.4	3.6	2.0	
77	5	04	EA-1700	40		12	8.6	2.4	3.6	2.0	
77	5	04	EA-1900	40		12	8.6	2.4	3.6	2.0	
77	5	04	EA-2300	40		12	8.6	2.4	3.6	2.0	
77	9	04	EA-0100	38		16	3.5	9.2	2.5	4.5	
77	9	04	EA-1100	33		11	5.5	3.2	5.4	2.5	
77	9	04	EA-1300	33		11	5.5	3.2	5.4	2.5	
77	9	04	EA-1700	34		11	5.5	3.2	5.4	2.5	
77	9	04	EA-1900	34		11	5.5	3.2	5.4	2.5	
77	9	04	EA-2300	34		11	5.5	3.2	5.4	2.5	
77	10	04	EA-0100	32		11	5.5	3.2	5.4	2.5	
77	10	04	EA-1100	32		11	5.5	3.2	5.4	2.5	
77	10	04	EA-1300	32		11	5.5	3.2	5.4	2.5	
77	10	04	EA-1700	32		11	5.5	3.2	5.4	2.5	
77	10	04	EA-1900	32		11	5.5	3.2	5.4	2.5	
77	10	04	EA-2300	32		11	5.5	3.2	5.4	2.5	

ARE THE 2 HR RESULTS FROM 19/4 110 HRS PERIOD BASED ON 3 HR
 FILTERED FROM A CONTINUOUS RECOPI DURING THIS PERIOD BASED ON 3 HR

ALL INTERPRETATIONS ARE THE 2 HR RESULTS FROM 19/4 110 HRS PERIOD BASED ON 3 HR

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD BOD	UNFILTERED TKN	COD	300	FOC	NH3N	NO2N	NO3N	TKN
75	20	04	EA-1500			29		10	0.2	0	5.4	1.4
75	20	04	EA-1700			22		11	0.3	0	5.3	1.2
75	20	04	EA-1900			27		11	0.3	0	4.8	1.0
75	20	04	EA-2100			44		10	0.0	0	4.0	1.0
75	20	04	EA-2300			45		10	0.0	0	4.0	1.0
75	21	04	EA-0300			53		10	0.0	0	4.3	1.0
75	21	04	EA-0500			37		10	0.5	0	4.0	1.0
75	21	04	EA-0700			33		9	0.8	0	4.4	1.0
75	21	04	EA-0900			35		9	0.5	0	4.3	1.0
75	21	04	EA-1100			33		9	0.2	0	4.5	1.0
75	21	04	EA-1300			35		9	0.5	0	4.0	1.0
75	21	04	EA-1500			33		9	0.2	0	4.8	1.0
75	21	04	EA-1700			35		9	0.5	0	4.5	1.0
75	21	04	EA-1900			38		9	0.2	0	4.2	1.0
75	21	04	EA-2100			35		9	0.9	0	4.5	1.0
75	21	04	EA-2300			33		9	0.2	0	4.2	1.0
75	22	04	EA-0100			35		9	0.5	0	4.5	1.0
75	22	04	EA-0300			33		9	0.0	0	4.5	1.0
75	22	04	EA-0500			33		9	0.7	0	5.0	1.0
75	22	04	EA-0700			33		9	0.0	0	4.5	1.0
75	22	04	EA-0900			33		9	0.7	0	4.5	1.0
75	22	04	EA-1100			33		9	0.0	0	4.5	1.0
75	22	04	EA-1300			40		10	0.5	0	4.5	1.0
75	22	04	EA-1500			44		11	0.3	0	4.5	1.0
75	22	04	EA-1700			44		11	0.9	0	4.5	1.0
75	22	04	EA-1900			44		11	0.3	0	4.5	1.0
75	22	04	EA-2100			44		11	0.9	0	4.5	1.0
75	22	04	EA-2300			44		11	0.3	0	4.5	1.0
75	23	04	EA-0100			44		11	0.9	0	4.5	1.0
75	23	04	EA-0300			44		11	0.3	0	4.5	1.0
75	23	04	EA-0500			44		11	0.9	0	4.5	1.0
75	23	04	EA-0700			44		11	0.3	0	4.5	1.0
75	23	04	EA-0900			44		11	0.9	0	4.5	1.0
75	23	04	EA-1100			44		11	0.3	0	4.5	1.0
75	23	04	EA-1300			44		11	0.9	0	4.5	1.0
75	23	04	EA-1500			44		11	0.3	0	4.5	1.0
75	23	04	EA-1700			44		11	0.9	0	4.5	1.0
75	23	04	EA-1900			44		11	0.3	0	4.5	1.0
75	23	04	EA-2100			44		11	0.9	0	4.5	1.0
75	23	04	EA-2300			44		11	0.3	0	4.5	1.0
75	23	04	EA-2500			44		11	0.9	0	4.5	1.0
75	23	04	EA-2700			44		11	0.3	0	4.5	1.0
75	23	04	EA-2900			44		11	0.9	0	4.5	1.0
75	23	04	EA-3100			44		11	0.3	0	4.5	1.0
75	23	04	EA-3300			44		11	0.9	0	4.5	1.0
75	23	04	EA-3500			44		11	0.3	0	4.5	1.0
75	23	04	EA-3700			44		11	0.9	0	4.5	1.0
75	23	04	EA-3900			44		11	0.3	0	4.5	1.0
75	23	04	EA-4100			44		11	0.9	0	4.5	1.0
75	23	04	EA-4300			44		11	0.3	0	4.5	1.0
75	23	04	EA-4500			44		11	0.9	0	4.5	1.0
75	23	04	EA-4700			44		11	0.3	0	4.5	1.0
75	23	04	EA-4900			44		11	0.9	0	4.5	1.0
75	23	04	EA-5100			44		11	0.3	0	4.5	1.0
75	23	04	EA-5300			44		11	0.9	0	4.5	1.0
75	23	04	EA-5500			44		11	0.3	0	4.5	1.0
75	23	04	EA-5700			44		11	0.9	0	4.5	1.0
75	23	04	EA-5900			44		11	0.3	0	4.5	1.0
75	23	04	EA-6100			44		11	0.9	0	4.5	1.0
75	23	04	EA-6300			44		11	0.3	0	4.5	1.0
75	23	04	EA-6500			44		11	0.9	0	4.5	1.0
75	23	04	EA-6700			44		11	0.3	0	4.5	1.0
75	23	04	EA-6900			44		11	0.9	0	4.5	1.0
75	23	04	EA-7100			44		11	0.3	0	4.5	1.0
75	23	04	EA-7300			44		11	0.9	0	4.5	1.0
75	23	04	EA-7500			44		11	0.3	0	4.5	1.0
75	23	04	EA-7700			44		11	0.9	0	4.5	1.0
75	23	04	EA-7900			44		11	0.3	0	4.5	1.0
75	23	04	EA-8100			44		11	0.9	0	4.5	1.0
75	23	04	EA-8300			44		11	0.3	0	4.5	1.0
75	23	04	EA-8500			44		11	0.9	0	4.5	1.0
75	23	04	EA-8700			44		11	0.3	0	4.5	1.0
75	23	04	EA-8900			44		11	0.9	0	4.5	1.0
75	23	04	EA-9100			44		11	0.3	0	4.5	1.0
75	23	04	EA-9300			44		11	0.9	0	4.5	1.0
75	23	04	EA-9500			44		11	0.3	0	4.5	1.0
75	23	04	EA-9700			44		11	0.9	0	4.5	1.0
75	23	04	EA-9900			44		11	0.3	0	4.5	1.0
75	23	04	EA-10100			44		11	0.9	0	4.5	1.0
75	23	04	EA-10300			44		11	0.3	0	4.5	1.0
75	23	04	EA-10500			44		11	0.9	0	4.5	1.0
75	23	04	EA-10700			44		11	0.3	0	4.5	1.0
75	23	04	EA-10900			44		11	0.9	0	4.5	1.0
75	23	04	EA-11100			44		11	0.3	0	4.5	1.0
75	23	04	EA-11300			44		11	0.9	0	4.5	1.0
75	23	04	EA-11500			44		11	0.3	0	4.5	1.0
75	23	04	EA-11700			44		11	0.9	0	4.5	1.0
75	23	04	EA-11900			44		11	0.3	0	4.5	1.0
75	23	04	EA-12100			44		11	0.9	0	4.5	1.0
75	23	04	EA-12300			44		11	0.3	0	4.5	1.0
75	23	04	EA-12500			44		11	0.9	0	4.5	1.0
75	23	04	EA-12700			44		11	0.3	0	4.5	1.0
75	23	04	EA-12900			44		11	0.9	0	4.5	1.0
75	23	04	EA-13100			44		11	0.3	0	4.5	1.0
75	23	04	EA-13300			44		11	0.9	0	4.5	1.0
75	23	04	EA-13500			44		11	0.3	0	4.5	1.0
75	23	04	EA-13700			44		11	0.9	0	4.5	1.0
75	23	04	EA-13900			44		11	0.3	0	4.5	1.0
75	23	04	EA-14100			44		11	0.9	0	4.5	1.0
75	23	04	EA-14300			44		11	0.3	0	4.5	1.0
75	23	04	EA-14500			44		11	0.9	0	4.5	1.0
75	23	04	EA-14700			44		11	0.3	0	4.5	1.0
75	23	04	EA-14900			44		11	0.9	0	4.5	1.0
75	23	04	EA-15100			44		11	0.3	0	4.5	1.0
75	23	04	EA-15300			44		11	0.9	0	4.5	1.0
75	23	04	EA-15500			44		11	0.3	0	4.5	1.0
75	23	04	EA-15700			44		11	0.9	0	4.5	1.0
75	23	04	EA-15900			44		11	0.3	0	4.5	1.0
75	23	04	EA-16100			44		11	0.9	0	4.5	1.0
75	23	04	EA-16300			44		11	0.3	0	4.5	1.0
75	23	04	EA-16500			44		11	0.9	0	4.5	1.0
75	23	04	EA-16700			44		11	0.3	0	4.5	1.0
75	23	04										

ANALYSES

YEAR	DAY	MON	DESIGNATION	SAMPLE		COD	BOD	FOC	NH3N	NO2N	NO3N	TKN
				UNFILTERED	FILTERED							
75	27	05	EA-1500			47		19	0.4	3.7	17.3	2.9
75	27	05	EA-1800			55		17	0.5	7.5	18.0	4.8
75	27	05	EA-2100			53		17	2.2	16.7	14.5	8.8
75	27	05	EA-2300			84		36	5.3	4.0	13.0	6.2
75	28	05	EA-0600			40		20	1.0	3.3	11.0	3.8
75	28	05	EA-0900			65		19	1.3	3.3	13.9	2.2
75	28	05	EA-1500			50		22	1.6	1.8	15.8	3.6
75	28	05	EA-1800			62		27	0.5	1.9	12.0	2.9
75	28	05	EA-2100			55		17	1.0	3.4	13.5	1.1
75	28	05	EA-2400			62		27	1.6	1.9	12.0	2.9
75	29	05	EA-0600			57		19	0.9	3.7	13.9	2.2
75	29	05	EA-0900			44		16	1.0	3.2	15.3	1.2
75	29	05	EA-1200			46		15	0.8	5.0	17.8	2.2
75	29	05	EA-1500			47		15	1.0	2.0	15.3	1.2
75	29	05	EA-1800			43		15	1.1	2.7	18.8	2.2
75	29	05	EA-2100			55		17	1.1	3.4	15.3	1.2
75	29	05	EA-2300			51		17	0.5	1.9	11.0	2.2
75	30	05	EA-0600			45		14	1.9	3.8	17.7	1.4
75	30	05	EA-0900			66		24	0.3	1.2	11.0	2.2
75	30	05	EA-1200			66		24	0.8	5.0	17.8	2.2
75	30	05	EA-1500			66		24	1.0	3.2	15.3	1.2
75	30	05	EA-1800			66		24	1.1	3.4	15.3	1.2
75	30	05	EA-2100			66		24	1.1	3.4	15.3	1.2
75	30	05	EA-2300			66		24	1.1	3.4	15.3	1.2
75	02	06	MLA-C	70	11	70	5.9	19				
75	03	06	MLA-C	80	12	80	17.5	15				
75	04	06	MLA-C	69	10	69	29.3	13				
75	05	06	MLA-C	76	11	76	10.0	15				
75	06	06	MLA-C			40	26.0	26	14.4	3.6	11.4	15.6
75	07	06	MLA-C			40	26.0	26	0.0	4.6	9.4	27.1
75	08	06	MLA-C			40	21.0	21	0.0	4.1	10.3	22.9
75	09	06	MLA-C			77	37.4	34	3.7	6.0	7.3	4.6
75	10	06	MLA-C			39	24.5	24	4.5	2.2	7.3	4.1
75	11	06	MLA-C			44	44.4	43	3.0	5.5	10.2	5.4
75	12	06	MLA-C			44	44.4	43	4.0	1.8	10.2	5.4
75	13	06	MLA-C			44	35.1	33	3.4	0.0	9.9	4.3
75	14	06	MLA-C			44	42.8	41	2.7	6.8	10.6	5.0
75	15	06	MLA-C			38	28.9	28	1.5	4.7	11.5	3.8
75	16	06	MLA-C			29	12.6	11	0.9	1.5	11.5	2.9
75	17	06	MLA-C			47	37.9	36	1.7	1.5	11.5	3.8
75	18	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	19	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	20	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	21	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	22	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	23	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	24	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	25	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	26	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	27	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	28	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	29	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9
75	30	06	MLA-C			44	44.4	43	1.7	4.9	11.5	2.9

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD	BOD	UNFILTERED TKN	COD	BOD	FILTERED	NH3N	N02N	N03N	TKN
75	03	07	EA-1700	45			45		12	0.5	0.9	14.1	1.2
75	03	07	EA-1900	45			45		13	0.6	1.5	14.5	1.0
75	03	07	EA-2100	44			44		12	0.7	3.7	14.7	1.5
75	03	07	EA-2300	44			44		11	0.6	3.1	13.4	1.1
75	04	07	EA-0300	44			44		11	0.5	3.6	12.6	1.1
75	04	07	EA-0500	44			44		14	0.5	4.5	11.5	1.0
75	04	07	EA-0700	44			44		14	0.5	5.5	11.5	1.0
75	09	11	EBB1-0900	34	120.0	12.3	34	12.3	18	11.0	4.5	13.8	1.6
75	09	11	EBB1-1200	35	183.0	26.0	35	26.0	15	15.6	4.5	13.8	1.6
75	09	11	EBB1-1045	40	79.6	5	40	5	18	15.0	1.2	13.9	1.1
75	11	14	EBB1-1100	53			53		16	11.0	0.1	12.7	1.1
75	11	14	MLB1-C	46	141.0	11.0	46	11.0	15	11.0	0.2	2.0	11.0
75	11	15	MLB1-C	94	992.0	426	94	426	19	14.2	0.1	2.7	14.2
75	11	15	MLB1-C	44	313.0		44		13	14.3	0.1	1.2	14.3
75	12	01	MLB1-C	81	81.1		81		18	14.3	0.1	2.2	14.3
75	12	01	MLB1-C	57	57.9		57		16	14.0	0.2	1.1	14.0
75	12	01	MLB1-C	119	119.0		119		16	10.4	0.2	1.6	10.4
75	12	01	MLB1-C	45	45.0		45		16	10.4	0.1	3.4	4.9
75	12	01	MLB1-C	87	87.2		87		9	10.5	0.1	0.6	10.5
75	12	01	MLB1-C	62	62.4		62		19	11.8	0.4	1.2	11.8
75	12	01	MLB1-C	45	45.0		45		7	6.2	0.2	2.5	6.3
75	12	01	MLB1-C	59	59.0		59		7	12.0	0.2	1.5	12.0
75	12	01	MLB1-C	76	76.0		76		9	15.7	0.2	3.6	13.9
75	12	01	MLB1-C	101	101.2		101		11	12.9	0.2	0.7	11.6
75	12	01	MLB1-C	99	99.0		99		8	11.1	0.2	1.1	11.1
75	12	01	MLB1-C	94	94.0		94		8	11.0	0.1	1.9	11.0
75	12	01	MLB1-C	202	202.5		202		6	11.8	0.1	1.1	11.8
75	12	01	MLB1-C	58	58.4		58		11	8.0	0.2	2.0	8.2
75	12	01	MLB1-C	57	57.6		57		11	15.0	0.2	1.9	15.1
75	12	01	MLB1-C	76	76.6		76		11	19.0	0.2	0.8	19.0

ANALYSES

YEAR	DAY	MON	SAMPLE SIGNATION	COD	BOD	UNFILTERED TKN	COD	300	FOC	NH3N	NO2N	NO3N	TKN
74	25	03	MLB1-GAM	87	22	170.0	45	10	18	20.2	0.2	2.7	20.2
74	25	03	ED1-C	107	30	20.9	49	13	15	24.3	0.7	8.0	24.3
74	03	04	MLB1-GAM			145.0	33	6	10	20.6	0.6	2.9	20.6
74	05	04	MLB1-GAM			21.8							
74	05	04	MLB1-GAM			110.0							
74	05	04	EB1-C	57	9	20.7							
74	05	04	EB1-C			109/04/74							
74	09	04	UNFILTERED SAMPLE (09/04/74) TO SAMPLER BREAKDOWN			5.0							
74	09	04	MLB1-1500			140.0							
74	09	04	MLB1-C1	77	14	8.2	53	10	13	7.9	1.5	3.5	7.9
74	09	04	EB1-C2	69	9	30.3	49	7	8	20.4	1.7	3.4	20.4
74	09	04	EB1-C3	73	13	33.3	49	4	10	28.4	1.4	2.2	28.4
74	09	04	EB1-C4	77	11	33.3	53	4	13	31.0	1.3	2.2	31.0
74	09	04	EB1-C5	61	11	31.5	44	4	14	28.1	1.3	1.8	28.1
74	09	04	EB1-C6	61	11	36.6	44	4	15	28.7	1.3	1.8	28.7
74	09	04	EB1-C8			129.0	49	4	17	23.0	1.1	13.9	23.0
74	09	04	EB1-C			179.0			20	13.0	1.1	13.9	13.0
74	09	04	MLB1-0900			152.0							
74	10	00	MLB1-1500			28.0	33	4	3	19.4	1.2	3.5	19.4
74	10	00	MLB1-C1	49	7	28.0	33	3	8	25.6	1.8	6.3	25.6
74	10	00	EB1-C2	59	10	28.0	33	5	8	28.6	1.5	6.3	28.6
74	10	00	EB1-C3	61	10	28.0	33	7	11	28.7	1.6	3.1	28.7
74	10	00	EB1-C4	67	11	28.0	33	4	11	27.9	1.6	2.2	27.9
74	10	00	EB1-C5	33	16	28.0	33	6	12	25.9	1.8	1.4	25.9
74	10	00	EB1-C6	55	8	28.0	33	6	11	24.8	1.7	2.6	24.8
74	10	00	EB1-C8			27.0			10	26.0	1.7	2.6	26.0
74	10	00	EB1-C			27.0			10	26.0	1.7	2.6	26.0
74	10	00	MLB1-C-GAM			17.0	52	12	15	12.7	0.6	1.2	12.7
74	10	00	EB1-C-GAM	115	31	17.0							
74	10	00	MLB1-C-GAM	173	11	26.0	48	13	13	20.9	0.4	1.8	20.9
74	10	00	EB1-C-GAM	72	24	23.0	52	8	12	20.9	0.4	1.5	20.9
74	10	00	MLB1-C-GAM	84	24	23.0	64	14	18	23.8	0.5	1.8	23.8
74	10	00	EB1-C			25.0							
74	10	00	MLB1-1500			25.0							
74	10	00	MLB1-C1	69	7	25.0	36	3	9	28.9	0.2	3.8	28.9
74	10	00	EB1-C2	56	10	25.0	44	3	9	26.9	0.2	2.4	26.9
74	10	00	EB1-C3	76	11	25.0	45	4	12	29.1	0.2	0.7	29.1
74	10	00	EB1-C4	76	11	25.0	55	4	13	28.7	0.2	1.4	28.7
74	10	00	EB1-C5	64	9	25.0	56	4	13	27.6	0.2	1.4	27.6
74	10	00	EB1-C6	76	11	25.0	58	4	15	25.6	0.2	1.4	25.6
74	10	00	EB1-C7	64	9	25.0	45	2	11	25.4	0.2	1.4	25.4
74	10	00	EB1-C8			25.0			11	23.0	0.2	1.4	23.0
74	10	00	EB1-C			25.0			11	23.0	0.2	1.4	23.0

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD	BOD	UNFILTERED TKN	COD	BOD	FOC	NH3N	NO2N	NO3N	TKN
74	01	05	MLB1-0900	44	39	113.0	25	38	10	31.4	2.6	4.2	31.4
74	01	05	MLB1-1500	51	39	136.0	38	38	10	30.6	3.8	3.8	40.7
74	01	05	EB1-C9	55	40	42.9	33	40	13	48.8	2.0	2.5	48.0
74	01	05	EB1-C11	55	38	52.4	46	33	18	48.8	2.0	1.0	45.0
74	01	05	EB1-C12	108	33	43.8	42	34	17	45.2	1.3	0.0	45.2
74	02	05	EB1-C13	57	22	47.8	42	38	11	43.4	0.3	0.1	43.5
74	02	05	EB1-C14	67	22	44.7	34	34	15	43.4	0.3	0.5	43.4
74	02	05	EB1-C15	71	26	41.1	34	42	15	43.4	0.3	0.5	43.4
74	02	05	EB1-C16	68	35	41.4	34	42	13	43.4	0.3	0.5	43.4
74	04	05	EB1-C	29	11	49.8	32	42	10	28.5	1.8	1.1	28.5
74	14	05	MLB1-GAM	65	17	30.0	34	50	14	27.4	0.5	4.0	27.4
74	16	05	MLB1-GAM	129	38	116.7	38	17	20	12.8	0.5	3.6	12.8
74	22	05	EB1-C	132	37	17.0	38	3	14	9.6	0.7	7.7	9.6
74	22	05	EB1-C	151	24	13.0	62	41	26	19.3	0.2	1.6	19.3
74	23	05	EB1-C	151	43	18.7	65	20	26	20.0	0.2	1.2	20.0
74	24	06	EB1-C	102	14	13.0	78	9	17	25.7	0.0	0.2	25.7
74	06	06	MLB1-GAM	67	7	20.7	35	5	13	16.1	0.3	1.1	16.1
74	06	06	MLB1-GAM	61	12	20.7	42	7	14	15.8	0.4	1.0	15.8
74	06	06	EB1-C	38	6	17.0	31	5	9	16.8	2.4	5.2	16.8
74	06	06	MLB1-GAM	95	15	17.0	54	6	16	26.7	0.5	1.5	26.7
74	06	06	EB1-C	79	10	20.3	50	8	19	25.2	1.3	2.1	25.2
74	07	07	MLB1-GAM	84	16	16.9	42	10	27	30.4	0.3	0.7	30.4
74	07	07	EB1-C	232	93	20.4	68	24	29	14.7	0.0	0.7	14.7
74	10	07	MLB1-GAM	203	64	20.7	72	27	28	16.2	0.0	0.6	16.2
74	12	07	EB1-C	102	30	29.3	97	18	20	27.5	0.1	0.5	27.6
74	16	07	MLB1-GAM	148	29	30.0	51	11	18	27.0	0.1	0.4	27.0
74	18	07	EB1-C	110	27	30.0	55	15	14	24.0	0.1	0.2	25.0
74	22	07	MLB1-GAM	75	16	17.6	42	9	16	41.0	0.5	4.0	44.8
74	30	07	EB1-C	198.7	16	198.7	42	9	16	41.0	0.5	4.0	44.8

ANALYSES

- YEAR	DAY	MON	SAMPLE DESIGNATION	COD	UNFILTERED TKN	COD	300 FOC	FILTERED NH3N	NO2N	NO3N	TKN	
74	06	08	EB11-C	52	33.3	24	7	15	29.5	0.7	1.9	31.8
74	08	08	MLB11-GAM	60	196.0	24	10	18	34.9	0.5	1.0	34.9
74	08	08	EB11-C	36	37.0	24	4	13	27.0	2.7	5.8	28.6
74	13	08	MLB11-GAM	53	29.6	33	4	11	28.5	3.2	4.9	30.5
74	15	08	EB11-C	74	13.0	53	20	22	22.0	0.1	0.2	22.3
74	20	08	MLB11-GAM	86	18.0	37	12	22	31.0	0.2	1.4	33.6
74	22	08	EB11-C	160	27.0	49	20	22	18.0	0.1	0.1	24.0
74	22	08	MLB11-GAM	50	185.0	33	6	15	45.0	0.2	0.9	45.2
74	29	09	EB11-C	58	47.0	41	5	26	44.6	0.3	1.8	44.6
74	06	09	MLB11-GAM	59	27.0	45	5	18	48.0	1.0	0.1	51.1
74	10	09	EB11-C	127	52.0	39	5	16	42.5	0.3	1.2	42.5
74	12	09	MLB11-GAM	77	47.0	53	7	21	40.3	0.0	1.0	40.3
74	17	09	EB11-C	109	46.0	40	4	15	40.0	0.1	5.9	40.0
74	19	09	MLB11-GAM	69	44.0	46	12	20	39.0	0.1	1.3	39.5
74	25	09	EB11-C	159	37.0	51	18	29	21.0	0.1	0.5	21.8
74	27	09	MLB11-GPM	144	42.0	38	13	25	23.5	0.2	0.8	24.0
74	27	09	EB11-C	160	27.0	99	20	32	24.5	0.1	0.8	25.9
74	03	10	MLB11-GAM	445	263.0	48	10	24	40.8	0.2	0.2	40.8
74	08	10	EB11-C	74	287.0	44	5	23	38.0	0.0	1.1	41.8
74	18	10	MLB11-GAM	71	328.0	42	6	20	40.5	0.4	2.3	43.8
74	25	10	EB11-C	76	44.0	38	8	24	51.5	0.3	3.0	52.8
74	28	10	MLB11-GAM	67	54.0	46	10	16	49.5	0.2	3.3	53.9
74	04	11	EB11-C	70	205.0	49	6	16	66.0	0.7	3.9	75.5
74	05	11	MLB11-GAM	53	176.0	41	5	14	68.0	0.6	11.2	68.3
74	05	11	EB11-C		202.0							
74	13	11	MLB11-GAM		234.0							

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	CGO	UNFILTERED YKN	COD	BOD	FOC	NH3N	NO2N	NO3N	TKN
74	25	11	EB1-C	87	36.5	41	10	15	21.0	0.2	2.7	32.2
74	25	11	ML01-C	21	92.0							
74	27	11	EB1-C	91	35.8	41	17	28	28.0	0.1	3.0	32.5
74	27	11	ML01-C	46	177.0							
75	10	12	EB1-C	168	27.4	64	16	25	15.0	0.2	3.3	21.9
75	10	12	MLSS	TAKEN								
75	10	12	EB1-C	106	33.7	64	9	21	32.0	0.4	13.3	32.0
75	20	02	ML01-C	19	150.0							
75	26	02	EB1-C	95	34.8	67	10	19	32.0	0.6	14.4	32.9
75	26	02	ML31-C	16	1300	1600	HRS DUE TO SAMPLER ERROR					
75	03	02	EB1-C	148	45.0	58	8	20	13.0	0.7	9.3	16.0
75	03	02	ML01-C	26	19.0							
75	04	03	EB1-C	183	28.0	71	13	20	14.0	0.6	3.3	19.0
75	04	03	ML01-C	33	24.0							
75	05	03	EB1-C	221	20.9	58	20	26	16.0	0.5	1.7	18.5
75	05	03	MLA-G	42	25.9							
75	06	03	NO MLSS	TAKEN	104.0							
75	07	03	EB1-C	43	25.8	58	16	24	15.0	0.5	0.9	19.7
75	07	03	ML01-C	218	30.0	67	17	23	16.0	0.4	1.4	18.1
75	08	03	ML01-C	42	30.0							
75	03	03	EB1-C	163	13.0	5	16	3	13.0	0.0	4.0	0.3
75	03	03	ML01-C	28	17.0	6	7	1	17.0	0.0	1.0	14.0
75	03	03	EB1-C	76	15.0	7	8	1	15.0	0.0	1.7	18.6
75	03	03	ML01-C	43	12.0	6	7	0	12.0	0.0	1.5	9.6
75	04	03	EB1-C	65	11.0	5	6	1	11.0	0.0	1.4	11.8
75	04	03	ML01-C	47	13.0	6	7	0	13.0	0.0	1.7	14.8
75	04	03	EB1-C	67	19.0	7	8	7	19.0	0.0	2.5	20.5
75	04	03	ML01-C	72	17.0	6	7	7	17.0	0.0	2.1	19.0
75	04	03	EB1-C	65	16.0	7	8	6	16.0	0.0	2.6	20.0
75	04	03	ML01-C	47	14.0	6	7	4	14.0	0.0	3.9	17.3
75	05	03	EB1-C	44	13.0	5	4	3	13.0	0.0	4.1	17.9
75	05	03	ML01-C	57	15.0	6	5	4	15.0	0.0	5.5	20.3
75	05	03	EB1-C	61	17.0	7	8	4	17.0	0.0	4.4	21.6
75	05	03	ML01-C	70	16.0	8	9	4	16.0	0.0	4.4	20.3
75	05	03	EB1-C	68	15.0	7	8	3	15.0	0.0	4.4	19.2
75	06	03	ML01-C	55	12.0	6	5	3	12.0	0.0	3.3	15.1

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD BOD	UNFILTERED TKY	COD	BOD	FOC	NH3N	NO2N	NO3N	TKN
75	06	03	EB1-1500			9			17.0	0.4	1.4	17.9
75	06	03	EB1-1800			26			19.0	0.6	1.3	20.3
75	06	03	EB1-2100			27			15.0	0.5	0.8	16.3
75	06	03	EB1-0300			47			14.0	0.4	0.6	16.3
75	06	03	EB1-0600			54			13.0	0.3	0.8	13.8
75	06	03	EB1-0900			44			18.0	0.5	0.6	18.6
75	06	03	EB1-1200			53			16.0	0.4	0.8	17.3
75	06	03	EB1-1500			100			17.0	0.4	0.8	17.4
75	06	03	EB1-1800			60			16.0	0.3	0.8	16.7
75	06	03	EB1-2100			66			17.0	0.4	0.8	17.4
75	06	03	EB1-0600			55	8	20	17.0	0.4	0.7	18.6
75	06	03	EB1-0900		22.0	65	19	28	15.0	0.3	1.4	19.6
75	06	03	EB1-1200		27.0	64	26	28	15.0	0.2	0.7	17.1
75	06	03	EB1-1500		25.0	74	21	25	17.0	0.3	1.2	18.9
75	06	03	EB1-1800		24.0	60	6	18	13.3	0.3	1.7	15.7
75	06	03	EB1-2100		48.0	49	7	17	11.7	0.3	3.5	13.3
75	06	03	EB1-0300		38.0	57	9	21	11.9	0.4	3.2	13.1
75	06	03	EB1-0600		17.0	45	10	21	12.3	0.6	3.3	14.2
75	06	03	EB1-0900		38.0	40	7	11	6.9	0.0	0.0	8.5
75	06	03	EB1-1200		25.0	48	4	11	12.0	0.0	0.2	14.0
75	06	03	EB1-1500		24.0	48	4	11	18.0	0.0	0.2	20.5
75	06	03	EB1-1800		21.0	75	5	11	20.0	0.0	1.1	22.3
75	06	03	EB1-2100		17.0	69	5	11	12.0	0.0	0.6	13.6
75	06	03	EB1-0300		15.0	55	3	11	3.8	0.0	1.1	4.9
75	06	03	EB1-0600		15.0	49	4	11	15.0	0.0	1.4	16.5
75	06	03	EB1-0900		14.0	67	5	11	19.0	0.0	1.6	21.6
75	06	03	EB1-1200		15.0	49	4	11	15.0	0.0	1.2	16.2
75	06	03	EB1-1500		12.0	67	5	11	18.0	0.0	1.4	19.4
75	06	03	EB1-1800		14.0	65	4	11	13.0	0.0	1.0	14.0
75	06	03	EB1-2100		36.0	132	3	11	13.0	0.0	0.0	15.4
75	06	03	EB1-0300		19.0	103	3	11	11.0	0.0	0.0	11.0
75	06	03	EB1-0600		38.0	93	3	11	11.0	0.0	0.0	11.0
75	06	03	EB1-0900		17.0	128	3	11	11.0	0.0	0.0	11.0
75	06	03	EB1-1200		19.0	132	3	11	11.0	0.0	0.0	11.0
75	06	03	EB1-1500		19.0	132	3	11	11.0	0.0	0.0	11.0
75	06	03	EB1-1800		19.0	132	3	11	11.0	0.0	0.0	11.0
75	06	03	EB1-2100		19.0	132	3	11	11.0	0.0	0.0	11.0

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED	FILTERED	COD	800 FOC	NH3N	NO2N	NO3N	TKN
75	13	3	EB1-1200	52	7	42		12.7	0.4	1.2	14.3
75	13	3	EB1-1500	92	17	44		15.0	0.4	1.8	19.3
75	13	3	EB1-1800	86	16	62		17.0	1.3	2.5	21.9
75	13	3	EB1-2100	97	13	82		17.0	1.3	2.5	21.9
75	14	4	EB1-0300			74		15.0	1.2	1.8	18.0
75	14	4	EB1-0600			45		13.4	1.2	1.8	17.4
75	14	4	EB1-0900			51		15.4	2.3	1.7	19.3
75	14	4	EB1-1200			51		15.4	2.3	1.7	19.3
75	14	4	EB1-1500			51		15.4	2.3	1.7	19.3
75	14	4	EB1-1800			78		18.0	3.4	1.0	23.8
75	14	4	EB1-2100			90		22.4	0.0	1.0	23.4
75	15	5	EB1-0300			75		17.0	0.2	1.1	18.3
75	15	5	EB1-0600			64		17.0	0.2	1.1	18.3
75	15	5	EB1-0900			47		17.0	0.2	1.1	18.3
75	15	5	EB1-1200			43		17.0	0.2	1.1	18.3
75	15	5	EB1-1500			48		17.0	0.2	1.1	18.3
75	15	5	EB1-1800			55		19.0	0.4	1.3	20.7
75	15	5	EB1-2100			58		16.0	0.5	1.3	17.8
75	16	6	EB1-0300			55		16.0	0.5	1.3	17.8
75	16	6	EB1-0600			59		16.0	0.5	1.3	17.8
75	16	6	EB1-0900			55		16.0	0.5	1.3	17.8
75	16	6	EB1-1200			43		16.0	0.5	1.3	17.8
75	16	6	EB1-1500			55		16.0	0.5	1.3	17.8
75	16	6	EB1-1800			55		16.0	0.5	1.3	17.8
75	16	6	EB1-2100			55		16.0	0.5	1.3	17.8
75	17	7	EB1-0300			47		17.0	0.7	2.3	20.0
75	17	7	EB1-0600			37		7.0	0.5	1.3	9.8
75	17	7	EB1-0900			29		8.0	0.4	1.2	10.6
75	17	7	EB1-1200			26		8.0	0.4	1.2	10.6
75	17	7	EB1-1500			26		8.0	0.4	1.2	10.6
75	17	7	EB1-1800			26		8.0	0.4	1.2	10.6
75	17	7	EB1-2100			26		8.0	0.4	1.2	10.6
75	18	8	EB1-0300			26		8.0	0.4	1.2	10.6
75	18	8	EB1-0600			26		8.0	0.4	1.2	10.6
75	18	8	EB1-0900			26		8.0	0.4	1.2	10.6
75	18	8	EB1-1200			26		8.0	0.4	1.2	10.6
75	18	8	EB1-1500			26		8.0	0.4	1.2	10.6
75	18	8	EB1-1800			26		8.0	0.4	1.2	10.6
75	18	8	EB1-2100			26		8.0	0.4	1.2	10.6
75	19	9	EB1-0300			44		17.0	0.6	2.9	20.5
75	19	9	EB1-0600			41		17.0	0.6	2.9	20.5
75	19	9	EB1-0900			47		17.0	0.6	2.9	20.5
75	19	9	EB1-1200			37		7.0	0.5	1.3	9.8
75	19	9	EB1-1500			29		8.0	0.4	1.2	10.6
75	19	9	EB1-1800			26		8.0	0.4	1.2	10.6
75	19	9	EB1-2100			26		8.0	0.4	1.2	10.6
75	20	10	EB1-0300			26		8.0	0.4	1.2	10.6
75	20	10	EB1-0600			26		8.0	0.4	1.2	10.6
75	20	10	EB1-0900			26		8.0	0.4	1.2	10.6
75	20	10	EB1-1200			26		8.0	0.4	1.2	10.6
75	20	10	EB1-1500			26		8.0	0.4	1.2	10.6
75	20	10	EB1-1800			26		8.0	0.4	1.2	10.6
75	20	10	EB1-2100			26		8.0	0.4	1.2	10.6
75	21	11	EB1-0300			44		17.0	0.6	2.9	20.5
75	21	11	EB1-0600			41		17.0	0.6	2.9	20.5
75	21	11	EB1-0900			47		17.0	0.6	2.9	20.5
75	21	11	EB1-1200			37		7.0	0.5	1.3	9.8
75	21	11	EB1-1500			29		8.0	0.4	1.2	10.6
75	21	11	EB1-1800			26		8.0	0.4	1.2	10.6
75	21	11	EB1-2100			26		8.0	0.4	1.2	10.6
75	22	12	EB1-0300			44		17.0	0.6	2.9	20.5
75	22	12	EB1-0600			41		17.0	0.6	2.9	20.5
75	22	12	EB1-0900			47		17.0	0.6	2.9	20.5
75	22	12	EB1-1200			37		7.0	0.5	1.3	9.8
75	22	12	EB1-1500			29		8.0	0.4	1.2	10.6
75	22	12	EB1-1800			26		8.0	0.4	1.2	10.6
75	22	12	EB1-2100			26		8.0	0.4	1.2	10.6
75	23	13	EB1-0300			44		17.0	0.6	2.9	20.5
75	23	13	EB1-0600			41		17.0	0.6	2.9	20.5
75	23	13	EB1-0900			47		17.0	0.6	2.9	20.5
75	23	13	EB1-1200			37		7.0	0.5	1.3	9.8
75	23	13	EB1-1500			29		8.0	0.4	1.2	10.6
75	23	13	EB1-1800			26		8.0	0.4	1.2	10.6
75	23	13	EB1-2100			26		8.0	0.4	1.2	10.6
75	24	14	EB1-0300			44		17.0	0.6	2.9	20.5
75	24	14	EB1-0600			41		17.0	0.6	2.9	20.5
75	24	14	EB1-0900			47		17.0	0.6	2.9	20.5
75	24	14	EB1-1200			37		7.0	0.5	1.3	9.8
75	24	14	EB1-1500			29		8.0	0.4	1.2	10.6
75	24	14	EB1-1800			26		8.0	0.4	1.2	10.6
75	24	14	EB1-2100			26		8.0	0.4	1.2	10.6
75	25	15	EB1-0300			44		17.0	0.6	2.9	20.5
75	25	15	EB1-0600			41		17.0	0.6	2.9	20.5
75	25	15	EB1-0900			47		17.0	0.6	2.9	20.5
75	25	15	EB1-1200			37		7.0	0.5	1.3	9.8
75	25	15	EB1-1500			29		8.0	0.4	1.2	10.6
75	25	15	EB1-1800			26		8.0	0.4	1.2	10.6
75	25	15	EB1-2100			26		8.0	0.4	1.2	10.6
75	26	16	EB1-0300			44		17.0	0.6	2.9	20.5
75	26	16	EB1-0600			41		17.0	0.6	2.9	20.5
75	26	16	EB1-0900			47		17.0	0.6	2.9	20.5
75	26	16	EB1-1200			37		7.0	0.5	1.3	9.8
75	26	16	EB1-1500			29		8.0	0.4	1.2	10.6
75	26	16	EB1-1800			26		8.0	0.4	1.2	10.6
75	26	16	EB1-2100			26		8.0	0.4	1.2	10.6
75	27	17	EB1-0300			44		17.0	0.6	2.9	20.5
75	27	17	EB1-0600			41		17.0	0.6	2.9	20.5
75	27	17	EB1-0900			47		17.0	0.6	2.9	20.5
75	27	17	EB1-1200			37		7.0	0.5	1.3	9.8
75	27	17	EB1-1500			29		8.0	0.4	1.2	10.6
75	27	17	EB1-1800			26		8.0	0.4	1.2	10.6
75	27	17	EB1-2100			26		8.0	0.4	1.2	10.6
75	28	18	EB1-0300			44		17.0	0.6	2.9	20.5
75	28	18	EB1-0600			41		17.0	0.6	2.9	20.5
75	28	18	EB1-0900			47		17.0	0.6	2.9	20.5
75	28	18	EB1-1200			37		7.0	0.5	1.3	9.8
75	28	18	EB1-1500			29		8.0	0.4	1.2	10.6
75	28	18	EB1-1800			26		8.0	0.4	1.2	10.6
75	28	18	EB1-2100			26		8.0	0.4	1.2	10.6
75	29	19	EB1-0300			44		17.0	0.6	2.9	20.5
75	29	19	EB1-0600			41		17.0	0.6	2.9	20.5
75	29	19	EB1-0900			47		17.0	0.6	2.9	20.5
75	29	19	EB1-1200			37		7.0	0.5	1.3	9.8
75	29	19	EB1-1500			29		8.0	0.4	1.2	10.6
75	29	19	EB1-1800			26		8.0	0.4	1.2	10.6
75	29	19	EB1-2100			26		8.0	0.4	1.2	10.6
75	30	20	EB1-0300			44		17.0	0.6	2.9	20.5
75	30	20	EB1-0600			41		17.0	0.6	2.9	20.5
75	30	20	EB1-0900			47		17.0	0.6	2.9	20.5
75	30	20	EB1-1200			37		7.0	0.5	1.3	9.8
75	30	20	EB1-1500			29		8.0	0.4	1.2	10.6
75	30	20	EB1-1800			26		8.0	0.4	1.2	10.6
75	30	20	EB1-2100			26		8.0	0.4	1.2	10.6
75	31	21	EB1-0300			44		17.0	0.6	2.9	20.5
75	31	21	EB1-0600			41		17.0	0.6	2.9	20.5
75	31	21	EB1-0900			47		17.0	0.6	2.9	20.5
75	31	21	EB1-1200			37		7.0	0.5	1.3	9.8
75	31	21	EB1-1500			29		8.0	0.4	1.2	10.6
75	31	21	EB1-1800			26		8.0	0.4	1.2	10.6
75	31	21	EB1-2100			26		8.0	0.4	1.2	10.6

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD BOD	UNFILTERED IKN	COD	800 FOC	FILTERED NH3N	NO2N	NO3N	IKN
75	26	03	EBR1-0300	79	12	4	1	7.5	0.0	1.9	8.3
75	26	03	EBR1-0600	79	12	4	4	6.9	0.0	1.9	7.6
75	26	03	EBR1-1200	79	12	4	4	5.8	0.0	3.2	5.3
75	26	03	EBR1-1800	79	12	4	4	10.4	0.0	4.3	11.3
75	26	03	EBR1-2400	79	12	4	8	11.9	1.0	1.0	11.5
75	27	03	EBR1-0600	79	12	4	5	5.5	0.0	2.8	11.0
75	27	03	EBR1-0900	79	12	4	7	5.7	0.0	1.0	11.0
75	27	03	EBR1-1200	79	12	4	2	6.6	0.0	2.8	7.8
75	27	03	EBR1-1500	79	12	4	5	10.6	0.0	4.5	11.5
75	27	03	EBR1-2100	79	12	4	5	12.6	0.0	1.3	11.5
75	27	03	EBR1-2300	79	12	4	4	10.6	0.0	1.3	11.5
75	28	03	EBR1-0600	79	12	4	4	5.2	0.0	2.4	11.0
75	29	04	MLR1-0600	79	12	4	5	5.0	0.0	4.5	11.7
75	07	04	MLR1-0600	107	24	73	7	20.7	0.9	4.1	20.7
75	08	04	MLR1-0600	107	24	73	18	20.7	0.9	4.1	20.7
75	09	04	MLR1-0600	64	10	48	7	10.5	0.9	2.9	11.3
75	10	04	MLR1-0600	50	9	45	7	10.9	0.2	3.6	13.9
75	11	04	MLR1-0600	150	12	150	15	7.8	0.0	1.0	32.6
75	11	04	MLR1-0900	48	7	47	8	8.2	1.0	5.5	11.0
75	11	04	MLR1-1200	55	6	55	2	11.5	0.0	3.3	12.6
75	11	04	MLR1-1500	55	6	55	5	4.8	0.0	3.3	11.8
75	11	04	MLR1-1800	55	6	55	6	9.8	0.0	3.3	11.9
75	11	04	MLR1-2100	55	6	55	5	8.4	0.0	3.3	11.8
75	11	04	MLR1-2300	55	6	55	9	4.4	0.0	3.3	11.5
75	11	04	MLR1-0600	43	5	43	5	5.9	0.0	5.2	11.5
75	11	04	MLR1-0900	43	5	43	9	8.2	0.0	5.2	11.5
75	11	04	MLR1-1200	43	5	43	5	5.9	0.0	5.2	11.5
75	11	04	MLR1-1500	43	5	43	7	8.2	0.0	5.2	11.5
75	11	04	MLR1-1800	43	5	43	5	5.9	0.0	5.2	11.5
75	11	04	MLR1-2100	43	5	43	7	8.2	0.0	5.2	11.5
75	11	04	MLR1-2300	43	5	43	5	5.9	0.0	5.2	11.5
75	12	07	MLR1-0600	113	8	113	4	7.9	0.0	0.0	11.7
75	12	07	MLR1-0900	113	8	113	4	7.9	0.0	0.0	11.7
75	12	07	MLR1-1200	113	8	113	4	7.9	0.0	0.0	11.7
75	12	07	MLR1-1500	113	8	113	4	7.9	0.0	0.0	11.7
75	12	07	MLR1-1800	113	8	113	4	7.9	0.0	0.0	11.7
75	12	07	MLR1-2100	113	8	113	4	7.9	0.0	0.0	11.7
75	12	07	MLR1-2300	113	8	113	4	7.9	0.0	0.0	11.7

ANALYSES

YEAR	DAY	MON	SAMPLE SIGNATION	UNFILTERED COD BOD	TKN	COD	BOD	FOC	FILTERED NH3N	NO2N	NO3N	TKN
75	16	04	1900	11	158	0	42	2	18	0	0	3
75	16	04	2300	11	126	0	42	2	17	0	0	3
75	17	04	0300	11	114	0	42	2	19	0	0	3
75	17	04	0500	11	114	0	42	2	23	0	0	3
75	17	04	0700	11	114	0	42	2	23	0	0	3
75	17	04	1100	11	114	0	42	2	23	0	0	3
75	17	04	1300	11	114	0	42	2	23	0	0	3
75	17	04	1500	11	114	0	42	2	23	0	0	3
75	17	04	1700	11	114	0	42	2	23	0	0	3
75	17	04	1900	11	114	0	42	2	23	0	0	3
75	17	04	2300	11	114	0	42	2	23	0	0	3
75	18	04	0300	11	114	0	42	2	23	0	0	3
75	18	04	0500	11	114	0	42	2	23	0	0	3
75	18	04	0700	11	114	0	42	2	23	0	0	3
75	18	04	0900	11	114	0	42	2	23	0	0	3
75	18	04	1100	11	114	0	42	2	23	0	0	3
75	18	04	1300	11	114	0	42	2	23	0	0	3
75	18	04	1500	11	114	0	42	2	23	0	0	3
75	18	04	1700	11	114	0	42	2	23	0	0	3
75	18	04	1900	11	114	0	42	2	23	0	0	3
75	19	04	0300	11	114	0	42	2	23	0	0	3
75	19	04	0500	11	114	0	42	2	23	0	0	3
75	19	04	0700	11	114	0	42	2	23	0	0	3
75	19	04	0900	11	114	0	42	2	23	0	0	3
75	19	04	1100	11	114	0	42	2	23	0	0	3
75	19	04	1300	11	114	0	42	2	23	0	0	3
75	19	04	1500	11	114	0	42	2	23	0	0	3
75	19	04	1700	11	114	0	42	2	23	0	0	3
75	19	04	1900	11	114	0	42	2	23	0	0	3
75	20	04	0300	11	114	0	42	2	23	0	0	3
75	20	04	0500	11	114	0	42	2	23	0	0	3
75	20	04	0700	11	114	0	42	2	23	0	0	3
75	20	04	0900	11	114	0	42	2	23	0	0	3
75	20	04	1100	11	114	0	42	2	23	0	0	3
75	20	04	1300	11	114	0	42	2	23	0	0	3
75	20	04	1500	11	114	0	42	2	23	0	0	3
75	20	04	1700	11	114	0	42	2	23	0	0	3
75	20	04	1900	11	114	0	42	2	23	0	0	3
75	21	04	0300	11	114	0	42	2	23	0	0	3
75	21	04	0500	11	114	0	42	2	23	0	0	3
75	21	04	0700	11	114	0	42	2	23	0	0	3
75	21	04	0900	11	114	0	42	2	23	0	0	3
75	21	04	1100	11	114	0	42	2	23	0	0	3
75	21	04	1300	11	114	0	42	2	23	0	0	3
75	21	04	1500	11	114	0	42	2	23	0	0	3
75	21	04	1700	11	114	0	42	2	23	0	0	3
75	21	04	1900	11	114	0	42	2	23	0	0	3
75	22	04	0300	11	114	0	42	2	23	0	0	3
75	22	04	0500	11	114	0	42	2	23	0	0	3
75	22	04	0700	11	114	0	42	2	23	0	0	3
75	22	04	0900	11	114	0	42	2	23	0	0	3
75	22	04	1100	11	114	0	42	2	23	0	0	3
75	22	04	1300	11	114	0	42	2	23	0	0	3
75	22	04	1500	11	114	0	42	2	23	0	0	3
75	22	04	1700	11	114	0	42	2	23	0	0	3
75	22	04	1900	11	114	0	42	2	23	0	0	3
75	23	04	0300	11	114	0	42	2	23	0	0	3
75	23	04	0500	11	114	0	42	2	23	0	0	3
75	23	04	0700	11	114	0	42	2	23	0	0	3
75	23	04	0900	11	114	0	42	2	23	0	0	3
75	23	04	1100	11	114	0	42	2	23	0	0	3
75	23	04	1300	11	114	0	42	2	23	0	0	3
75	23	04	1500	11	114	0	42	2	23	0	0	3
75	23	04	1700	11	114	0	42	2	23	0	0	3
75	23	04	1900	11	114	0	42	2	23	0	0	3

ANALYSES

YEAR	DAY	MON	SAMPLE	SIGNA	TION	COD	BOD	UNFILTERED	TKN	COD	BOD	FOC	NH3N	M02N	M03N	TKN
75	26	05	81	1	0900	105							19.3	1.0	4.0	21.0
77	26	05	81	1	1200	38						15	12.8	0.9	3.3	13.0
77	26	05	81	1	1800	47						23	22.9	0.2	0.0	23.0
77	26	05	81	1	2400	73						27	29.5	0.0	0.5	28.5
77	27	05	81	1	0900	69						22	17.5	0.0	0.0	18.0
77	27	05	81	1	1200	64						22	17.3	0.0	0.0	18.0
77	27	05	81	1	1800	56						23	13.6	0.0	0.0	13.9
77	27	05	81	1	2400	93						23	13.3	0.0	0.0	13.9
77	28	05	81	1	0900	138						23	11.0	0.0	0.0	11.0
77	28	05	81	1	1200	109						23	7.8	0.0	0.0	7.8
77	28	05	81	1	1800	44						23	7.8	0.0	0.0	7.8
77	28	05	81	1	2400	67						23	11.0	0.0	0.0	11.0
77	29	05	81	1	0900	44						23	11.0	0.0	0.0	11.0
77	29	05	81	1	1200	67						23	11.0	0.0	0.0	11.0
77	29	05	81	1	1800	55						23	11.0	0.0	0.0	11.0
77	29	05	81	1	2400	55						23	11.0	0.0	0.0	11.0
77	30	05	81	1	0900	55						23	11.0	0.0	0.0	11.0
77	30	05	81	1	1200	55						23	11.0	0.0	0.0	11.0
77	30	05	81	1	1800	55						23	11.0	0.0	0.0	11.0
77	30	05	81	1	2400	55						23	11.0	0.0	0.0	11.0
77	31	05	81	1	0900	79						23	11.0	0.0	0.0	11.0
77	31	05	81	1	1200	79						23	11.0	0.0	0.0	11.0
77	31	05	81	1	1800	55						23	11.0	0.0	0.0	11.0
77	31	05	81	1	2400	55						23	11.0	0.0	0.0	11.0
77	31	05	81	1	0900	55						23	11.0	0.0	0.0	11.0
77	31	05	81	1	1200	55						23	11.0	0.0	0.0	11.0
77	31	05	81	1	1800	55						23	11.0	0.0	0.0	11.0
77	31	05	81	1	2400	55						23	11.0	0.0	0.0	11.0
77	01	06	81	1	0900	93						27	34.0	0.7	3.3	36.2
77	01	06	81	1	1200	55						24	44.0	0.3	0.7	46.9
77	01	06	81	1	1800	55						20	36.0	0.2	0.6	36.4
77	01	06	81	1	2400	58						39	15.0	0.5	1.8	16.9
77	02	06	81	1	0900	39						17	12.3	0.0	0.0	13.4
77	02	06	81	1	1200	39						24	18.1	0.0	0.0	19.0
77	02	06	81	1	1800	35						23	19.0	0.0	0.0	20.0
77	02	06	81	1	2400	35						23	17.6	0.0	0.0	18.0
77	03	06	81	1	0900	50						22	16.1	0.0	0.0	17.0
77	03	06	81	1	1200	50						22	15.3	0.0	0.0	16.0
77	03	06	81	1	1800	50						22	15.3	0.0	0.0	16.0
77	03	06	81	1	2400	50						22	15.3	0.0	0.0	16.0

115 27 0.7
 151 30 1.4
 120 25 3.1
 129 25 7.1
 6 66.5

ANALYSES

YEAR	DAY	MON	SAMPLE SIGNATION	COD	BOD	UNFILTERED TKN	FILTERED TKN	COD	800	FOC	RH3N	NO2N	NO3N	TKN
73	9	11	MLB22-GAM	54.4		319.0	7	5.8	0.2	1.5	1.5			6.3
74	2	01	EB22-GAM	50.1		404.5	7	9.9	0.3	1.3	1.3			9.9
74	2	01	MLB22-GAM		35.3	188.9		4.6	0.4	3.9	3.9			4.6
74	2	01	MLB22-GAM		54.6	189.6	9	8.5	0.5	2.1	2.1			8.5
74	3	01	EB22-1900			187.0								
74	3	01	MLB22-1500			167.0								
74	3	01	MLB22-1800			120.8								
74	3	01	MLB22-2100			8.8								
74	3	01	EB22-C1	45.8	24	11.7	4	7.1	0.6	6.2	6.2			7.1
74	3	01	EB22-C2	45.6	14	11.7	4	1.1	0.6	3.8	3.8			1.1
74	3	01	EB22-C3	47.8	3	12.3	3	1.7	0.6	2.2	2.2			1.7
74	3	01	EB22-C4	57.6	2	11.4	3	0.2	0.6	1.9	1.9			0.2
74	3	01	EB22-C5	56.3	2	14.2	2	3.9	0.6	1.3	1.3			3.9
74	3	01	EB22-C6	55.8	2	11.9	2	0.9	0.6	1.8	1.8			0.9
74	3	01	EB22-C7	55.4	2	11.9	2	2.6	0.6	3.0	3.0			2.6
74	3	01	EB22-C8	57.5	1	14.6	1	9.6	0.6	1.2	1.2			9.6
74	4	01	EB22-C9	55.4	1	11.6	4	2.1	0.6	3.0	3.0			2.1
74	4	01	EB22-C10	55.9	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C11	66.7	1	15.4	4	1.6	0.6	3.2	3.2			1.6
74	4	01	EB22-C12	66.7	1	15.4	4	2.2	0.6	3.3	3.3			2.2
74	4	01	EB22-C13	54.4	1	12.5	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C14	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C15	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C16	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C17	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C18	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C19	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C20	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C21	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C22	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C23	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C24	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C25	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C26	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C27	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C28	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C29	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C30	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C31	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C32	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C33	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C34	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C35	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C36	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C37	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C38	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C39	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C40	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C41	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C42	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C43	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C44	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C45	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C46	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C47	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C48	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C49	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C50	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C51	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C52	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C53	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C54	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C55	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C56	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C57	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C58	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C59	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C60	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C61	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C62	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C63	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C64	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C65	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C66	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C67	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C68	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C69	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C70	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C71	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C72	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C73	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C74	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C75	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C76	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C77	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C78	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C79	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C80	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C81	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C82	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C83	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C84	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C85	54.4	1	11.6	4	1.6	0.6	2.2	2.2			1.6
74	4	01	EB22-C86	54.4	1	1								

ANALYSES

YEAR	DAY	MON	SIGNATION	UNFILTERED		FILTERED		COD	BOO	FOC	NH3N	NO2N	NO3N	TKN
				COD	BOO	COD	FOC							
74	11	04	EB2-C4	58	6	41	8	1	3	3	1.2	1.9	30.1	2.0
74	11	04	EB2-C5	58	7	37	2	3	3	10	0.8	1.3	30.7	1.9
74	11	04	EB2-C6	55	5	41	2	2	2	10	0.7	1.2	27.8	1.1
74	11	04	EB2-C7	50	5	37	1	3	3	10	1.3	1.2	27.0	1.1
74	11	04	EB2-C8	50	4	37	6	3	3	13	1.3	1.0	29.0	1.6
74	11	04	MLB2-C	16	4	37	3	3	3	8	1.2	1.4	27.6	1.3
74	16	04	MLB2-C	76	13	36	0	6	6	10	0.4	0.3	9.8	1.3
74	18	04	MLB2-C	44	7	24	19	7	7	9	6.6	0.4	11.7	6.6
74	22	04	MLB2-C	44	6	36	14	4	4	9	1.1	1.0	14.3	2.4
74	22	04	MLB2-C	44	6	36	16	4	4	9	1.1	1.0	14.3	2.4
74	23	04	MLB2-C	40	7	36	14	5	5	9	3.1	3.1	14.8	4.6
74	23	04	MLB2-C	15	7	36	4	5	5	9	3.1	3.1	14.8	4.6
74	30	04	MLB2-1500	47	5	51	14	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-01	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-02	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-03	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-04	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-05	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-06	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-07	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-08	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-09	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-10	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-11	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-12	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-13	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-14	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-15	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-16	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-17	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-18	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-19	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-20	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-21	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-22	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-23	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-24	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-25	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-26	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-27	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-28	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-29	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-30	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-31	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-32	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-33	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-34	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-35	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-36	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-37	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-38	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-39	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-40	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-41	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-42	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-43	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-44	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-45	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-46	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-47	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-48	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-49	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6
74	30	04	MLB2-50	51	5	51	11	5	5	9	0.3	0.1	14.8	4.6

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED TKN	COD	800	FILTERED TKN	COD	800	FOC	NH3N	NO2N	NO3N	TKN
74	13	06	MLB2-C	275.0	82	4	51	10	3	9.8	2.1	18.4	9.8	
74	13	06	EB2-C	9.8	36	4	23	19	3	2.3	1.5	14.0	2.3	
74	18	06	EB2-C	166.4	42	5	31	10	4	1.8	0.5	16.5	1.8	
74	26	06	MLB2-C	94.0	42	7	25	8	5	4.3	1.5	18.5	4.3	
74	28	06	EB2-C	90.0	62	8	42	12	4	3.3	3.0	25.5	3.3	
74	02	07	MLB2-C	74.0	46	4	33	10	4	2.6	2.0	27.5	2.6	
74	05	07	EB2-C	89.0	42	6	30	10	5	4.0	0.5	22.5	4.0	
74	10	07	EB2-C	5.8	70	6	37	12	5	4.3	0.1	8.7	4.3	
74	11	07	MLB2-C	207.0	62	6	38	13	5	4.4	0.1	8.4	4.4	
74	12	07	EB2-C	250.0	38	7	39	10	4	3.9	0.4	22.8	4.6	
74	16	07	MLB2-C	229.0	65	8	42	11	4	3.4	0.2	21.3	4.4	
74	18	07	EB2-C	194.7	51	10	34	13	5	5.5	0.1	13.5	6.6	
74	22	07	MLB2-C	142.0	67	11	29	10	6	8.5	0.5	24.5	9.6	
74	23	07	EB2-C	121.0	44	9	16	13	7	2.8	1.2	24.8	3.4	
74	30	07	MLB2-C	165.0	44	9	16	13	7	2.8	1.2	24.8	3.4	
74	06	08	EB2-C	140.0	108	8	28	10	6	0.5	0.1	31.4	1.4	
74	09	08	EB2-SAMPLER MALFUNCTION GRABBED	155.0	44	5	16	6	10	4.9	0.2	28.3	5.6	
74	08	08	MLB2-C	6.7	44	5	16	6	10	6.4	0.1	29.0	7.3	
74	13	08	EB2(0900-1700)	136.0	61	9	37	6	11	6.6	0.3	30.7	7.4	
74	15	08	MLB2-C	78.0	49	11	25	12	10	2.9	0.2	15.3	3.5	
74	20	08	EB2-C	4.6	61	12	20	6	13	6.5	0.2	20.3	7.2	
74	22	08	MLB2-C	123.0	50	6	29	5	15	10.0	1.2	4.9	14.2	
74	29	08	EB2-C	187.0	42	6	29	4	11	8.0	0.2	38.8	8.1	
74	29	08	74 RATE DAY PLANT B (TSS) SYSTEM GRABBED	115.2	41	6	21	3	12	6.7	0.1	36.0	7.1	
74	29	08	HEAVY SOLIDS 0100 TO 0400	269.0	42	6	29	4	11	8.0	0.2	38.8	8.1	
74	06	09	24 HP. COMPOSITE ER2.	10.0	41	6	21	3	12	6.7	0.1	36.0	7.1	
74	06	09	MLB2-C	171.0										
74	10	09	EB2-C	177.5										
74	10	09	MLB2-C	153.0										

SAMPLES AT 0800 NEXT MORNING

ANALYSIS BASED ON 21 HR COMPOSITE

HRS MISSING FROM

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED	FILTERED	COO	BOO	FOC	NO3N	NO2N	NO3N	TKN
74	12	09	EB2-09-2309	49	17.0	32	3	11	12.5	0.1	21.0	15.9
74	12	09	EB2-SAMPLER BRAKEDOWN, ONLY	209.0	209.0	SAMPLES FROM 0900 TO 2300 HRS						
74	11	09	MLB2-C-GAM	42	2	31	2	12	19.0	0.3	19.7	19.8
74	11	09	MLB2-C-GAM	42	4	37	3	13	14.8	0.1	15.4	14.8
74	11	09	MLB2-C-GAM	51	5	33	3	15	4.6	0.0	32.5	4.8
74	12	09	EB2-C-GPH	72	9	38	3	17	6.5	0.0	32.5	7.5
74	22	09	MLB2-C-GPM	54	7	35	6	16	5.1	0.0	10.8	6.3
74	22	09	EB2-C-GPH	43	5	32	4	17	3.2	0.1	13.9	4.7
74	08	10	EB2-C-GAM	50	7	31	5	19	3.4	0.4	12.7	5.4
74	08	10	MLB2-C-GAM	57	6	46	3	17	15.0	1.5	27.0	15.8
74	18	10	EB2-C-GAM	47	4	SAMPLES DUE TO MECHANICAL BREAKDOWN						
74	22	10	EB2-C-GAM	42	6	37	3	17	3.2	0.5	41.5	4.4
74	22	10	MLB2-C-GAM	38	7	34	3	17	2.8	7.3	38.7	4.2
74	22	10	MLB2-C-GAM	58	10	25	4	17	7.7	3.7	36.3	9.3
74	06	11	MLB2-C-GAM	58	10	29	3	13	2.2	0.2	39.3	3.1
74	06	11	EB2-C-GAM	58	10	45	4	13	14.0	9.9	39.1	15.2
74	13	11	MLB2-C-GAM	66	6	33	4	13	14.0	0.3	26.7	14.1
74	15	11	EB2-C-GAM	46	7	25	3	9	5.6	0.2	26.0	5.6
74	22	11	MLB2-C-GAM	29	41	25	3	9	11.0	0.0	28.0	12.1
74	22	11	EB2-C-GAM	79	7	17	0	2	0.2	0.0	10.0	1.8
74	22	11	EB2-C-GAM	37	6	16	0	1	0.1	0.0	11.2	0.8
74	22	11	EB2-C-GAM	46	4	10	0	0	0.0	0.0	11.4	0.9
74	22	11	EB2-C-GAM	50	5	12	0	3	1.4	0.0	12.9	7.1
74	22	11	EB2-C-GAM	54	4	10	0	0	0.0	0.0	10.2	9.0
74	22	11	EB2-C-GAM	63	3	10	0	0	0.0	0.0	10.2	15.0
74	22	11	EB2-C-GAM	83	2	10	0	0	0.0	0.0	8.9	19.0
74	22	11	EB2-C-GAM	109	9	14	0	0	0.0	0.0	15.0	30.0
74	22	11	EB2-C-GAM	149	8	17	0	0	0.0	0.0	18.1	19.0
74	22	11	EB2-C-GAM	158	1	27	0	0	0.0	0.0	40.0	21.0

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED COD	UNFILTERED BOD	TKN	COD	BOD	FOC	FILTERED NH3N	FILTERED NO2N	FILTERED NO3N	TKN
74	10	12	EB2-0900	112		19.9			20	16.9	0.0	2.2	17.7
74	10	11	EB2-1100	179		17.1			15	12.9	0.0	3.4	14.3
74	10	11	EB2-1500	759		15.5			13	11.2	0.0	4.5	15.7
74	10	11	EB2-1700	791		16.6			13	13.2	0.0	5.7	18.9
74	10	11	EB2-1800	914		17.6			15	14.2	0.0	7.1	21.3
74	11	01	EB2-0300	1044		20.3			15	16.2	0.0	9.1	29.3
74	11	01	EB2-0500	1240		19.8			15	17.9	0.0	10.6	30.4
74	11	02	EB2-0700	1107		22.5			17	15.0	0.0	19.5	34.5
74	11	02	EB2-0900	1189		22.9			17	15.9	0.0	25.5	38.4
74	11	02	EB2-1100	899		22.6			16	17.9	0.0	34.6	46.5
74	11	02	EB2-1300	876		17.3			14	17.2	0.0	46.6	63.8
74	11	02	EB2-1500	644		22.0			17	18.9	0.0	67.6	85.6
74	11	02	EB2-1600	441		22.7			18	18.8	0.0	97.2	116.0
74	11	02	EB2-1800	101		22.9			19	14.4	0.0	169.5	183.9
74	11	02	EB2-2000	1083	108	18.3			19	16.2	0.0	202.8	221.1
74	11	02	EB2-2200	1113	110	19.6			19	16.9	0.0	228.9	257.8
74	11	02	EB2-0100	959	112	20.0			19	16.8	0.0	299.6	338.4
74	11	02	EB2-0300	559	112	19.9			19	16.7	0.0	329.0	370.7
74	11	02	EB2-0500	529	112	19.9			19	16.7	0.0	359.4	403.1
74	11	02	EB2-0700	559	112	19.9			19	16.7	0.0	389.8	435.5
74	11	02	EB2-0900	579	112	19.9			19	16.7	0.0	419.2	467.9
74	11	02	EB2-1100	569	112	19.9			19	16.7	0.0	449.6	500.3
74	11	02	EB2-1300	559	112	19.9			19	16.7	0.0	479.0	532.7
74	11	02	EB2-1500	549	112	19.9			19	16.7	0.0	509.4	565.1
74	11	02	EB2-1600	539	112	19.9			19	16.7	0.0	539.8	597.5
74	11	02	EB2-1800	529	112	19.9			19	16.7	0.0	569.2	630.0
74	11	02	EB2-2000	519	112	19.9			19	16.7	0.0	599.6	662.4
74	11	02	EB2-0100	509	112	19.9			19	16.7	0.0	629.0	694.8
74	11	02	EB2-0300	499	112	19.9			19	16.7	0.0	659.4	727.2
74	11	02	EB2-0500	489	112	19.9			19	16.7	0.0	689.8	759.6
74	11	02	EB2-0700	479	112	19.9			19	16.7	0.0	719.2	792.0
74	11	02	EB2-0900	469	112	19.9			19	16.7	0.0	749.6	824.4
74	11	02	EB2-1100	459	112	19.9			19	16.7	0.0	779.0	856.8
74	11	02	EB2-1300	449	112	19.9			19	16.7	0.0	809.4	889.2
74	11	02	EB2-1500	439	112	19.9			19	16.7	0.0	839.8	921.6
74	11	02	EB2-1600	429	112	19.9			19	16.7	0.0	869.2	954.0
74	11	02	EB2-1800	419	112	19.9			19	16.7	0.0	899.6	986.4
74	11	02	EB2-2000	409	112	19.9			19	16.7	0.0	929.0	1018.8
74	11	02	EB2-0100	399	112	19.9			19	16.7	0.0	959.4	1051.2
74	11	02	EB2-0300	389	112	19.9			19	16.7	0.0	989.8	1083.6
74	11	02	EB2-0500	379	112	19.9			19	16.7	0.0	1019.2	1116.0
74	11	02	EB2-0700	369	112	19.9			19	16.7	0.0	1049.6	1148.4
74	11	02	EB2-0900	359	112	19.9			19	16.7	0.0	1079.0	1180.8
74	11	02	EB2-1100	349	112	19.9			19	16.7	0.0	1109.4	1213.2
74	11	02	EB2-1300	339	112	19.9			19	16.7	0.0	1139.8	1245.6
74	11	02	EB2-1500	329	112	19.9			19	16.7	0.0	1169.2	1278.0
74	11	02	EB2-1600	319	112	19.9			19	16.7	0.0	1199.6	1310.4
74	11	02	EB2-1800	309	112	19.9			19	16.7	0.0	1229.0	1342.8
74	11	02	EB2-2000	299	112	19.9			19	16.7	0.0	1259.4	1375.2
74	11	02	EB2-0100	289	112	19.9			19	16.7	0.0	1289.8	1407.6
74	11	02	EB2-0300	279	112	19.9			19	16.7	0.0	1319.2	1440.0
74	11	02	EB2-0500	269	112	19.9			19	16.7	0.0	1349.6	1472.4
74	11	02	EB2-0700	259	112	19.9			19	16.7	0.0	1379.0	1504.8
74	11	02	EB2-0900	249	112	19.9			19	16.7	0.0	1409.4	1537.2
74	11	02	EB2-1100	239	112	19.9			19	16.7	0.0	1439.8	1569.6
74	11	02	EB2-1300	229	112	19.9			19	16.7	0.0	1469.2	1602.0
74	11	02	EB2-1500	219	112	19.9			19	16.7	0.0	1499.6	1634.4
74	11	02	EB2-1600	209	112	19.9			19	16.7	0.0	1529.0	1666.8
74	11	02	EB2-1800	199	112	19.9			19	16.7	0.0	1559.4	1699.2
74	11	02	EB2-2000	189	112	19.9			19	16.7	0.0	1589.8	1731.6
74	11	02	EB2-0100	179	112	19.9			19	16.7	0.0	1619.2	1764.0
74	11	02	EB2-0300	169	112	19.9			19	16.7	0.0	1649.6	1796.4
74	11	02	EB2-0500	159	112	19.9			19	16.7	0.0	1679.0	1828.8
74	11	02	EB2-0700	149	112	19.9			19	16.7	0.0	1709.4	1861.2
74	11	02	EB2-0900	139	112	19.9			19	16.7	0.0	1739.8	1893.6
74	11	02	EB2-1100	129	112	19.9			19	16.7	0.0	1769.2	1926.0
74	11	02	EB2-1300	119	112	19.9			19	16.7	0.0	1799.6	1958.4
74	11	02	EB2-1500	109	112	19.9			19	16.7	0.0	1829.0	1990.8
74	11	02	EB2-1600	99	112	19.9			19	16.7	0.0	1859.4	2023.2
74	11	02	EB2-1800	89	112	19.9			19	16.7	0.0	1889.8	2055.6
74	11	02	EB2-2000	79	112	19.9			19	16.7	0.0	1919.2	2088.0

29071525890
3327425445340
45445454540

ANALYSES

YEAR	DAY	MGN	SAMPLE DESIGNATION	UNFILTERED	FILTERED	COD	BOD	FOC	NH3N	NO2N	NO3N	TKN	IKN
75	04	03	EB2-C	57	6	47	3	90	0.4	0.0	12.1	1.1	1.1
75	04	03	MLB2-C										
75	05	03	EB2-C	92	12	43	4	12	8.6	0.3	4.7	1.7	1.7
75	06	03	MLB2-C										
75	06	03	NO MLSS	TKN TAKEN									
75	07	03	EB2-C	94	10	44	3	19	3.1	0.1	14.0	4.8	4.8
75	07	03	MLB2-C										
75	08	03	EB2-C	93	10	49	4	12	4.6	0.3	11.2	5.6	5.6
75	08	03	MLB2-C										
75	09	03	EB2-C			37			0.6	0.0	27.0	1.0	1.0
75	09	03	MLB2-C			34			0.1	0.0	28.0	1.0	1.0
75	09	03	EB2-C			35			0.1	0.0	30.0	1.0	1.0
75	09	03	MLB2-C			43			0.1	0.0	35.0	1.0	1.0
75	09	03	EB2-C			43			0.1	0.0	35.0	1.0	1.0
75	09	03	MLB2-C			43			0.1	0.0	35.0	1.0	1.0
75	09	03	EB2-C			43			0.1	0.0	34.0	1.0	1.0
75	09	03	MLB2-C			43			0.1	0.0	34.0	1.0	1.0
75	09	03	EB2-C			43			0.1	0.0	34.0	1.0	1.0
75	09	03	MLB2-C			43			0.1	0.0	34.0	1.0	1.0
75	09	03	EB2-C			32			0.3	0.0	11.7	1.0	1.0
75	09	03	MLB2-C			33			0.1	0.0	11.7	1.0	1.0
75	09	03	EB2-C			33			0.1	0.0	12.8	1.0	1.0
75	09	03	MLB2-C			39			0.1	0.0	13.8	1.0	1.0
75	09	03	EB2-C			47			0.1	0.0	13.8	1.0	1.0
75	09	03	MLB2-C			47			0.1	0.0	13.8	1.0	1.0
75	09	03	EB2-C			29			4.3	0.0	0.0	2.0	2.0
75	09	03	MLB2-C			37			3.0	0.0	5.6	0.0	0.0
75	09	03	EB2-C			36			2.0	0.0	5.6	0.0	0.0
75	09	03	MLB2-C			38			0.0	0.0	6.7	0.0	0.0
75	09	03	EB2-C			44			0.0	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			44			1.1	0.0	6.7	0.0	0.0
75	09	03	EB2-C			45			1.0	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			45			1.0	0.0	6.7	0.0	0.0
75	09	03	EB2-C			45			1.0	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			45			1.0	0.0	6.7	0.0	0.0
75	09	03	EB2-C			49			2.3	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	MLB2-C			54			5.5	0.0	6.7	0.0	0.0
75	09	03	EB2-C										

ANALYSES

YEAR	DAY	MON	SAMPLER DESIGNATION	UNFILTERED		FILTERED		COD	BOD	FQC	NH3N	NO2N	NO3N	TKN
				COD	BOD	FQC	TKN							
75	11	03	EB22-C-GAM	79	9	79	8	76	2	11	0.8	0.0	14.0	1.0
75	11	03	MLB22-C-GAM				3.8							
75	12	03	EB22-C-GAM	94	11		10.6	42	46	12	7.3	0.0	11.5	8.4
75	12	03	MLB22-C-GAM				16.3							
75	13	03	EB22-C-GAM	174	25		39.4	61	14	23	14.0	0.5	1.7	17.7
75	13	03	MLB22-C-GAM				29.0							
75	14	03	EB22-C-GAM	92	9		18.2	60	5	15	13.4	0.8	2.7	15.6
75	14	03	MLB22-C-GAM				17.0							
75	15	03	EB22-C-GAM	77	8		20.3	46	4	13	13.6	0.2	2.8	16.1
75	15	03	MLB22-C-GAM				7.0							
75	16	03	EB22-C-GAM	77	7		14.7	45	4	16	10.0	0.8	6.7	12.9
75	16	03	MLB22-C-GAM				17.0							
75	17	03	EB22-C-GAM	84	9		15.3	31	4	14	6.6	1.9	11.9	8.1
75	17	03	MLB22-C-GAM				5.0							
75	18	03	EB22-C-GAM	99	13		6.0	51	4	10	3.6	3.4	13.6	4.1
75	18	03	MLB22-C-GAM				3.0							
75	19	03	EB22-C-GAM				3.0							
75	19	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21	03	MLB22-C-GAM				5.0							
75	21	03	EB22-C-GAM				5.0							
75	21													

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD	BOD	UNFILTERED	TKN	COD	BOD	FILTERED	N02N	N03N	TKN
75	25	04	EB2-0700	48	17	5.4	0.5	8.8	6.8	2.0	0.0	0.0	6.8
75	25	04	EB2-0900	45	15	4.2	0.5	9.2	5.7	3.0	0.0	0.0	5.7
75		04	FOLLOWING ARE THE 2 HR RESULTS FROM 19/4 110CHRS TO 23/4 1100 HRS AS INTERPRETED FROM A CONTINUOUS RECORD DURING THIS PERIOD BASED ON 3 HR SAMPLES										
75			SA	04	00	00	00	00	00	00	00	00	00
75			EB2-1000	00	00	00	00	00	00	00	00	00	00
75			EB2-1100	00	00	00	00	00	00	00	00	00	00
75			EB2-1200	00	00	00	00	00	00	00	00	00	00
75			EB2-1300	00	00	00	00	00	00	00	00	00	00
75			EB2-1400	00	00	00	00	00	00	00	00	00	00
75			EB2-1500	00	00	00	00	00	00	00	00	00	00
75			EB2-1600	00	00	00	00	00	00	00	00	00	00
75			EB2-1700	00	00	00	00	00	00	00	00	00	00
75			EB2-1800	00	00	00	00	00	00	00	00	00	00
75			EB2-1900	00	00	00	00	00	00	00	00	00	00
75			EB2-2000	00	00	00	00	00	00	00	00	00	00
75			EB2-2100	00	00	00	00	00	00	00	00	00	00
75			EB2-2200	00	00	00	00	00	00	00	00	00	00
75			EB2-2300	00	00	00	00	00	00	00	00	00	00
75			EB2-2400	00	00	00	00	00	00	00	00	00	00
75			EB2-2500	00	00	00	00	00	00	00	00	00	00
75			EB2-2600	00	00	00	00	00	00	00	00	00	00
75			EB2-2700	00	00	00	00	00	00	00	00	00	00
75			EB2-2800	00	00	00	00	00	00	00	00	00	00
75			EB2-2900	00	00	00	00	00	00	00	00	00	00
75			EB2-3000	00	00	00	00	00	00	00	00	00	00
75			EB2-3100	00	00	00	00	00	00	00	00	00	00
75			EB2-3200	00	00	00	00	00	00	00	00	00	00
75			EB2-3300	00	00	00	00	00	00	00	00	00	00
75			EB2-3400	00	00	00	00	00	00	00	00	00	00
75			EB2-3500	00	00	00	00	00	00	00	00	00	00
75			EB2-3600	00	00	00	00	00	00	00	00	00	00
75			EB2-3700	00	00	00	00	00	00	00	00	00	00
75			EB2-3800	00	00	00	00	00	00	00	00	00	00
75			EB2-3900	00	00	00	00	00	00	00	00	00	00
75			EB2-4000	00	00	00	00	00	00	00	00	00	00
75			EB2-4100	00	00	00	00	00	00	00	00	00	00
75			EB2-4200	00	00	00	00	00	00	00	00	00	00
75			EB2-4300	00	00	00	00	00	00	00	00	00	00
75			EB2-4400	00	00	00	00	00	00	00	00	00	00
75			EB2-4500	00	00	00	00	00	00	00	00	00	00
75			EB2-4600	00	00	00	00	00	00	00	00	00	00
75			EB2-4700	00	00	00	00	00	00	00	00	00	00
75			EB2-4800	00	00	00	00	00	00	00	00	00	00
75			EB2-4900	00	00	00	00	00	00	00	00	00	00
75			EB2-5000	00	00	00	00	00	00	00	00	00	00

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	UNFILTERED COD	BOD	TKN	COD	BOD	FOC	NH3N	NO2N	NO3N	TKN
75	23	04	MLB2-0100				37		10	13.0	3.9	16.5	14.5
75	23	04	MLB2-0300				38		10	13.0	3.9	16.5	14.5
75	23	04	MLB2-0500				39		10	11.0	2.8	16.0	12.5
75	23	04	MLB2-0700				36		10	16.1	2.7	15.3	18.9
75	23	04	MLB2-0900				38		10	4.0	2.6	15.0	5.0
75	23	04	MLB2-1100				38		10	2.0	2.4	15.0	3.0
75	05	05	END OF C	93		16.2	55	4	15	10.5	10.2	24.8	13.0
75	07	05	MLB2-GAM	95	21	43.0	69	5	13	9.1	4.0	28.0	9.9
75	12	05	MLB2-GAM	104	14	126.8	41	6	12	2.5	0.4	9.9	3.8
75	13	05	MLB2-GAM	143	40	63.4	45	9	17	9.2	0.6	5.8	11.6
75	14	05	MLB2-GAM	87	25	17.1	46	9	10	9.7	0.6	6.1	10.7
75	15	05	MLB2-GAM	161	26	12.0	56	10	46	12.7	1.2	6.6	15.3
75	22	05	MLB2-0900				52		18	0.2	0.0	0.0	5.8
75	22	05	MLB2-1200				22		9	0.0	0.0	0.0	0.0
75	22	05	MLB2-1500				26		9	0.0	0.0	0.0	0.0
75	22	05	MLB2-1800				26		9	0.0	0.0	0.0	0.0
75	22	05	MLB2-2100				26		9	0.0	0.0	0.0	0.0
75	22	05	MLB2-2400				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-2600				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-2900				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-3200				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-3500				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-3800				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-4100				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-4400				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-4700				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-5000				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-5300				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-5600				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-5900				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-6200				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-6500				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-6800				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-7100				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-7400				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-7700				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-8000				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-8300				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-8600				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-8900				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-9200				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-9500				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-9800				44		16	5.5	0.5	0.3	7.3
75	22	05	MLB2-10100				44		16	5.5	0.5	0.3	7.3

ANALYSES

YEAR	DAY	MON	SAMPLE DESIGNATION	COD	BOD	UNFILTERED TKN	COD	BOD	FOC	NH3N	NO2N	NO3N	TKN
75	04	05	MLB2-C	84	15	117.0	48	7	13	8.7	4.3	21.7	8.9
75	05	06	MLB2-C			111.9	36	7	29	1.4	0.3	11.6	2.0
75	06	06	MLB2-C			92.0	32	7	35	6.0	0.1	12.9	2.0
75	07	06	MLB2-C				33	7	11	0.1	0.1	12.1	2.0
75	08	06	MLB2-C				35	7	12	0.1	0.1	12.3	2.0
75	09	06	MLB2-C				36	7	14	0.1	0.1	15.8	2.0
75	10	06	MLB2-C				37	7	15	0.4	0.1	17.9	2.0
75	11	06	MLB2-C				38	7	13	0.4	0.1	14.4	2.0
75	12	06	MLB2-C				33	7	11	0.4	0.1	17.7	2.0
75	13	06	MLB2-C				35	7	11	0.4	0.1	14.4	2.0
75	14	06	MLB2-C				32	7	11	0.4	0.1	17.7	2.0
75	15	06	MLB2-C				35	7	11	0.4	0.1	14.4	2.0
75	16	06	MLB2-C				34	7	11	0.4	0.1	18.3	2.0
75	17	06	MLB2-C				44	7	13	2.6	0.2	3.8	1.5
75	18	06	MLB2-C				47	7	13	4.2	0.2	7.3	1.5
75	19	06	MLB2-C				44	7	13	2.8	0.2	7.0	1.5
75	20	06	MLB2-C				47	7	13	4.8	0.2	7.2	1.5
75	21	06	MLB2-C				44	7	13	8.0	0.2	7.0	1.5
75	22	06	MLB2-C				45	7	13	1.1	0.2	5.8	1.5
75	23	06	MLB2-C				40	7	13	1.1	0.2	5.8	1.5
75	24	06	MLB2-C				42	7	13	1.1	0.2	5.8	1.5
75	25	06	MLB2-C				44	7	13	1.1	0.2	5.8	1.5
75	26	06	MLB2-C				47	7	13	1.1	0.2	5.8	1.5
75	27	06	MLB2-C				44	7	13	1.1	0.2	5.8	1.5
75	28	06	MLB2-C				44	7	13	1.1	0.2	5.8	1.5
75	29	06	MLB2-C				44	7	13	1.1	0.2	5.8	1.5
75	30	06	MLB2-C				44	7	13	1.1	0.2	5.8	1.5
75	31	06	MLB2-C				44	7	13	1.1	0.2	5.8	1.5
75	01	07	MLB3-C	92	23	126.0	47	2	15	0.4	1.8	22.2	1.5
75	02	07	MLB3-C	58	18	34.0	52	11	16	11.3	4.0	16.0	12.5
75	03	07	MLB3-C			00.0							
75	04	07	MLB3-C			00.0							
75	05	07	MLB3-C			00.0							
75	06	07	MLB3-C			00.0							
75	07	07	MLB3-C			00.0							
75	08	07	MLB3-C			00.0							
75	09	07	MLB3-C			00.0							
75	10	07	MLB3-C			00.0							
75	11	07	MLB3-C			00.0							
75	12	07	MLB3-C			00.0							
75	13	07	MLB3-C			00.0							
75	14	07	MLB3-C			00.0							
75	15	07	MLB3-C			00.0							
75	16	07	MLB3-C			00.0							
75	17	07	MLB3-C			00.0							
75	18	07	MLB3-C			00.0							
75	19	07	MLB3-C			00.0							
75	20	07	MLB3-C			00.0							
75	21	07	MLB3-C			00.0							
75	22	07	MLB3-C			00.0							
75	23	07	MLB3-C			00.0							
75	24	07	MLB3-C			00.0							
75	25	07	MLB3-C			00.0							
75	26	07	MLB3-C			00.0							
75	27	07	MLB3-C			00.0							
75	28	07	MLB3-C			00.0							
75	29	07	MLB3-C			00.0							
75	30	07	MLB3-C			00.0							
75	31	07	MLB3-C			00.0							

(INTERPRETED)

ANALYSES

YEAR	DAY	NON	SAMPLE	UNFILTERED	FILTERED	COD	BOD	800	FOC	NH3N	N02N	N03N	TKN
75	01	07	0900	00	00	42	37	21	00	00	00	19	7
75	01	07	1100	00	00	43	40	14	00	00	00	15	1
75	01	07	1300	00	00	44	66	15	00	00	00	14	1
75	01	07	1700	00	00	44	80	16	00	00	00	14	1
75	01	07	1900	00	00	45	80	17	00	00	00	18	2
75	01	07	2100	00	00	45	55	16	00	00	00	16	2
75	02	00	0300	00	00	45	55	16	00	00	00	16	2
75	02	00	0500	00	00	45	55	16	00	00	00	16	2
75	02	00	0700	00	00	44	33	16	00	00	00	15	1
75	02	00	0900	00	00	44	33	16	00	00	00	15	1
75	02	00	1100	00	00	44	33	16	00	00	00	15	1
75	02	00	1300	00	00	44	33	16	00	00	00	15	1
75	02	00	1500	00	00	44	33	16	00	00	00	15	1
75	02	00	1700	00	00	44	33	16	00	00	00	15	1
75	02	00	1900	00	00	44	33	16	00	00	00	15	1
75	02	00	2100	00	00	44	33	16	00	00	00	15	1
75	03	00	0100	00	00	44	33	16	00	00	00	15	1
75	03	00	0300	00	00	44	33	16	00	00	00	15	1
75	03	00	0500	00	00	44	33	16	00	00	00	15	1
75	03	00	0700	00	00	44	33	16	00	00	00	15	1
75	03	00	0900	00	00	44	33	16	00	00	00	15	1
75	03	00	1100	00	00	44	33	16	00	00	00	15	1
75	03	00	1300	00	00	44	33	16	00	00	00	15	1
75	03	00	1500	00	00	44	33	16	00	00	00	15	1
75	03	00	1700	00	00	44	33	16	00	00	00	15	1
75	03	00	1900	00	00	44	33	16	00	00	00	15	1
75	03	00	2100	00	00	44	33	16	00	00	00	15	1
75	04	00	0300	00	00	44	33	16	00	00	00	15	1
75	04	00	0500	00	00	44	33	16	00	00	00	15	1
75	04	00	0700	00	00	44	33	16	00	00	00	15	1
75	04	00	0900	00	00	44	33	16	00	00	00	15	1
75	04	00	1100	00	00	44	33	16	00	00	00	15	1
75	04	00	1300	00	00	44	33	16	00	00	00	15	1
75	04	00	1500	00	00	44	33	16	00	00	00	15	1
75	04	00	1700	00	00	44	33	16	00	00	00	15	1
75	04	00	1900	00	00	44	33	16	00	00	00	15	1
75	04	00	2100	00	00	44	33	16	00	00	00	15	1

APPENDIX C

Pseudo "Steady-State" Experimental Run Results

The results of experiments designed to compare the separate and combined sludge systems (Table 4) together with the results of other pseudo "steady-state" experiments undertaken to allow for system design are summarized in Table C1.

Genuine Versus Non-Genuine Repeated Results

A certain number of the pseudo "steady-state" experiments were repeated in order to allow estimation of the variance associated with the results. Certain repeated experiments were carried out during another pseudo "steady-state" period from that of the original experiment ("genuine" repeats), others during the same period (non-"genuine" repeats). In comparing the rate results (Table C2) there is no evidence to necessitate differentiating between "genuine" and non-"genuine" repeats.

Nitrification Rate and Ammonia Concentration Relationship

At 15°C and 4 day SRT the combined sludge system rate data indicates no dependence on ammonia concentration down to values approaching 0.5 mg/l $\text{NH}_4^+\text{-N}$ (Figure C1, Table C3):

Effect of NO_3^- -N on Analytical Determination of Filterable Organic Nitrogen

It has been stated (Parkin and McCarty, 1975) that the analytical determination of filterable organic nitrogen may be interfered with by the presence of NO_3^- -N leading to an apparent lower value than actually present. The low concentrations of filterable organic nitrogen analytically determined in this research were independent of the concentration of NO_3^- -N present (Figure C2).

Nitrification - HRT Relationship

The pseudo "steady-state" relationships developed between filterable TKN removal and temperature imply an independence on hydraulic residence time (HRT). The pseudo "steady-state" models developed at a

TABLE C1 PSEUDO "STEADY-STATE" EXPERIMENTAL RESULTS

Run No.	Date	System Conditions		System Solids Retention		System Nitritification		System TKN			
		Temp °C	Detention Time hrs	Time - days	Rate	Removal	TKN	TSS	TSC		
				SSC	TSS	TSC	g Filterable TKN g MLVSS - day	mg/l Filterable TKN	SSC	TSS	TSC
(1973)											
PSS- 1	15/11	6	4	7	7	7	0.009	0.011	5.6	7.6	
PSS- 2	19/11	5	4	7			0.006		3.9		
PSS- 3	20/11	5	4	7	7	7	0.004	0.009	2.9	5.9	
PSS- 4	27/11	5	4			7		0.003			1.7
PSS- 5	29/11	5	4			7		0.005			3.2
(1974)											
PSS- 6	29/01	5	4	4	4	4	0.003	0.005	1.5	3.0	
PSS- 7	31/01	5	4	4	4	4	0.004	0.005	2.2	2.9	
PSS- 8	04/02	5	4	4	4	4	0.005	0.008	3.0	3.3	
PSS- 9	11/02	10	4		7	4	0.030	0.026	15.1	16.3	
PSS-10	19/02	7	4		4	4	0.013	0.011	5.7	5.1	
PSS-11	21/02	10	4		4	4	0.021	0.020	12.1	11.2	

TABLE C1 (Cont'd)

Run No.	Date	System Conditions		System Solids Retention			System Nitrification Rate			System TKN Removal		
		Temp °C	Detention Time hrs	SSC	TSS	TSC	g Filterable TKN / g MLVSS - day	SSC	TSS	TSC	mg/l Filterable TKN	TSS
PSS-12	27/02	15	4	4	4	4	0.053	0.032	0.032	19.7	17.8	
PSS-13	10/04	15	6.4	10	10	10	0.037	0.025	0.025	23.9	22.8	
PSS-14	16/04	5	6.4	10	10	10	0.022	0.014	0.014	16.5	15.4	
PSS-15	18/04	5	6.4	10	10	10	0.021	0.012	0.012	17.5	13.7	
PSS-16	01/05	20	6.4	10	10	10	0.031	0.053	0.053	30.0	32.9	
PSS-17	21/05	6	4	7	7	7	0.019	0.013	0.013	6.6	6.2	
PSS-18	04/06	7	5	7	7	7	0.007	0.008	0.008	6.1	5.8	
PSS-19	06/06	7	5	7	7	7	0.0002	0.012	0.012	0.2	7.8	
PSS-20	13/06	10	5	7	7	7	0.014	0.022	0.022	12.5	17.8	
PSS-21	18/06	10	5	7	7	7	0.028	0.018	0.018	17.1	16.1	
PSS-22	20/06	10	5	7	7	7	0.037	0.021	0.021	17.9	18.4	
PSS-23	28/06	15	5	7	7	7	0.048	0.031	0.031	29.9	29.9	

TABLE C1 (Cont'd)

Run No.	Date	Temp °C	System Conditions		System Solids Retention Time - days		System Nitritification Rate		System TKN Removal			
			Detention Time hrs	Temp °C	SSC	TSS	TSC	g Filterable TKN / g MLVSS - day	SSC	TSS	TSC	mg/l Filterable TKN
PSS-24	02/07	15	5	7	7	7	0.029	0.052	27.9	26.3		
PSS-25	05/07	15	5	7	7	7	0.029	0.068	28.4	27.4		
PSS-26	10/07	8	5	7	7	7	0.027	0.014	15.9	11.4		
PSS-27	12/07	8	5	7	7	7	0.022	0.014	16.2	12.9		
PSS-28	16/07	15	4	4	4	4	0.029	0.052	18.1	24.5		
PSS-29	18/07	15	4	4	4	4	0.031	0.049	23.1	25.6		
PSS-30	22/07	15	4	4	4	4	0.0637	0.032	22.1	20.7		
PSS-31	30/07	20	5	7	7	7	0.086	0.044	38.1	40.1		
PSS-32	06/08	20	5	7	7	7	0.060	0.036	35.6	35.1		
PSS-33	08/08	20	5	7	7	7	0.030	0.030	27.7	28.7		
PSS-34	13/08	20	5	7	7	7	0.030	0.064	27.7	28.7		
PSS-35	15/08	20	5	7	7	7	0.040	0.082	32.8	32.4		

TABLE C1 (Cont'd)

Run No.	Date	System Conditions		System Solids Retention Time - days			System Nitritification Rate			System TKN Removal			
		Temp °C	Detention Time hrs	SSC	TSS	TSC	g Filterable TKN / g MLVSS - day	SSC	TSS	TSC	mg/l Filterable TKN	SSC	TSS
PSS-36	20/08	12	5	7	7	7	0.026	0.051		22.2	20.8		
PSS-37	22/08	13	5	7	7	7	0.033	0.058		29.6	30.4		
PSS-39	29/08	7	5			7		0.016			11.2		
PSS-40*	06/09	25	5			7	0.035						
PSS-41*	10/09	25	5			7	0.034						
PSS-42	17/09	20	4							0.045		30.5	
PSS-43	19/09	20	4							0.054		36.1	
PSS-44	25/09	20	4			4		0.085	0.059		41.3	37.1	
PSS-45	27/09	20	4			4		0.099	0.058		41.8	37.3	
PSS-46	03/10	8	5			7		0.026			18.0		
PSS-47	08/10	8	5			4		0.026			22.8		
PSS-48	10/10	8	5			4		0.029			21.9		

TABLE C1 (Cont'd)

Run No.	Date	System Conditions		System Solids Retention Time - days		System Nitrification Rate		System TKN Removal	
		Temp °C	Detention Time hrs	SSC	TSS	g Filterable TKN / g MLVSS - day	TSS	mg/l Filterable TKN	TSS
PSS-49	18/10	20	4	4	4	0.069	0.038	26.8	24.3
PSS-50*	25/10	25	4		4		0.057		
PSS-51*	28/10	25	4		4	0.060			
PSS-52	04/11	25	5	7	7	0.048	0.129	55.3	48.7
PSS-53	06/11	25	5	7	7	0.164	0.057	56.4	57.4
PSS-54	13/11	25	6.4	10	10	0.150	0.062	63.9	73.1
PSS-55	15/11	25	6.4	10	10	0.071	0.213	82.6	76.6
PSS-56	25/11	12	6.4	10	10	0.068	0.032	33.4	33.4
PSS-57	27/11 (1975)	10	6.4	10	10	0.022	0.039	21.4	22.1
PSS-58	10/02	10	4	4	4	0.024	0.038	12.4	15.1
PSS-59	20/02	10	6.4	10	10	0.050	0.020	30.4	21.8
PSS-60	26/02	15	6.4	10	10	0.034	0.077	32.1	32.5

TABLE C1 (Cont'd)

Run No.	Date	System Conditions		System Solids Retention Time - days			System Nitritification Rate			System TKN Removal		
		Temp °C	Detention Time hrs	SSC	TSS	TSC	g Filterable TKN / g MLVSS - day	SSC	TSS	TSC	mg/l Filterable TKN	TSS
PSS-61	05/05	25	4	4	4	4	0.117	0.271	47.1	42.1	42.1	42.1
PSS-62	07/05	25	4	4	4	4	0.261	0.135	42.6	49.8	42.6	49.8
PSS-63	20/06	20	6.4	10	10	10	0.130	0.052	48.9	47.8	48.9	47.8

Note: *Reactor D0 less than 2.0 mg/l during part of day therefore not "pseudo" steady-state conditions.

TABLE C2 GENUINE VERSUS NON-GENUINE REPEATED EXPERIMENTS

Run No.	Date	System Conditions		TSS System Solids Retention Time days	Nitrification Rate g Filterable TKN g MLVSS - day
		Temp. °C	Detention Time hrs		
	(1974)				
PSS- 9	11/2	10	5	7	0.030
PSS-18	4/6	7	5	7	0.008
PSS-19	6/6	7	5	7	0.012
PSS-20	13/6	10	5	7	0.022
PSS-21	18/6	10	5	7	0.028
PSS-22	20/6	10	5	7	0.037
PSS-23	28/6	15	5	7	0.048
PSS-24	2/7	15	5	7	0.052
PSS-25	5/7	15	5	7	0.068
PSS-26	10/7	8	5	7	0.027
PSS-27	12/7	8	5	7	0.022
PSS-31	30/7	20	5	7	0.086
PSS-32	6/8	20	5	7	0.060
PSS-34	13/8	20	5	7	0.064
PSS-35	15/8	20	5	7	0.082
PSS-39	29/8	7	5	7	0.016
PSS-46	3/10	8	5	7	0.026




FIG. C1 INDEPENDENCE OF NITRIFICATION RATE AND AMMONIA CONCENTRATION

TABLE C3 COMBINED SLUDGE SYSTEM RATE DEPENDENCY ON AMMONIA CONCENTRATION

Run No.	Date	System Temp. °C	System Solids Retention Time days	Effluent NH ₄ -N mg/l	Nitrification Rate $\frac{\text{g Filterable NH}_4\text{-N}}{\text{g MLVSS} \cdot \text{day}}$
	(1974)				
PSS-12	27/2	15	4	2.8	0.032
PSS-28	16/7	15	4	9.8	0.030
PSS-29	18/7	15	4	4.9	0.034
PSS-30	22/7	15	4	6.7	0.030
	(1975)				
* D-1	3/3	15	4	0.6	0.032
* D-2	11/3	15	4	1.0	0.034
* D-3	24/3	15	4	1.3	0.015
* D-4	7/4	15	4	0.9	0.023

Note: *Pseudo "steady-state" baseline day of dynamic run.




FIG. C2 EFFECT OF OXIDIZED NITROGEN ON FILTERABLE ORGANIC NITROGEN DETERMINATION

four day SSRT involved operating at an HRT of four hours. No difference in TKN removal was observed at an eight hour HRT under equal SRT and temperature conditions (Table C4.)

TABLE C4 VERIFICATION OF FILTERABLE TKN REMOVAL - SRT-TEMPERATURE RELATIONSHIP

Run No.	Date	Sludge System	System Temp °C	System Conditions HRT hrs	SRT days	Filterable TKN Removal Observed mg/l	**Model Prediction mg/l
	(1975)						
*D-6	12/5	SSC	13	8	4	19.9	16.3
*D-7	26/5	SSC	13	8	4	15.8	16.3
*D-8	2/6	SSC	13	8	4	16.0	16.3
*D-6	12/5	TSS	13	8	4	21.5	20.2
*D-7	26/5	TSS	13	8	4	18.9	20.2
*D-8	2/6	TSS	13	8	4	19.4	20.2

Note: *Pseudo "steady-state" baseline day of dynamic run.
 **Predictions based on filterable TKN removal models (HRT=4 hrs);
 Combined sludge system: $K = 2.52 \times 10^{13} e^{-15950/RT}$
 Separate sludge system: $K = 2.98 \times 10^{10} e^{-12000/RT}$

APPENDIX D

Mixing Characteristics of Reactors

In order to describe the mixing characteristics in the dispersed aeration tanks two flow models were used to interpret tracer response results.

Tanks in series model

The particular flow patterns which produce the effluent dye concentration curves in tracer studies can often be approximated by effluent concentrations predicted for a number of equal sized continuous stirred tanks in series (CSTR's).

The final effluent of a system of j equal sized CSTR's can be found from the following equation:

$$\frac{C}{C_0} = \frac{j^j (j\theta)^{j-1}}{(j-1)!} e^{-j\theta} \quad \dots\dots\dots(46)$$

where: C = effluent tracer concentrations

θ = dimensionless time

j = number of tanks

C_0 = the quantity of tracer added divided by the volume of the entire system

This applies only to a pulse input of tracer. In this type of system, as j approaches large values (say 15), the flow regime approximates plug flow whereas, when j is equal to 1, the flow is completely mixed. If the time at which the peak dye concentration occurs is shown, the above equation can be solved for j by taking the derivative and equating the result to zero. Theta peak is determined by dividing the peak time by the residence time. The final form of the equation is:

$$j = \frac{1}{1 - \theta} \quad \dots\dots\dots(47)$$

Dispersion model

The dispersion model is developed in such a way that it assumes plug flow with the inclusion of a term which describes the degree of molecular dispersion or deviation from the ideal. The general equation for this model is:

$$\frac{D^2 C}{x^2} - \frac{u C}{x} - \frac{C}{\tau} = 0 \quad \dots\dots\dots(48)$$

Where: u = mean displacement velocity
 C = concentration
 $\frac{C}{x}$ = concentration gradient
 $\frac{C}{\tau}$ = reaction term
 D = turbulence expression

The solution of this equation for a tracer pulse input to a closed vessel given by Mujachi (1953) is quoted by Timpany (1966).

$$\frac{C}{C_0} = 2 \sum_{n=1}^{\infty} \frac{U_n (U \sin U_n + U_n \cos U_n)}{(U^2 + 2U + U_n^2)} \text{EXP } U - \frac{(U^2 + U_n^2)}{2U} \theta \quad \dots\dots\dots(49)$$

where: $U_n = \text{COT}^{-1} \left(\frac{U_n}{U} - \frac{U}{U_n} \right) / 2$

$$U = \frac{uL}{2D}$$

L = tank length

The value U_n is best calculated by trial and error using an iterative approach. Also, the summation in equation forty-eight is taken to some reasonably large but finite value for practical purposes.

Instead of determining a value for D by the normal variance technique suggested by Levenspiel (1967), a correlation between peak time and D/uL developed by Timpany (1966) has been used. Proper use of the variance method for D/uL calculation generally requires concentration data to be entered to at least seven detention times.

This is rarely practical.

Mixing studies

The mixing characteristics of the single, two-stage, and five-stage combined sludge reactors (SSC, TSC and FSC) were established by the use of dye or tracer response methods. In addition the mixing regime in the first stage of the two-stage separate sludge system was determined.

All dye studies were conducted with a Turner Model 111 continuous flow fluorometer. The dye used in each run was prepared from 50% by weight stock Rodamine WT. Previous to the dye studies the mixed-liquor suspended solids were removed from the reactors and the testing conducted using tap water at approximately 8°C. Calibration curves were determined for the four fluorometer scales using dye solutions of known concentration at 8°C. To initiate each study a known slug of dye was added to the tank inlet through a tube immersed six inches below the liquid level. Halfway through the addition period (five sec) the dye test was assumed to begin. The effluent dye concentration was measured at the outlet weir by pumping 280 ml/min of effluent through the fluorometer located within three feet of the sampling point. The fluorometer was connected to a Fischer Recordall Series 200 recorder.

The results and further details of each dye study are included in Tables D1, D2, D3 and D4 together with a listing of the computer program (Table D5) utilized in the analyses.

TABLE D1 TRACER RESPONSE ANALYSIS FOR SSC SLUDGE REACTOR (2/1/75)

 TEST METHOD USING A PULSE INPUT OF RHODAMINE WT DYE

 REACTOR OPERATION AND TEST CONDITIONS

VOLUME OF REACTOR	=	2184.33 LITRES
HYDRAULIC LOADING	=	7.28 LITRES/MIN
THEORETICAL DET	=	300.34 MIN
DYE INJECTION	=	0.1843 LITRES
CONC OF DYE ADDED	=	1.238E+07 PPM
DYE / TANK VOLUME	=	200.51 PPM

 TEST RESULTS AND CALCULATED VALUES

DYE PEAK TIME	=	4.30 MIN
PEAK/THEOR DET	=	0.013

PEAK/MEAN DYE RES	=	0.035 MIN
MEAN DYE RESIDENCE	=	110.93 MIN
PER DYE RECOVERY	=	93.447%
FR. STAGNANT ZONE	=	0.633

CSTR S IN SERIES USING THEORETICAL RES.	=	1.01
CSTR S IN SERIES USING MEAN DYE RES.	=	1.04
D/UL VALUE USING THEORETICAL RESIDENCE	=	0.6510E+02
D/UL VALUE USING MEAN DYE RESIDENCE	=	0.1597E+02

TABLE D1 (Cont'd)

EXPERIMENTAL RESULTS C/CO VERSUS THETA

THETA	C/CO
0.100	5.989
0.200	5.817
0.300	1.720
0.400	0.629
0.500	0.550
0.600	0.482
0.700	0.419
0.800	0.357
0.900	0.315
1.000	0.263
1.100	0.232
1.200	0.201
1.300	0.174
1.400	0.150
1.500	0.129
1.600	0.111
1.700	0.099
1.800	0.086
1.900	0.075
2.000	0.065
2.100	0.056
2.200	0.048
2.300	0.043
2.400	0.036
2.500	0.031
2.600	0.027
2.700	0.024
2.800	0.020
2.900	0.017
3.000	0.016
3.333	0.009
3.667	0.006
4.000	0.004

CALCULATED C/C₀ VERSUS THETA VALUES
FOR CSTR IN SERIES MODEL

THEORETICAL DETENTION		ACTUAL DETENTION	
THETA	C/C ₀	THETA	C/C ₀
0.100	0.910	0.100	0.909
0.150	0.951	0.150	0.951
0.200	0.905	0.200	0.905
0.250	0.861	0.250	0.861
0.300	0.819	0.300	0.819
0.350	0.779	0.350	0.779
0.400	0.741	0.400	0.741
0.450	0.705	0.450	0.705
0.500	0.673	0.500	0.673
0.550	0.638	0.550	0.638
0.600	0.607	0.600	0.607
0.650	0.577	0.650	0.577
0.700	0.549	0.700	0.549
0.750	0.522	0.750	0.522
0.800	0.497	0.800	0.497
0.850	0.472	0.850	0.472
0.900	0.449	0.900	0.449
0.950	0.427	0.950	0.427
1.000	0.407	1.000	0.407
1.100	0.387	1.100	0.387
1.200	0.368	1.200	0.368
1.300	0.351	1.300	0.351
1.400	0.336	1.400	0.336
1.500	0.322	1.500	0.322
1.600	0.310	1.600	0.310
1.800	0.282	1.800	0.282
2.000	0.257	2.000	0.257
2.200	0.235	2.200	0.235
2.400	0.215	2.400	0.215
2.600	0.197	2.600	0.197
2.800	0.181	2.800	0.181
3.000	0.167	3.000	0.167
3.200	0.155	3.200	0.155
3.400	0.144	3.400	0.144
3.600	0.135	3.600	0.135
3.800	0.127	3.800	0.127
4.000	0.120	4.000	0.120
4.200	0.115	4.200	0.115

TABLE D1 (Cont'd)

CALCULATED C/CO VERSUS THETA VALUES
FOR DISPERSION MODEL

THEORETICAL DETENTION		ACTUAL DETENTION	
0.100	0.929	0.100	0.922
0.200	0.823	0.200	0.833
0.300	0.744	0.300	0.753
0.400	0.673	0.400	0.681
0.500	0.619	0.500	0.616
0.600	0.551	0.600	0.556
0.700	0.498	0.700	0.503
0.800	0.451	0.800	0.455
0.900	0.418	0.900	0.411
1.000	0.369	1.000	0.372
1.100	0.334	1.100	0.336
1.200	0.302	1.200	0.304
1.300	0.273	1.300	0.274
1.400	0.247	1.400	0.248
1.500	0.223	1.500	0.224
1.600	0.202	1.600	0.203
1.700	0.183	1.700	0.183
1.800	0.165	1.800	0.165
1.900	0.150	1.900	0.151
2.000	0.135	2.000	0.135
2.100	0.122	2.100	0.122
2.200	0.111	2.200	0.111
2.300	0.100	2.300	0.101
2.400	0.091	2.400	0.093
2.500	0.082	2.500	0.082
2.600	0.074	2.600	0.074
2.700	0.067	2.700	0.067
2.800	0.061	2.800	0.060
2.900	0.055	2.900	0.055
3.000	0.050	3.000	0.049

TABLE D2 TRACER RESPONSE ANALYSIS FOR TSC SLUDGE REACTOR (6/1/75)

 TEST METHOD USING A PULSE INPUT OF RCDAMINE WT DYE

 REACTOR OPERATION AND TEST CONDITIONS

VOLUME OF REACTOR = 2184.00 LITRES
 HYDRAULIC LOADING = 7.28 LITRES/MIN
 THEORETICAL DET = 30.00 MIN
 DYE INJECTION = 0.184 LITRES
 CONC OF DYE ADDED = 0.238E+07 PPB
 DYE / TANK VOLUME = 20.51 PPB

 TEST RESULTS AND CALCULATED VALUES

DYE PEAK TIME = 120.00 MIN
 PEAK/THEOR DET = 4.00

PEAK/MEAN DYE RES = 0.636 MIN
 MEAN DYE RESIDENCE = 198.00 MIN
 PER DYE RECOVERY = 81.884%
 FR. STAGNANT ZONE = 0.340

CSTR S IN SERIES USING THEORETICAL RES. = 1.67
 CSTR S IN SERIES USING MEAN DYE RES. = 2.54
 D/UL VALUE USING THEORETICAL RESIDENCE = 0.5875E+00
 D/UL VALUE USING MEAN DYE RESIDENCE = 0.2179E+00

TABLE D2 (Cont'd)

EXPERIMENTAL RESULTS C/CO VERSUS THETA

THETA	C/CO
0.060	0.273
0.120	0.487
0.180	0.621
0.240	0.718
0.300	0.753
0.360	0.772
0.420	0.769
0.480	0.759
0.540	0.746
0.600	0.714
0.660	0.671
0.720	0.620
0.780	0.569
0.840	0.519
0.900	0.473
0.960	0.430
1.020	0.393
1.080	0.363
1.140	0.336
1.200	0.292
1.260	0.267
1.320	0.246
1.380	0.219
1.440	0.199
1.500	0.179
1.560	0.162
1.620	0.144
1.680	0.125
1.740	0.112
1.800	0.098
1.860	0.084
1.920	0.074
1.980	0.064
2.040	0.054
2.100	0.044
2.160	0.034
2.220	0.025
2.280	0.015
2.340	0.012

TABLE D2 (Cont'd)

CALCULATED C/ZCO VERSUS THEIA VALUES
FOR CSTR IN SERIES MODFL

THEORETICAL DETENTION		ACTUAL DETENTION	
THEIA	C/ZCO	THEIA	C/ZCO
0.050	0.710	0.050	0.707
0.100	0.713	0.050	0.729
0.150	0.327	0.100	0.707
0.150	0.444	0.150	0.194
0.200	0.536	0.200	0.295
0.250	0.617	0.250	0.399
0.300	0.659	0.300	0.496
0.350	0.695	0.350	0.579
0.400	0.719	0.400	0.651
0.450	0.732	0.450	0.709
0.500	0.736	0.500	0.753
0.550	0.732	0.550	0.784
0.600	0.723	0.600	0.803
0.650	0.719	0.650	0.811
0.700	0.690	0.700	0.811
0.750	0.669	0.750	0.803
0.800	0.646	0.800	0.784
0.850	0.621	0.850	0.762
0.900	0.595	0.900	0.735
0.950	0.568	0.950	0.705
1.000	0.541	1.000	0.672
1.200	0.435	1.200	0.531
1.400	0.341	1.400	0.397
1.600	0.261	1.600	0.284
1.800	0.197	1.800	0.198
2.000	0.147	2.000	0.134
2.200	0.108	2.200	0.089
2.400	0.079	2.400	0.058
2.600	0.057	2.600	0.037
2.800	0.041	2.800	0.024
3.000	0.030	3.000	0.015
3.200	0.021	3.200	0.009
3.400	0.015	3.400	0.006
3.600	0.011	3.600	0.004
3.800	0.008	3.800	0.002
4.000	0.005	4.000	0.001
4.200	0.004	4.200	0.001

TABLE D2 (Cont'd)

CALCULATED C/CO VERSUS THETA VALUES
FOR DISPERSION MODEL

THEORETICAL DETENTION		ACTUAL DETENTION	
0.100	0.124	0.100	0.101
0.200	0.612	0.200	0.797
0.300	0.855	0.300	1.415
0.400	0.912	0.400	0.729
0.500	1.859	0.500	0.912
0.600	0.795	0.600	0.968
0.700	1.713	0.700	0.941
0.800	0.623	0.800	0.869
0.900	0.550	0.900	0.774
1.000	0.484	1.000	0.676
1.100	0.426	1.100	0.582
1.200	0.374	1.200	0.495
1.300	0.329	1.300	0.419
1.400	0.289	1.400	0.353
1.500	0.254	1.500	0.295
1.600	0.223	1.600	0.247
1.700	0.196	1.700	0.205
1.800	0.172	1.800	0.172
1.900	0.151	1.900	0.143
2.000	0.133	2.000	0.119
2.100	0.116	2.100	0.099
2.200	0.102	2.200	0.082
2.300	0.090	2.300	0.069
2.400	0.079	2.400	0.057
2.500	0.069	2.500	0.047
2.600	0.061	2.600	0.039
2.700	0.053	2.700	0.033
2.800	0.047	2.800	0.027
2.900	0.041	2.900	0.023
3.000	0.036	3.000	0.019

TABLE D3 TRACER RESPONSE ANALYSIS FOR FSC SLUDGE REACTOR (8/7/75)

TEST METHOD USING A PULSE INPUT OF ROOAMINE WT DYE

REACTOR OPERATION AND TEST CONDITIONS

VOLUME OF REACTOR = 2184.00LITRES
 HYDRAULIC LOADING = 7.28LITRES/MIN
 THEORETICAL DET = 350.00MIN
 DYE INJECTION = 0.0600LITRES
 CONC OF DYE ADDED = 0.239E+07PPB
 DYE / TANK VOLUME = 65.38PPB

TEST RESULTS AND CALCULATED VALUES

DYE PEAK TIME = 180.00MIN
 PEAK/THEOR DET = 0.600

PEAK/MEAN DYE RES = 0.686MIN
 MEAN DYE RESIDENCE = 262.50MIN
 PER DYE RECOVERY = 114.304%
 FR. STAGNANT ZONE = 0.125

CSTR S IN SERIES USING THEORETICAL RES. = 2.50
 CSTR S IN SERIES USING MEAN DYE RES. = 3.18
 D/UL VALUE USING THEORETICAL RESIDENCE = 0.2244E+00
 D/UL VALUE USING MEAN DYE RESIDENCE = 0.1485E+00

TABLE D3 (Cont'd)

EXPERIMENTAL RESULTS C/CO VERSUS THETA

THETA	C/CO
0.075	0.314
0.150	0.115
0.225	0.315
0.300	0.572
0.375	0.772
0.450	0.901
0.525	0.973
0.600	1.016
0.675	1.002
0.750	0.973
0.825	0.916
0.900	0.844
0.975	0.801
1.050	0.730
1.125	0.658
1.200	0.601
1.275	0.529
1.350	0.473
1.425	0.430
1.500	0.372
1.575	0.329
1.650	0.286
1.725	0.257
1.800	0.214
1.875	0.187
1.950	0.165
2.025	0.136
2.100	0.115
2.175	0.099
2.250	0.086
2.500	0.057
2.750	0.029

CALCULATED C/CO VERSUS THETA VALUES
FOR CSTR IN SERIES MODELS

THEORETICAL DETENTION		ACTUAL DETENTION	
THETA	C/CO	THETA	C/CO
0.000	0.000	0.000	0.000
0.050	0.181	0.050	0.029
0.100	0.327	0.100	0.100
0.150	0.464	0.150	0.194
0.200	0.536	0.200	0.296
0.250	0.607	0.250	0.399
0.300	0.659	0.300	0.494
0.350	0.695	0.350	0.579
0.400	0.719	0.400	0.651
0.450	0.732	0.450	0.709
0.500	0.736	0.500	0.753
0.550	0.732	0.550	0.784
0.600	0.723	0.600	0.803
0.650	0.709	0.650	0.811
0.700	0.690	0.700	0.810
0.750	0.669	0.750	0.800
0.800	0.646	0.800	0.784
0.850	0.621	0.850	0.762
0.900	0.595	0.900	0.735
0.950	0.568	0.950	0.705
1.000	0.541	1.000	0.672
1.200	0.435	1.200	0.531
1.400	0.341	1.400	0.397
1.600	0.251	1.600	0.284
1.800	0.197	1.800	0.198
2.000	0.147	2.000	0.134
2.200	0.108	2.200	0.089
2.400	0.079	2.400	0.058
2.600	0.057	2.600	0.037
2.800	0.041	2.800	0.024
3.000	0.030	3.000	0.015
3.200	0.021	3.200	0.009
3.400	0.015	3.400	0.006
3.600	0.011	3.600	0.004
3.800	0.008	3.800	0.002
4.000	0.005	4.000	0.001
4.200	0.004	4.200	0.001

TABLE D3 (Cont'd)

CALCULATED C/ZCO VERSUS THETA VALUES
FOR DISPERSION MODEL

THEORETICAL DETENTION		ACTUAL DETENTION	
0.100	0.001	0.100	0.000
0.200	0.117	0.200	0.021
0.300	0.432	0.300	0.207
0.400	0.741	0.400	0.538
0.500	0.915	0.500	0.830
0.600	0.955	0.600	0.995
0.700	0.934	0.700	1.037
0.800	0.859	0.800	0.994
0.900	0.766	0.900	0.903
1.000	0.658	1.000	0.791
1.100	0.575	1.100	0.676
1.200	0.491	1.200	0.567
1.300	0.416	1.300	0.469
1.400	0.350	1.400	0.385
1.500	0.294	1.500	0.313
1.600	0.247	1.600	0.254
1.700	0.206	1.700	0.205
1.800	0.172	1.800	0.164
1.900	0.144	1.900	0.132
2.000	0.120	2.000	0.105
2.100	0.100	2.100	0.084
2.200	0.083	2.200	0.067
2.300	0.069	2.300	0.054
2.400	0.058	2.400	0.043
2.500	0.048	2.500	0.034
2.600	0.040	2.600	0.027
2.700	0.033	2.700	0.021
2.800	0.028	2.800	0.017
2.900	0.023	2.900	0.014
3.000	0.019	3.000	0.011

TABLE D4 TRACER RESPONSE ANALYSIS FOR FIRST STAGE OF
TSS SLUDGE REACTOR (7/1/75)

TEST METHOD USING A PULSE INPUT OF RODAPINE WT DYE

REACTOR OPERATION AND TEST CONDITIONS

VOLUME OF REACTOR = 796.33 LITRES
 HYDRAULIC LOADING = 7.23 LITRES/MIN
 THEORETICAL DET = 109.38 MIN
 DYE INJECTION = 0.0603 LITRES
 CONC OF DYE ADDED = 0.2389E+17 PPM
 DYE / TANK VOLUME = 179.33 PPB

TEST RESULTS AND CALCULATED VALUES

DYE PEAK TIME = 0.75 MIN
 PEAK/THEOR DET = 0.007

PEAK/MEAN DYE RES = 0.0119 IN
 MEAN DYE RESIDENCE = 70.00 MIN
 PER DYE RECOVERY = 112.166
 FR. STAGNANT ZONE = 0.363

CSTR S IN SERIES USING THEORETICAL RES. = 1.01
 CSTR S IN SERIES USING MEAN DYE RES. = 1.01
 D/U/L VALUE USING THEORETICAL RESIDENCE = 0.1587E+03
 D/U/L VALUE USING MEAN DYE RESIDENCE = 0.8727E+02

TABLE D4 (Cont'd)

EXPERIMENTAL RESULTS C/CO VERSUS THETA

THETA	C/CO
0.137	1.053
0.274	0.905
0.411	0.792
0.549	0.687
0.686	0.589
0.823	0.507
0.960	0.429
1.097	0.370
1.234	0.317
1.371	0.269
1.508	0.236
1.646	0.209
1.783	0.175
1.920	0.148
2.057	0.128
2.194	0.108
2.331	0.093
2.468	0.080
2.606	0.071
2.743	0.061
2.880	0.053
3.017	0.046
3.154	0.040
3.291	0.035
3.428	0.030
3.565	0.025
3.703	0.022
3.840	0.018
3.977	0.017
4.114	0.013
4.251	0.008
4.388	0.004
4.525	0.003

CALCULATED C/CO VERSUS THETA VALUES
FOR CSTR IN SERIES MODEL

THEORETICAL DETENTION		ACTUAL DETENTION	
THETA	C/CO	THETA	C/CO
0.000	0.999	0.000	0.999
0.050	0.951	0.050	0.951
0.100	0.905	0.100	0.905
0.150	0.861	0.150	0.861
0.200	0.819	0.200	0.819
0.250	0.779	0.250	0.779
0.300	0.741	0.300	0.741
0.350	0.705	0.350	0.705
0.400	0.670	0.400	0.670
0.450	0.638	0.450	0.638
0.500	0.607	0.500	0.607
0.550	0.577	0.550	0.577
0.600	0.549	0.600	0.549
0.650	0.522	0.650	0.522
0.700	0.497	0.700	0.497
0.750	0.472	0.750	0.472
0.800	0.449	0.800	0.449
0.850	0.427	0.850	0.427
0.900	0.407	0.900	0.407
0.950	0.387	0.950	0.387
1.000	0.368	1.000	0.368
1.200	0.301	1.200	0.301
1.400	0.247	1.400	0.247
1.600	0.202	1.600	0.202
1.800	0.165	1.800	0.165
2.000	0.135	2.000	0.135
2.200	0.111	2.200	0.111
2.400	0.091	2.400	0.091
2.600	0.074	2.600	0.074
2.800	0.061	2.800	0.061
3.000	0.050	3.000	0.050
3.200	0.041	3.200	0.041
3.400	0.033	3.400	0.033
3.600	0.027	3.600	0.027
3.800	0.022	3.800	0.022
4.000	0.018	4.000	0.018
4.200	0.015	4.200	0.015

TABLE D4 (Cont'd)

CALCULATED C/CO VERSUS THETA VALUES
FOR DISPERSION MODEL

THEORETICAL DETENTION		ACTUAL DETENTION	
0.100	0.917	0.100	0.908
0.200	0.820	0.200	0.822
0.300	0.742	0.300	0.743
0.400	0.671	0.400	0.672
0.500	0.617	0.500	0.608
0.600	0.550	0.600	0.551
0.700	0.497	0.700	0.498
0.800	0.450	0.800	0.451
0.900	0.407	0.900	0.407
1.000	0.358	1.000	0.369
1.100	0.333	1.100	0.333
1.200	0.311	1.200	0.302
1.300	0.273	1.300	0.273
1.400	0.247	1.400	0.247
1.500	0.223	1.500	0.223
1.600	0.202	1.600	0.202
1.700	0.183	1.700	0.183
1.800	0.165	1.800	0.165
1.900	0.150	1.900	0.151
2.000	0.135	2.000	0.135
2.100	0.122	2.100	0.122
2.200	0.111	2.200	0.111
2.300	0.100	2.300	0.100
2.400	0.091	2.400	0.091
2.500	0.082	2.500	0.082
2.600	0.074	2.600	0.074
2.700	0.067	2.700	0.067
2.800	0.061	2.800	0.061
2.900	0.055	2.900	0.055
3.000	0.050	3.000	0.050

TABLE D5 TRACER RESPONSE ANALYSIS COMPUTER PROGRAM

```

C THE TWO CHIEF REFERENCES USED FOR THIS PROGRAM ARE
C
C 1. LEVENSPIEL, CHEMICAL REACTION ENGINEERING, CHAPTER 9.
C
C 2. TIMPANY, VARIATION IN AXIAL MIXING IN AN AERATION
C TANK. MASTERS THESIS, DEPT. OF CHEM ENG., MCMASTER
C UNIVERSITY, 1966.
C
C THE  $\theta/\tau$  VALUE FOR THE DISPERSION MODEL IS SOLVED BY USING THE
C CORRELATIONS OF PEAK TIME VERSUS  $\theta/\tau$  DEVELOPED BY TIMPANY. (PP 31 - 32)
C
C THE CSTR IN SERIES MODEL IS SOLVED BY TAKING THE DERIVATIVE OF
C EQUATION 9-35 IN LEVENSPIEL - EQUATING THE RESULT TO ZERO AND
C SOLVING FOR THE NUMBER OF EQUAL TANKS IN SERIES, J, IN TERMS
C OF  $\theta/\tau$ .  $\theta/\tau$  IS FOUND BY DIVIDING THE PEAK DYE TIME BY THE
C THEORETICAL RESIDENCE TIME.
C
C THE  $C/C_0$  VALUES FOR THE DISPERSION MODEL ARE SOLVED BY ITERATION
C USING EQUATION 8 IN CHAPTER 2 OF TIMPANY.
C
C THE  $C/C_0$  VALUES FOR THE CSTR IN SERIES MODEL ARE SOLVED USING
C EQUATION 9-35 IN LEVENSPIEL FOR VARIOUS VALUES OF  $\theta/\tau$ .
C
C
C DIMENSION C(500),CUL(500),TANKS(5),AW(5),DULP(5),THETA(2,100)
C DIMENSION CCO(2,100),U(500),AMU(5,500),COCO(5,500),CCI(100)
C DIMENSION TTB(100),TBAR(2),RATIO(500),BETA(500),ETA(500)
C DIMENSION BLUE(100)
C DIMENSION CE(200)
C
C VOLT=TANK VOLUME IN LITRES VFLR=FLOW IN LITRES/MIN
C TPEAK=PEAK TIME IN MINUTES DYIN=AMOUNT OF DYE IN LITRES
C DYCON=CONC OF DYE IN PPB DT=MINUTES BETWEEN DATA PTS
C N=NUMBER OF DATA PTS
C C(I)=CONC OF DYE IN EFFLUENT PPB
C
C READ 1,VOLT,VFLR,TPEAK,DYIN,DYCON,DT
C PRINT 1,VOLT,VFLR,TPEAK,DYIN,DYCON,DT
C READ 2,N
C PRINT 2,N
C READ 3,(C(I),I=1,N)
C PRINT 3,(C(I),I=1,N)
C
C PERCENT DYE RECOVERY
C
C AMT= C(1)*DT*VFLR*10.**(-6)
C CUL(1) = AMT
C DO 100 I=2,N
C AMT=.5*(C(I)+C(I-1))*DT*VFLR*10.**(-6)
C * LUL = I-1
C CUL(I) = CUL(LUL)+AMT
C 100 CONTINUE

```

```

DYE = DYCON*DYI*10.**(-6)
PER = CUL(N)/DYE*100.
C
C   CALCULATION OF MEAN RESIDENCE TIME OF THE TOTAL DYE RETRIEVED
C   CALCULATION OF PERCENT STAGNANT ZONE
C
TBAR(1) = VOLI/VFLR
ANT = 1.
I = 1
ZONE = CUL(N)/2.
201 IF(CUL(I).GT.ZONE) GO TO 202
ANT = ANT + 1.
I = I + 1
GO TO 201
200 TBAR(2) = ANT*DT
DEAD = (TBAR(1)-TBAR(2))/TBAR(1)
C
C   CALCULATION NUMBER OF TANKS IN SERIES
C
TP1 = TPEAK/TBAR(1)
TP2 = TPEAK/TBAR(2)
TANKS(1) = 1./((TP1*(1./TP1-1.))
TANKS(2) = 1./((TP2*(1./TP2-1.))
C
C   TRUNCATE TO NEAREST WHOLE NUMBER OF TANKS
C
AW(1) = TANKS(1)
AA = 1.5
203 IF(AW(1).LT.AA) GO TO 202
AA = AA + 1.
GO TO 203
202 AW(1) = AA - .5
AW(2) = TANKS(2)
AA = 1.5
205 IF(AW(2).LT.AA) GO TO 204
AA = AA + 1.
GO TO 205
204 AW(2) = AA - .5
C
C   CALCULATION OF TAMPANYS PEAK TIME D/UL VAULES
C
IF((TP1.GT.0.03).AND.(TP1.LT.0.3)) GO TO 206
IF((TP1.GT.0.3).AND.(TP1.LT.0.8)) GO TO 207
GO TO 208
206 DULP(1) = .2*(TP1**(-1.34))
GO TO 209
207 DULP(1) = 4.027*(10.**(-2.09*TP1))
GO TO 209
208 PRINT 300
IF(TP1.LE.0.03) GO TO 206
GO TO 207
209 CONTINUE

```

```

IF ((TP2.GT.0.03).AND.(TP2.LE.1.3)) GO TO 210
IF ((TF2.GT.0.3).AND.(TP2.LE.0.8)) GO TO 211
GO TO 213
210 DULP(?) = .2*(TP2**(-1.34))
GO TO 214
211 DULP(?) = 4.027*(10.**(-2.09*TP2))
GO TO 214
213 PRINT 300
IF (TP2.LE.0.03) GO TO 210
GO TO 211
214 CONTINUE

```

```

C
C CALCULATION OF C/CO VS THETA VALUES FOR CSTR MODELS
C DERIVATIVE AT PEAK DYE CONC METHOD USED
C
DO 101 I=1,2
X=AW(I)**AW(I)
XX=1.
BB=1.
216 IF (AW(I).EQ.B3) GO TO 215
XX=XX*(AW(I)-BB)
BB=BB+1.
GO TO 216
215 FACT = XX
THETA(I,1) = 0.
DO 102 J=2,21
THETA(I,J) = THETA(I,J-1) + .05
102 CCO(I,J) = X/XX*THETA(I,J)**(AW(I)-1.)*EXP(-AW(I)*THETA(I,J))
DO 103 J= 22,37
THETA(I,J) = THETA(I,J-1) + .2
103 CCO(I,J) = X/XX*THETA(I,J)**(AW(I)-1.)*EXP(-AW(I)*THETA(I,J))
101 CONTINUE

```

```

C
C CLACULATION OF ACTUAL C/CO VALUES FROM EXPERIMENTAL DATA
C
CNOT = DYIN*DYCON/VOLT
MM = 0
DRAG = 0.
NN = 0
DO 104 I = 1,30
NN = NN + 3
MM = MM + 1
RATIO(MM) = C(NN)/CNOT
DRAG = DRAG + 3*DT
BETA(MM) = DRAG/TBAR(1)
104 ETA(MM) = DRAG/TBAR(2)
IM = (N-90)/10 + 29
DO 105 I = 31, IM
MM = MM + 1
DRAG = DRAG + 10.*DT
NN = NN + 10
RATIO(MM) = C(NN)/CNOT

```

```
BETA(M,I) = DRAG/IDAR(I)
```

```
ETA(M,I) = DRAG/CNOT
```

```
105 CONTINUE
```

```
C
```

```
C CALCULATION OF C/CO VALUES VS THETA FOR D/W METHOD
```

```
C
```

```
C
```

```
M = 1
```

```
40 I=1
```

```
AMU(M,I)=1.4
```

```
U(M)=.5/DULP(M)
```

```
45 AMU(M,I)=AMU(M,I)-.001
```

```
FR = COS(AMU(M,I))/SIN(AMU(M,I))
```

```
FR = FR - AMU(M,I)*DULP(M) + .25/(AMU(M,I)*DULP(M))
```

```
IF(FR)45,45,50
```

```
50 AMU(M,I) = AMU(M,I) + .00001
```

```
FR = COS(AMU(M,I))/SIN(AMU(M,I))
```

```
FR = FR - AMU(M,I)*DULP(M) + .25/(AMU(M,I)*DULP(M))
```

```
IF(FR)55,50,50
```

```
55 AMU(M,I) = AMU(M,I) - .0000001
```

```
FR = COS(AMU(M,I))/SIN(AMU(M,I))
```

```
FR = FR - AMU(M,I)*DULP(M) + .25/(AMU(M,I)*DULP(M))
```

```
IF(FR)55,55,60
```

```
60 I = I + 1
```

```
AMU(M,I) = AMU(M,I-1)+3.1417
```

```
IF(I.LE.50) GO TO 45
```

```
M = M + 1
```

```
IF(M.LE.2) GO TO 40
```

```
DO 80 M=1,2
```

```
999 ZETA = 0.0
```

```
DO 70 K=1,30
```

```
ZETA = ZETA + .1
```

```
COCO(M,K) = 0.0
```

```
DO 65 I=1,50
```

```
A=2.0*AMU(M,I)*(U(M)*SIN(AMU(M,I)) + AMU(M,I)*COS(AMU(M,I)))
```

```
B=EXP(U(M)-((U(M)**2 + AMU(M,I)**2)/(2.0*U(M)))*ZETA)
```

```
D=U(M)**2 + 2.0*U(M) + AMU(M,I)**2
```

```
998 CE(I) = A*B/D
```

```
COCO(M,K) = COCO(M,K) + CE(I)
```

```
65 CONTINUE
```

```
67 CONTINUE
```

```
70 CONTINUE
```

```
80 CONTINUE
```

```
C
```

```
C PRINT INSTRUCTIONS AND DATA PRESENTATION FORMAT
```

```
C
```

```
PRINT 700
```

```
700 FORMAT(42X,24HTRACER RESPONSE ANALYSIS///)
```

```
PRINT 701
```

```
701 FORMAT(40X,29HROTATING BIOLOGICAL CONTACTOR)
```

```
PRINT 702
```

```
702 FORMAT(42X,26HHYDRAULIC CHARACTERIZATION///)
```



```

PRINT 703
703 FORMAT(30X, #TEST METHOD USING A PULSE INPUT OF ROGAMINE WT DYE#, /)
PRINT 704
704 FORMAT(23X, 37HREACTOR OPERATION AND TEST CONDITIONS///)
PRINT 705, VOLT
705 FORMAT(31X, 20HVOLUME OF REACTOR = ,F7.2, 6HLITRES)
PRINT 706, VFLR
706 FORMAT(31X, 20HHYDRAULIC LOADING = ,F7.2, 10HLITRES/MIN)
PRINT 707, T BAR(1)
707 FORMAT(31X, 20HTHEORETICAL DET = ,F7.2, 3HMIN)
PRINT 708, DYTIN
708 FORMAT(31X, 20HDYE INJECTION = ,F7.4, 6HLITRES)
PRINT 709, DYCON
709 FORMAT(31X, 20HCNC OF DYE ADDED = ,E10.3, 3HPPB)
PRINT 710, CNOT
710 FORMAT(31X, 20HDYE / TANK VOLUME = ,F7.2, 3HPPB, ///)
PRINT 711
711 FORMAT(23X, 34HTEST RESULTS AND CALCULATED VALUES, ///)
PRINT 712, TPEAK
712 FORMAT(31X, 20HDYE PEAK TIME = ,F7.2, 3HMIN)
PRINT 713, TP1
713 FORMAT(31X, 20HPEAK/THEOR DET = ,F7.3/)
PRINT 714, TP2
714 FORMAT(31X, 20HPEAK/MEAN DYE RES = ,F7.3, 3HMIN)
PRINT 715, T BAR(2)
715 FORMAT(31X, #MEAN DYE RESIDENCE =#, F7.2, #MIN#)
PRINT 716, PEP
716 FORMAT(31X, 20HPER DYE RECOVERY = ,F7.3, 1H%)
PRINT 717, DEAD
717 FORMAT(31X, 20HFR. STAGNANT ZONE = ,F7.3, /)
PRINT 718, TANKS(1)
718 FORMAT(31X, 42HCSTR S IN SERIES USING THEOPETICAL RES. = ,F7.2)
PRINT 719, TANKS(2)
719 FORMAT(31X, 42HCSTR S IN SERIES USING MEAN DYE RES. = ,F7.2)
PRINT 720, DULP(1)
720 FORMAT(31X, 42HD/UL VALUE USING THEORETICAL RESIDENCE = ,E11.4)
PRINT 721, DULP(2)
721 FORMAT(31X, 42HD/UL VALUE USING MEAN DYE RESIDENCE = ,E11.4)
PRINT 722
722 FORMAT(31X, 38H EXPERIMENTAL RESULTS C/CO VERSUS THETA, ///)
PRINT 723
723 FORMAT(14X, 5H THETA, 15X, 4HC/CO, ///)
PRINT 724, (BETA(I), RATIO(I), I=1, MM)
724 FORMAT(15X, F5.3, 15X, F5.3)
PRINT 725
725 FORMAT(31X, 35HCALCULATED C/CO VERSUS THETA VALUES)
PRINT 726
726 FORMAT(37X, 24HFOR CSTR IN SERIES MODEL, ///)
PRINT 727
727 FORMAT(12X, #THEORETICAL DETENSION ACTUAL DETENSION#, /)
PRINT 728
728 FORMAT(15X, 5H THETA, 6X, 4HC/CO, 15X, 5H THETA, 6X, 4HC/CO, ///)

```

```
PRINT 729, (THETA(1,J),COC(1,J),THETA(2,J),COC(2,J),J=1,37)
729 FORMAT (15X,F5.3,6X,F5.3,15X,F5.3,6X,F5.3)
PRINT 725
PRINT 730
730 FORMAT (26X,20HFOR DISPERSION MODEL,////)
PRINT 727
BLUE(1) = .1
DO 731 K=2,30
BLUE(K) = BLUE(K-1) + .1
731 CONTINUE
PRINT 729, (BLUE(K),COC(1,K),BLUE(K),COC(2,K),K=1,30)
1 FORMAT (4F10.4,E10.2,F10.4)
2 FORMAT (I10)
3 FORMAT (5F10:2)
300 FORMAT (10X,44HPEAK TIME OUTSIDE LIMIT FOR DZUL CALCULATION)
STOP
END
```

APPENDIX E

Effect of SRT and Temperature Variables on Nitrification

The complete factorial design at five levels of temperature and three levels of SRT (Table 10) allowed the effects of these factors on the output responses (filterable TKN removal and unit rate of filterable TKN removal) to be determined through an ANOVA (Tables E1 and E2). The factorial design, replicated once, allowed determination of the main effects of each variable and the two-factor interaction (Tables 11 and 12). SRT and temperature being quantitative factors, made it desirable to examine the relationship between the observed responses and the levels of each factor. The relationship between the response and the level of the factor can normally be approximated over a finite range of the factor by means of a polynomial. When the levels of the factor are at equal intervals the components of the polynomial linear, quadratic, etc., are all orthogonal to one another facilitating their determination. Calculating the components of the main effect of each factor (SRT and temperature), effectively gives the average shape of the curve relating the response to the level of the factor. It is possible for the shape of the curve describing the relationship between the response and one factor to change from one level of the other factor to another. This will be revealed by a detailed analysis of the two-factor interaction. For example, from Table E2 the interaction analysis for the combined sludge systems, SSC and TSC, reveals significant interactions of linear A (SRT) with linear B (Temperature) and quadratic B indicating the linear effect of A differs for different levels of B.

The methods and calculations involved in preparing the detailed ANOVA's are outlined in Design and Analysis of Industrial Experiments (1956).

Pseudo "Steady-State" Reparameterised Arrhenius Models

The analysis of variance results for the reparameterised Arrhenius models, describing the unit rate of filterable TKN removal and the filterable TKN removal as functions of temperature (Figures 13, 14, 15, 17, 18, and 19), were established from the use of a non-linear least squares routine. An example of the use of the computer program including the output results appears in Table E6. The sum of squares after regression

TABLE E1 DETAILED EFFECTS OF SYSTEM SRT AND TEMPERATURE ON FILTERABLE TKN REMOVAL IN SEPARATE AND COMBINED SLUDGE SYSTEMS

Source of Variation	Sum of Squares	Degrees of Freedom	Mean Square (MS)	Variance Ratio (MS/MSPE)	F $\alpha=.95$
<u>Main Effects</u>					
<u>SRT (A):</u>					
TSS	935.64	2	467.82	14.49	3.68
Components - Linear	907.21	1	907.21	28.10	4.54
- Quadratic	28.43	1	28.43	0.88	4.54
SSC or TSC	886.20	2	443.10	15.10	3.68
Components - Linear	869.88	1	869.88	29.65	4.54
- Quadratic	16.32	1	16.32	0.56	4.54
<u>Temperature (B):</u>					
TSS	7339.02	4	1834.75	56.84	3.06
Components - Linear	7078.55	1	7078.55	219.29	4.54
- Quadratic	142.88	1	142.88	5.43	4.54
- Cubic	83.08	1	83.08	2.57	4.54
- Quartic	34.51	1	34.51	1.07	4.54
SSC or TSC	10091.20	4	2552.80	85.96	3.06
Components - Linear	9370.00	1	9370.00	319.36	4.54
- Quadratic	527.00	1	527.20	17.96	4.54
- Cubic	153.28	1	153.28	5.22	4.54
- Quartic	46.92	1	40.92	1.40	4.54
<u>SRT-Temperature Interactions:</u>					
TSS	364.97	8	45.62	1.41	2.64
Components - Linear A x Linear B	44.95	1	44.95	1.39	4.54
- Linear A x Quadratic B	208.29	1	208.29	6.45	4.54
- Quadratic A x Linear B	1.05	1	1.05	0.03	4.54
- Quadratic A x Quadratic B	18.40	1	18.40	0.57	4.54
- *Remainder	92.28	4	23.04	0.71	3.06
SSC or TSC	442.01	8	55.25	1.88	2.64
Components - Linear A x Linear B	110.89	1	110.89	3.77	4.54
- Linear A x Quadratic B	189.44	1	189.44	6.46	4.54
- Quadratic A x Linear B	6.26	1	6.26	0.21	4.54
- Quadratic A x Quadratic B	63.15	1	63.15	2.15	4.54
- *Remainder	72.27	4	72.27	0.62	3.06
<u>Pure Error (PE):</u>					
TSS	484.23	15	32.28	-	-
SSC or TSC	440.15	15	29.34	-	-
Note:	*Remainder = Cubic B x Linear A Cubic B x Quadratic A Quartic B x Linear A Quartic B x Quadratic A				

TABLE E2 DETAILED EFFECTS OF SYSTEM SRT AND TEMPERATURE ON UNIT RATE OF FILTERABLE TKN REMOVAL IN SEPARATE AND COMBINED SLUDGE SYSTEMS

Source of Variation	*Sum of Squares	Degrees of Freedom	*Mean Square (MS)	Variance Ratio (MS/MSPE)	F $\alpha=.95$
<u>Main Effects</u>					
<u>SRT(A):</u>					
TSS	2.64	2	1.32	2.75	3.68
Components - Linear	0.24	1	0.24	0.50	4.54
- Quadratic	2.40	1	2.40	5.00	4.54
SSC or TSC	1.56	2	0.78	13.00	3.68
Components - Linear	0.74	1	0.74	12.30	4.54
- Quadratic	0.82	1	0.82	13.70	4.54
<u>Temperature (B):</u>					
TSS	125.98	4	31.50	65.61	3.06
Components - Linear	103.65	1	103.65	215.90	4.54
- Quadratic	17.17	1	17.17	35.77	4.54
- Cubic	4.54	1	4.54	9.46	4.54
- Quartic	0.62	1	0.62	1.29	4.54
SSC or TSC	18.84	4	4.71	78.50	3.06
Components - Linear	16.80	1	16.80	280.00	4.54
- Quadratic	1.55	1	1.55	25.83	4.54
- Cubic	0.46	1	0.46	7.67	4.54
- Quartic	0.03	1	0.03	0.50	4.54
<u>SRT-Temperature Interactions:</u>					
TSS	13.50	8	1.69	3.52	2.64
Components - Linear A x Linear B	3.95	1	3.95	8.27	4.54
- Linear A x Quadratic B	2.30	1	2.30	4.94	4.54
- Quadratic A x Linear B	3.15	1	3.15	6.58	4.54
- Quadratic A x Quadratic B	1.81	1	1.81	3.77	4.54
-**Remainder	2.19	4	0.55	1.15	3.06
SSC or TSC	4.82	8	0.60	10.04	2.64
Components - Linear A x Linear B	2.05	1	2.05	34.17	4.54
- Linear A x Quadratic B	0.59	1	0.59	9.83	4.54
- Quadratic A x Linear B	1.18	1	1.18	19.67	4.54
- Quadratic A x Quadratic B	0.46	1	0.46	7.67	4.54
- **Remainder	0.54	4	0.14	2.33	3.06
<u>Pure Error (PE):</u>					
TSS	7.18	15	0.48	-	-
SSC or TSC	0.86	15	0.06	-	-
Note:	*values x 10 ³				
	** Remainder = Cubic B x Linear A				
	Cubic B x Quadratic A				
	Quartic B x Linear A				
	Quartic B x Quadratic A				

result was used in preparation of Table E3. The pure error sum of squares was determined from repeats (Himmelblau, 1970). In determining ANOVA results for the pooled models (Table E4 and E5) the pure error was estimated by a pooled sum of squares based on individual pure error values and related degrees of freedom.

TABLE E3 ANOVA FOR REPARAMETERIZED ARRHENIUS MODEL FOR COMBINED
SLUDGE UNIT RATE RESULTS 10 DAY SRT

Source of Variation	*Sum of Squares (SS)	Degrees of Freedom	*Mean Square (MS)	MSLOF MSPE	F $\alpha = .95$
(Reparameterized Model: $K = 0.0308 \cdot e^{-12450/R} \left(\frac{1}{T} - \frac{1}{T_0} \right)$)					
After Regression	0.397	9	0.044		
Pure Error (PE)	0.293	5	0.059		
Lack of Fit (LOF)	0.104	4	0.026	0.45	5.19
Note: * values x 10^3					

TABLE E4 ANOVA FOR REPARAMETERIZED ARRHENIUS MODEL FOR COMBINED SLUDGE UNIT RATE RESULTS 4, 7, AND 10 DAY SRT WITH k/k^*

Source of Variation	Sum of Squares (SS)	Degrees of Freedom	Mean Square (MS)	MSLOF / MSPE	F $\alpha = .95$	F $\alpha = .99$
(Reparameterized Model: $k/k^* = e^{-17600/R} \left(\frac{1}{T} - \frac{1}{T_0} \right)$)						
After Regression	11.639	53	0.220			
Pure Error (PE)	0.544	32	0.017			
Lack of Fit (LOF)	11.095	21	0.528			
				31.08	1.9	2.5

TABLE E5 ANOVA FOR REPARAMATERIZED ARRHENIUS MODEL FOR COMBINED SLUDGE FILTERABLE TKN REMOVAL RESULTS 4, 7, AND 10 DAY SRT WITH K/K*

Source of Variation	Sum of Squares (SS)	Degrees of Freedom	Mean Square (MS)	MSLOF / MSPE	F $\alpha = .95$	F $\alpha = .99$
(Reparameterized Model: $K/K^* = e^{-15400/R (\frac{1}{T} - \frac{1}{T_0})}$)						
After Regression	2.865	53	0.054			
Pure Error (PE)	0.342	32	0.011			
Lack of Fit (LOF)	2.523	21	0.120	10.92	1.9	2.5

```

PROGRAM SUTTON
DIMENSION X(26),Y(26),SCRAT(300)
DIMENSION TH(2), SIGNS(2), DIFF(2)
COMMON X
EXTERNAL MODEL
3 READ 4,NOB,TH(1),TH(2),JS
IF(IFEQ(60),EQ,-1) STOP
4 FORMAT(I3,F10.3,F10.3,I3)
DO 10 I=1,NOB
READ 1000,X(I),Y(I)
1000 FORMAT(7X,F7.5,F7.4)
10 PRINT 1000, X(I), Y(I)
PRINT 4,(NOB,TH(1),TH(2))
PRINT 6,JS
5 FORMAT(20X,144PROBLEM NUMBER, I3)
SIGNS(1)=1
SIGNS(2)=1
DIFF(1)=.01
DIFF(2)=.01
EPS1=1.0E-7
EPS2=1.0E-7
CALL UWHAUS(1,MODEL,NOB,Y,2,TH,DIFF,SIGNS,EPS1,EPS2,
610,.01,10.,SCRAT)
GO TO 3
END

```

```

SUBROUTINE MODEL (NPROB,TH,F,NOB,NP)
COMMON X
DIMENSION TH(1),F(1),X(26)
DO 10 I=1,NOB
10 F(I)=TH(2)*EXP(TH(1)*X(I))
RETURN
END

```

```

SUBROUTINE UWHAUS(NPROB,MODEL,NOB,Y,NP,TH,DIFF,SIGNS,EPS1,EPS2,
1 MIT, FLAM, FNU, SCRAT)
DIMENSION SCRAT(1)
IA=1
IB=IA+NP
IC=IB+NP
ID=IC+NP
IE=ID+NP
IF=IE+NP
IG=IF+NOB
IH=IG+NOB
II = IH + NP * NOB
IJ = IH
CALL HAUS59(NPROB,MODEL,NOB,Y,NP,TH,DIFF,SIGNS,EPS1,EPS2,MIT
1 ,FLAM,FNU,SCRAT(IA), SCRAT(IB), SCRAT(IC), SCRAT(ID),
2 SCRAT(IE), SCRAT(IF), SCRAT(IG), SCRAT(IH), SCRAT(II),
3 SCRAT(IJ) )
RETURN
END

```

```

SUBROUTINE HAUS59(NPRB0, MODEL, NBO, Y, NQ, TH, DIFZ, SIGNS, EP1S, -P5,
1MIT, FLAM, FNU, Q, P, E, PHI, T8, F, R, A, D, DELZ)
C
C      FORTRAN II VERSION
C      W. J. WERTZ
C      ADAPTED FOR THE CDC 6400 (J. F. MACGREGOR)
C
C      DIMENSION TH(NQ), DIFZ(NQ), SIGNS(NQ), Y(NBO)
C      DIMENSION Q(NQ), P(NQ), F(NQ), PHI(NQ), T8(NQ)
C      DIMENSION F(NBO), R(NBO)
C      DIMENSION A(NQ,NO), D(NQ,NQ), DELZ(NBO,NO)
C      DIMENSION TH(1), DIFZ(1), SIGNS(1), Y(1), Q(1), P(1), E(1),
1 PHI(1), T8(1), F(1), R(1), A(1), D(1), DELZ(1)
ACOS(X) = ATAN(SQRT(1.0/X2+2 - 1.0))
NP = NQ
NPROB = NPRB0
NOB = NBO
EPS1 = EP1S
EPS2 = EP2S
NPSQ = NP * NP
NSCRAC = 5*NP+NPSQ +2*NOB+NP-NOB
PRINT 1000, NPROB, NOB, NP, NSCRAC
PRINT 1001
CALL GASS60(1, NP, TH, TEMP, TMEP)
PRINT 1002
CALL GASS60(1, NP, DIFZ, TEMP, TMEP)
IF(MINJ(NP-1,50-NP,NOB-NP,MIT-1,999-MIT)) 99,15,15
15 IF(FNU-1.0) 99, 99, 16
16 CONTINUE
DO 19 I=1, NP
TEMP = ABS(DIFZ(I))
IF(AMIN1(1.0-TEMP, ABS(TH(I)))) 99, 99, 19
19 CONTINUE
GA = FLAM
NIT = 1
LAOS = 0
IF(EPS1) 5,70,70
5 EPS1 = 0
70 SSQ = 0
CALL MODEL(NPROB, TH, F, NOB, NP)
DO 90 I = 1, NOB
R(I) = Y(I) - F(I)
90 SSQ=SSQ+R(I)*R(I)
PRINT 1003, SSQ
C
C
C      BEGIN ITERATION
C
100 GA = GA / FNU
INTCNT = 0
PRINT 1004, NIT
101 JS = 1 - NOB
DO 130 J=1, NP
TEMP = TH(J)

```

```

P(J)=QIFZ(J)*TH(J)
TH(J)= TH(J)+P(J)
Q(J)=C
JS = JS + NOB
CALL MODEL(NPROB, TH, DELZ(JS), NOB, NPI)
IJ = JS-1
DO 120 I = 1, NOB
  IJ = IJ + 1
  DELZ(IJ) = DELZ(IJ) - F(I)
120 Q(J) = Q(J) + DELZ(IJ) * P(I)
  Q(J)= Q(J)/P(J)
C
Q=XT-R (STEEPEST DESCENT)
130 TH(J) = TEMP
  IF(LAOS) 131,131,414
131 DO 150 I = 1, NP
  DO 151 J=1, I
  SUM = 0
  KJ = NOB*(J-1)
  KI = NOB*(I-1)
  DO 160 K = 1, NOB
  KI = KI + 1
  KJ = KJ + 1
160 SUM = SUM + DELZ(KI) * DELZ(KJ)
  TEMP= SUM/(P(I)+P(J))
  JI = J + NP*(I-1)
  D(JI) = TEMP
  IJ = I + NP*(J-1)
151 D(IJ) = TEMP
150 E(I) = SORT(D(JI))
666 CONTINUE
  DO 153 I = 1, NP
  IJ = I-NP
  DO 153 J=1, I
  IJ = IJ + NP
  A(IJ) = D(IJ) / (E(I)+E(J))
  JI = J + NP*(I-1)
153 A(JI) = A(IJ)
C
A= SCALED MOMENT MATRIX
  II = - NP
  DO 155 I=1, NP
  P(I)=Q(I)/E(I)
  PHI(I)=P(I)
  II = NP + 1 + II
155 A(II) = A(II) + GA
C
I=1
CALL MATIN(A, NP, P, I, DET)
C
P/E = CORRECTION VECTOR
  STEP=1.0
  SUM1=0.
  SUM2=0.
  SUM3=0.

```

```
SUBROUTINE GASS60(ITYPE, NQ, A, B, C)
DIMENSION A(NQ), B(NQ), C(NQ, NQ)
NP = NQ
NP = NP/10
LOW = 1
LUP = 10
10 IF ( NR )15, 20, 30
15 RETURN
20 LUP=NP
   IF(LOW .GT. LUP) RETURN
30 PRINT 500, (J, J=LOW, LUP)
   GO TO (40, 60, 80), ITYPE
+0 PRINT 600, (A(J), J=LOW, LUP)
   GO TO 100
50 PRINT 600, (B(J), J=LOW, LUP)
   GO TO 40
80 DO 90 I=LOW, LUP
90 PRINT 720, I, (C(J, I), J=LOW, I)
   LOW2=LUP+1
   IF(LOW2 .GT. NP) GO TO 100
   DO 95 I=LOW2, NP
95 PRINT 720, I, (C(J, I), J=LOW, LUP)
100 LOW = LOW + 10
   LUP = LUP + 10
   NR = NR - 1
   GO TO 10
500 FORMAT(/I8, 9I12)
600 FORMAT(10E12.4)
720 FORMAT(1H0, I3, 1X, F7.4, 9F12.4)
1 CONTINUE
RETURN
END
```

NON-LINEAR ESTIMATION, PROBLEM NUMBER : COMBINED SLUDGE SSRT = 10 DAYS11 OBSERVATIONS, 2 PARAMETERS 58 SCRATCH REQUIRED

INITIAL PARAMETER VALUES

1	2
-0.7000E+04	0.7000E-02

PROPORTIONS USED IN CALCULATING DIFFERENCE QUOTIENTS

1	2
0.1000E-01	0.1000E-01

INITIAL SUM OF SQUARES = 0.9774E-02

		ITERATION NO.	1
DETERMINANT =	0.3935E+00	ANGLE IN SCALED COORD. =	41.57 DEGREES

TEST POINT PARAMETER VALUES	
-0.3981E+04	0.3069E-01

TEST POINT SUM OF SQUARES = 0.1014E-02

PARAMETER VALUES VIA REGRESSION

1	2
-0.3981E+04	0.3069E-01

LAMBDA =	0.100E-02	SUM OF SQUARES
		AFTER REGRESSION = 0.101385 E-02

		ITERATION NO.	2
DETERMINANT =	0.7160E+00	ANGLE IN SCALED COORD. =	25.33 DEGREES

TEST POINT PARAMETER VALUES	
-0.6333E+04	0.3133E-01

TEST POINT SUM OF SQUARES = 0.4066E-03

PARAMETER VALUES VIA REGRESSION

1	2
-0.6333E+04	0.3133E-01

LAMBDA =	0.100E-03	SUM OF SQUARES
		AFTER REGRESSION = 0.4065500E-03

ITERATION NO. 3

DETERMINANT = 0.4524E+03 ANGLE IN SCALED COORD. = 13.830 DEGREES

TEST POINT PARAMETER VALUES

-0.6258E+04 0.3076E-01

TEST POINT SUM OF SQUARES = 0.3963E-03

PARAMETER VALUES VIA REGRESSION

1	2
-0.6258E+04	0.3076E-01

LAMBDA = 0.100E-04

SUM OF SQUARES
AFTER REGRESSION = 0.3968095 E-03

ITERATION NO. 4

DETERMINANT = 0.4596E+00 ANGLE IN SCALED COORD. = 45.39 DEGREES

TEST POINT PARAMETER VALUES

-0.6254E+04 0.3076E-01

TEST POINT SUM OF SQUARES = 0.3963E-03

PARAMETER VALUES VIA REGRESSION

1	2
-0.6254E+04	0.3076E-01

LAMBDA = 0.100E-05

SUM OF SQUARES
AFTER REGRESSION = 0.3968077 E-03

ITERATION NO. 5

DETERMINANT = 0.4600E+00 ANGLE IN SCALED COORD. = 43.27 DEGREES

TEST POINT PARAMETER VALUES

-0.6254E+04 0.3076E-01

TEST POINT SUM OF SQUARES = 0.3963E-03

PARAMETER VALUES VIA REGRESSION

1	2
-0.6254E+04	0.3076E-01

LAMBDA = 0.100E-06

SUM OF SQUARES
AFTER REGRESSION = 0.3968077E-03

FINAL FUNCTION VALUES

0.4477E-01	0.2114E-01	0.3076E-01	0.6516E-01	0.1364E-01	0.1364E-01
0.2114 E-01	0.2395 E-01	0.3076E-01	0.4477 E-01	0.6516E-01	

RESIDUALS

-0.1367E-01	0.1063E-02	0.3038E-02	0.5942E-02	0.7570E-03	-0.2143E-02
-0.9371 E-03	0.8446E-02	-0.5662E-02	0.6829 E-02	-0.9371 E-03	

CORRELATION MATRIX

	1	2
1	1.0000	
2	0.7348	1.0000

NORMALIZING ELEMENTS

	1	2
1	0.1212E+06	0.3560E+00

VARIANCE OF RESIDUALS = 0.4409E-04, 9 DEGREES OF FREEDOM

INDIVIDUAL CONFIDENCE LIMITS FOR EACH PARAMETER (ON LINEAR HYPOTHESIS)

	1	2
1	-0.4645E+04	0.3549E-01
2	-0.7864E+04	0.2603E-01

APPROXIMATE CONFIDENCE LIMITS FOR EACH FUNCTION VALUE

0.4949E-01	0.2608E-01	0.3549E-01	0.7376E-01	0.1825E-01	0.1825E-01
0.4005E-01	0.1619E-01	0.2603E-01	0.5656E-01	0.9035E-02	0.9035E-02
0.2608 E-01	0.2888E-01	0.3549E-01	0.4949E-01	0.7376E-01	
0.1619 E-01	0.1903E-01	0.2603E-01	0.4005E-01	0.5056E-01	


```

IF (NIT - MIT) 100, 100, 280
2700 PRINT 2710
2710 FORMAT (//115H)**** THE SUM OF SQUARES CANNOT BE REDUCED TO THE SUM
      10F SQUARES AT THE END OF THE LAST ITERATION - ITERATING STOPS //)
C
C
C
280 PRINT 1011
PRINT 2001, (F(I), I = 1, NOB)
PRINT 1012
PRINT 2001, (R(I), I = 1, NOB)
SSQ=SUM9
IOF=NOB-NP
PRINT 1015
I=0
CALL MATIN(D, NP, P, I, DET)
DO 7692 I=1, NP
II = I + NP*(I-1)
7692 E(I) = SQRT(D(II))
DO 340 I=1, NP
JI = I + NP*(I-1) - 1
IJ = I + NP*(I-2)
DO 340 J = I, NP
JI = JI + 1
A(JI) = D(JI) / (E(I)*E(J))
IJ = IJ + NP
340 A(IJ) = A(JI)
CALL GASS60(3, NP, TEMP, TEMP, A)
PRINT 1016
CALL GASS60(1, NP, E, TEMP, TEMP)
IF(IOF) 341, 410, 341
341 SDEV = SSQ / IOF
PRINT 1014, SDEV, IOF
SDEV = SQRT(SDEV)
DO 391 I=1, NP
P(I)=TH(I)+2.0*E(I)*SDEV
391 TB(I)=TH(I)-2.0*E(I)*SDEV
PRINT 1039
CALL GASS60(2, NP, TB, P, TEMP)
LAOS = 1
GO TO 101
414 DO 415 K = 1, NOB
TEMP = 0
DO 420 I=1, NP
DO 420 J=1, NP
ISUB = K+NOB*(I-1)
DEBUG1 = DELZ(ISUB)
C DEBUG1 = DELZ(K + NOB*(I-1))
ISUB = K+NOB*(J-1)
DEBUG2 = DELZ(ISUB)
C DEBUG2 = DELZ(K + NOB*(J-1))
IJ = I + NP*(J-1)

```

```

DO 231 I=1, NP
SUM1=P(I)*PHI(I)+SUM1
SUM2=P(I)*P(I)+SUM2
SUM3= PHI(I) * PHI(I) + SU 13
231 PHI(I) = P(I)
TEMP = SUM1/SQRT(SUM2*SUM3)
TEMP = AMIN1(TEMP, 1.0)
TEMP = 37.235*ACOS(TEMP)
PRINT 1041, DET, TEMP
170 DO 220 I = 1, NP
P(I) = PHI(I) *STEP / E(I)
TB(I) = TH(I) + P(I)
220 CONTINUE
PRINT 7000
7000 FORMAT(30H0 TEST POINT PARAMETER VALUES )
PRINT 2006, (TB(I), I = 1, NP)
DO 221 I = 1, NP
IF (SIGNS(I)) 221, 221, 222
222 IF (SIGN(1.0,TH(I))*SIGN(1.0,TB(I))) 563, 221, 221
221 CONTINUE
SUMB=0
CALL MODEL(NPROB, TB, F, NOB, NP)
DO 230 I=1,NOB
R(I)=Y(I)-F(I)
230 SUMB=SUMB+R(I)*R(I)
PRINT 1043, SUMB
IF (SUMB - (1.0+EPS1)*SSQ) 662, 662, 663
563 IF ( AMIN1(TEMP-30.0, GA)) 665, 665, 664
665 STEP=STEP/2.0
INTCNT = INTCNT + 1
IF (INTCNT - 36) 170, 2700, 2700
664 GA=GA*FNU
INTCNT = INTCNT + 1
IF (INTCNT - 36) 666, 2700, 2700
662 PRINT 1007
DO 669 I=1, NP
669 TH(I)=TB(I)
CALL GASS60(1, NP, TH, TEMP, TEMP)
PRINT 1040, GA, SUMB
IF (EPS2) 229,229,225
229 IF (EPS1) 270,270,265
225 DO 240 I = 1, NP
IF (ABS(P(I))/(1.E-20+ABS(TH(I)))) > EPS2) 240, 240, 241
241 IF (EPS1) 270,270,265
240 CONTINUE
PRINT 1009, EPS2
GO TO 280
265 IF (ABS(SUMB - SSQ) > EPS1*SSQ) 266, 266, 270
266 PRINT 1010, EPS1
GO TO 280
270 SSQ=SUMB
NIT=NIT+1

```

```

DEBUG3 = D(IJ)/(DIFZ(I)*TH(I)+DIFZ(J)*TH(J))
420 TEMP = TEMP + DEBUG1 - DEBUG2 - DEBUG3
    TEMP = 2.0*SQRT(TEMP)*SDEV
    R(K)=F(K)+TEMP
415 F(K)=F(K)-TEMP
    PRINT 1008
    IE=0
    DO +25 I=1,N03,10
    IE=IE+10
    IF(N03-IE) 430,435,435
430 IE=N03
435 PRINT 2001, (R(J), J = I, IE)
425 PRINT 2006, (F(J), J = I, IE)
+10 PRINT 1033, NPROB
    RETURN
99 PRINT 1034
    GO TO 410
10000FORMAT(38H1NON-LINEAR ESTIMATION, PROBLEM NUMBER I3, // I5,
    1 14H OBSERVATIONS, I5, 11H PARAMETERS I14, 17H SCRATCH REQUIRED)
1001 FORMAT(/25H0INITIAL PARAMETER VALUES )
1002 FORMAT(/54H0PROPORTIONS USED IN CALCULATING DIFFERENCE QUOTIENTS )
1003 FORMAT(/25H0INITIAL SUM OF SQUARES = E12.4)
1004 FORMAT(////45X,13HITERATION NO. I4)
1007 FORMAT(/32H0PARAMETER VALUES VIA REGRESSION )
1008 FORMAT(////54H0APPROXIMATE CONFIDENCE LIMITS FOR EACH FUNCTION VAL
10E )
10090FORMAT(/62H0ITERATION STOPS - RELATIVE CHANGE IN EACH PARAMETER LE
15S THAN E12.4)
10100FORMAT(/62H0ITERATION STOPS - RELATIVE CHANGE IN SUM OF SQUARES LE
15S THAN E12.4)
1011 FORMAT(22H1FINAL FUNCTION VALUES )
1012 FORMAT(////10H0RESIDUALS )
1014 FORMAT(/24H0VARIANCE OF RESIDUALS = ,E12.4,1H,I4,
120H DEGREES OF FREEDOM )
1015 FORMAT(////19H0CORRELATION MATRIX )
1016 FORMAT(////21H0NORMALIZING ELEMENTS )
1033 FORMAT(/19H0END OF PROBLEM NO. I3)
1034 FORMAT(/16H0PARAMETER ERROR )
10390FORMAT(/71H0INDIVIDUAL CONFIDENCE LIMITS FOR EACH PARAMETER (ON LI
1NEAR HYPOTHESIS) )
10400FORMAT(/9H0LAMBDA =E10.3,40X,33HSUM OF SQUARES AFTER REGRESSION =
1E15.7)
1041 FORMAT(14H DETERMINANT = E12.+, 6X, 25H ANGLE IN SCALED COORD. =
1 F5.2, 8HDEGREES )
1043 FORMAT(28H0TEST POINT SUM OF SQUARES = E12.4)
2001 FORMAT(/10E12.4)
2006 FORMAT(10E12.4)
    END

```

```
SUBROUTINE MATIN(A, NVAR, B, NB, DET)
```

```
  DIMENSION A(NVAR, 1), B(NVAR, 1)
```

```
  COMMON/GASPAR/DUMIES(7), PIVOTM
```

```
  PIVOTM = A(1,1)
```

```
  DET = 1.0
```

```
  DO 550 ICOL = 1, NVAR
```

```
    PIVOT = A(ICOL, ICOL)
```

```
    PIVOTM = AMIN1(PIVOT, PIVOTM)
```

```
    DET = PIVOT * DET
```

```
  C
```

```
  C    DIVIDE PIVOT ROW BY PIVOT ELEMENT
```

```
  C
```

```
    A(ICOL, ICOL) = 1.0
```

```
    PIVOT = AMAX1(PIVOT, 1.E-23)
```

```
    PIVOT = A(ICOL, ICOL)/PIVOT
```

```
    DO 350 L=1, NVAR
```

```
  350  A(ICOL, L) = A(ICOL, L)*PIVOT
```

```
    IF(NB .EQ. 0) GO TO 371
```

```
    DO 370 L=1, NB
```

```
  370  B(ICOL, L) = B(ICOL, L)*PIVOT
```

```
  C
```

```
  C    REDUCE NON-PIVOT ROWS
```

```
  C
```

```
  371  DO 550 L1=1, NVAR
```

```
    IF(L1 .EQ. ICOL) GO TO 550
```

```
    T = A(L1, ICOL)
```

```
    A(L1, ICOL) = 0.
```

```
    DO 450 L=1, NVAR
```

```
  450  A(L1, L) = A(L1, L) - A(ICOL, L)*T
```

```
    IF(NB .EQ. 0) GO TO 550
```

```
    DO 500 L=1, NB
```

```
  500  B(L1, L) = B(L1, L) - B(ICOL, L)*T
```

```
  550  CONTINUE
```

```
    RETURN
```

```
    END
```

APPENDIX F

Development of Transfer Function-Noise Models

A number of transfer function-noise models (TF-N) describing the effluent filterable TKN and NO_3^- -N from the combined and separate sludge systems (Tables F1 and F2) were developed according to the iterative procedure described previously using the results from experiment D5. The computer programs involved in the development of model number C1 (Table F1) including calculation of the cross correlations and impulse response weights (Table F4), estimation of the parameters of the tentatively identified transfer function model (Table F5), and the re-estimating of the parameters of the combined TF-N model (Table F6) are presented as examples. In determining the most appropriate models to represent the results the methods included statistical comparison techniques and individual evaluation through diagnostic checking.

The comparison techniques involved extra sums of squares testing (Draper and Smith, 1968) in which more elaborate models containing a greater number of parameters were compared to simpler forms and the significance of the extra parameters assessed. Individual diagnostic evaluation involved assessment of the autocorrelation function of the residuals and cross correlations between the residuals and the input variables. Assuming the form of the TF-N model was correct and that the true parameter values are known, then the estimated autocorrelation function of the residuals would be uncorrelated and distributed normally about zero with variance n^{-1} , where n is the number of data points in the series. A further assessment of the residuals involves taking the first k autocorrelations and computing the Q statistic (Table F3). Comparing the result to the chi-square distribution (χ^2) with $k-p-q$ degrees of freedom, where $p+q$ is the total number of parameters of the noise model, determines the significance of the residuals. In a similar manner the significance of the cross correlations between the residuals and the stationary input series for each variable can be computed by comparing the S statistic to the χ^2 distribution (Table F3)

TABLE F1 TRANSFER FUNCTION - NOISE MODELS FOR COMBINED SLUDGE SYSTEM

Output Variable	Model No.	Model	Sum of Squares	Residuals Degrees of Freedom	Mean Square
Filterable TKN	C1	$Y_t = \frac{0.011 \pm 0.004}{1 - 0.786 \pm 0.106\beta} X1_{t-1}$ $+ \frac{1}{1 - 1.066 \pm 0.177\beta + 0.336 \pm 0.175\beta z} \text{ at}$	292.4	116	2.52
	C2	$Y_t = \frac{0.012 \pm 0.004}{1 - 0.731 \pm 0.131\beta} X1_{t-1}$ $+ \frac{1}{1 - 0.796 \pm 0.111\beta} \text{ at}$	327.4	117	2.80
	C3	$Y_t = (0.151 \pm 0.065 + 0.148 \pm 0.065\beta) X2_{t-1}$ $+ 1.395 \pm 0.957 X4_{t-2}$ $+ \frac{1}{1 - 0.857 \pm 0.091\beta} \text{ at}$	308.5	116	2.67
NO ₃ -N	C4	$Y_t = 0.051 \pm 0.075 X2_{t-3}$ $- \frac{0.003 \pm 0.002}{1 - 0.744 \pm 0.310\beta} X3_{t-3}$ $+ \frac{1}{1 - 0.889 \pm 0.083\beta} \text{ at}$	383.0	116	3.30
	C5	$Y_t = \frac{0.052 \pm 0.076}{1 + 0.115 \pm 1.05\beta} X2_{t-3}$	382.9	115	3.33

TABLE F1 (Cont'd)

Output Variable	Model No.	Model	Sum of Squares	Residuals Degrees of Freedom	Mean Square
		$- \frac{0.003 \pm 0.002}{1-0.737 \pm 0.319\beta} X_{3,t-3}$ $+ \frac{1}{1-0.889 \pm 0.083\beta} \text{ at}$			
	C6	$Y_t = \frac{-0.0036 \pm 0.0022}{1-0.650 \pm 0.268\beta} X_{3,t-3}$ $+ \frac{1}{1-0.883 \pm 0.082\beta} \text{ at}$	396.03	117	3.39
<p>where X_1 = TKN (filterable) loading (g/day), X_2 = Influent TKN (filterable) concentration (mg/l), and X_3 = OC (filterable) loading.</p>					

TABLE F2 TRANSFER FUNCTION - NOISE MODELS FOR SEPARATE SLUDGE SYSTEM

Output Variable	Model No.	Model	Sum of Squares	Degrees of Freedom	Residuals Mean Square
Filterable TKN	S1	$Y_t = \frac{0.012 \pm 0.003}{1 - 0.550 \pm 0.148 \beta} + \frac{0.008 \pm 0.003 \beta}{X1_{t-1}}$	90.5	115	0.79
		$+ \frac{1}{1 - 1.394 \pm 0.158 \beta + 0.540 \pm 0.157 \beta z} \text{ at}$			
	S2	$Y_t = \frac{0.090 \pm 0.040}{1 - 0.552 \pm 0.181 \beta} + \frac{0.111 \pm 0.047 \beta}{X2_{t-1}}$	118.9	114	1.04
		$+ 0.502 \pm 0.548 X4_{t-2}$			
NO ₃ -N	S3	$Y_t = \frac{0.004 \pm 0.002}{1 - 0.815 \pm 0.151 \beta} + \frac{0.543 \pm 0.157 \beta z}{X3_{t-1}}$	210.9	115	7.83
		$+ \frac{1}{1 - 1.127 \pm 0.183 \beta + 0.221 \pm 0.182 \beta z} \text{ at}$			
	S4	$Y_t = \frac{0.048 \pm 0.054}{1 + 0.119 \pm 1.033 \beta} + \frac{0.222 \pm 0.182 \beta z}{X2_{t-3}}$	210.8	114	1.85
		$- \frac{0.004 \pm 0.002}{1 - 0.815 \pm 0.153 \beta} + \frac{1}{1 - 1.129 \pm 0.184 \beta + 0.222 \pm 0.182 \beta z} \text{ at}$			

TABLE F2 (Cont'd)

Output Variable	Model No.	Model	Sum of Squares	Degrees of Freedom	Residuals Mean Square
	S5	$Y_t = \frac{-0.003 \pm 0.002}{1 - 0.822 \pm 0.160 \beta} X_3 t^{-1}$ $+ \frac{1}{1 - 1.200 \pm 0.175 \beta + 0.280 \pm 0.177 \beta^2} \text{ at}$	225.2	116	1.94
<p>where X_1 = TKN (filterable) loading (g/day), X_2 = Influent TKN (filterable) concentration (mg/l), and X_3 = OC (filterable) loading.</p>					



TABLE F3. DIAGNOSTIC CHECKING OF FINAL EFFLUENT TKN AND NO₃-N MODELS

Output Variable	Model No.	Residual	Autocorrelation Results Q χ^2 $\alpha = .95$	Cross Correlation Results Sax ₁ χ^2 $\alpha = .95$	Cross Correlation Results Sax ₂ χ^2 $\alpha = .95$	Cross Correlation Results Sax ₃ χ^2 $\alpha = .95$
Filterable TKN	S ₁		16.82	22.36	9.93	22.36
	C ₁		10.28	22.36	22.09	23.68
	S ₃		12.26	22.36	14.07	25.00
	C ₄		9.79	23.68	12.47	25.00
NO ₃ -N						

where $Q = n \sum_{k=1}^{15} r_{aa}^2(k)$,

$S = n \sum_{k=1}^{15} r_{ax}^2(k)$,

r^2 = estimate of cross correlation function,

a = model residuals,

k = lag,

n = series length, and

$x = (1 - \beta)X$

CROSS CORRELATIONS AND V WEIGHTS FOR SSC SYSTEM FILTERABLE TKN
LOADING VERSUS EFFLUENT FILTERABLE TKN

DIMENSION A(24,120),X(120),Y(120),Z(120),W(120)
CALL FORMS(1)

IDENTIFY PARAMETERS

X = FLOW(IGAL/MIN)

Y = FILTERABLE RAW FEED TKN(MG/L)

W = FILTERABLE EFFLUENT TKN(MG/L)

Z = LOADING (GM/DAY)

AW = MEAN FILTERABLE EFFLUENT TKN(MG/L)

AZ = MEAN LOADING (GM/DAY)

NOB = NUMBER OF DATA POINTS

NL = NUMBER OF LAGS

DATA NOB/120/,NL/20/

READ 1,((A(I,J),I=1,8),J=1,120)

READ 1,((A(I,J),I=9,16),J=1,120)

READ 1,((A(I,J),I=17,24),J=1,120)

1 FORMAT(17X,F3.0,19X,F6.0,4X,F4.0,F5.0,F5.0,F5.0,F5.0,2X,F5.0)

3 READ 4,(IX,IY,IW)

4 FORMAT(3I2)

PRINT 4,IX,IY,IW

IF(IFFOE(60).EQ.-1) STOP

PRINT 12

12 FORMAT(28X,10HFILTERABLE,31X,10HFILTERABLE)

PRINT 11

11 FORMAT(10X,14HFLOW(IGAL/MIN),3X,12HF TKN(MG/L),5X,

11SHLOADING(GM/DAY),8X,13HEFF TKN(MG/L))

PRINT 9

9 FORMAT(16X,1HX,16X,1HY,19X,1HZ,19X,1HW)

SW=0.0

SZ=0.0

DO 5 K=1,NOB

X(K)=A(IX,K)

Y(K)=A(IY,K)

W(K)=A(IW,K)

Z(K)=(X(K)*Y(K))*6.552

SZ=SZ+Z(K)

SW=SW+W(K)

PRINT 10,(X(K),Y(K),Z(K),W(K))

10 FORMAT(9X,F10.2,7X,F10.2,10X,F10.2,10X,F10.2)

5 CONTINUE

AW=SW/FLOAT(NOBS)

AZ=SZ/FLOAT(NOBS)

PRINT 101

101 FORMAT(///,24X,6HZ MEAN,15X,6HW MEAN)

PRINT 102,AZ,AW

102 FORMAT(/,2CX,F10.3,10X,F10.3)

DO 81 K=1,NOB

H(K)=H(K)-AW

81 Z(K)=Z(K)-AZ

CALL IDENT TF(Z,W,NOB,NL,1)

GO TO 3

END

```

SUBROUTINE IDENT TF(X,Y,NOB,NL,NDIFF)
IDENTIFICATION OF THE IMPULSE RESPONSE
BY INVERSION OF MATRIX
THIS SUBROUTINE REQUIRES THE SSPLIB
SSPLIB MUST BE ATTACHED
COMMON SDA,SDX
DIMENSION X(1),Y(1),AC(50),GAM(20,20),VGAM(400)
DIMENSION CC1(21),CC2(21),L(45),M(45),V(20),VN(20)
NDATA=NOB
ND=0
PRINT 18
18 FORMAT(52H1 CROSS CORRELATIONS AT + AND - LAGS FOR NDIFF = 0)
6 CALL CROSS(X,Y,NOB,NL,CC1,CC2)
CALL ACORR(X,AC,SDZ,NOB,NL)
BUILDING THE MATRIX OF INPUT AUTOCORRELATION GAM
NLL=NL-1
DO 10 J=1,NLL
GAM(J,J)=1.0
II=NL-J+1
DO 20 I=2,II
IW=I+J-1
20 GAM(IW,J)=AC(I-1)
10 CONTINUE
GAM(NL,NL)=1.0
DO 30 J=2,NL
JJ=J-1
DO 40 I=1,JJ
40 GAM(I,J)=GAM(J,I)
30 CONTINUE
PRINT 42,((GAM(I,J),I=1,NL),J=1,NL)
42 FORMAT(10X,20F6.2)
TRANSFORMING GAM TO A VECTOR MATRIX VGAM
DO 50 J=1,20
DO 60 I=1,20
IR=NL+(J-1)+I
VGAM(IR)=GAM(I,J)
60 CONTINUE
50 CONTINUE
INVERSION OF MATRIX
MINV AND GMPRD ARE IBM SCIENTIFIC SUBROUTINES
N=NL*NL
CALL MINV(VGAM,NL,N,1,M)
PRINT 51,0
51 FORMAT(//////,10X,44 D =,E20.8)
NLL=NL*NL
PRINT 42,(VGAM(I),I=1,NLL)
CALCULATION OF THE TRANSFER FUNCTION PARAMETERS
CALL GAS003(VGAM,CC2,V,NL,NL,1)
CALL GAS003(VGAM,CC1,VN,NL,NL,1)
DO 16 I=1,NL
V(I)=V(I)*SDA/SDX
16 VN(I)=VN(I)*SDA/SDX
PLOTTING PARAMETERS V
PRINT 8,ND
8 FORMAT(///,10X,38H V WEIGHTS AT + AND - LAGS FOR NDIFF=,I2)
CL=SQRT(VGAM(1)/FLOAT(NOB))*SDA*2.0/SDX
CLN=-CL
DO 2 K=1,NL
I=FLOAT(K)
IT=-I
KK=K-1
K1=-KK
2 PRINT 4,K1,VN(K),KK,V(K)
4 FORMAT(5X,I3,5X,F6.3,10X,I3,5X,F6.3)
PRINT 12,CL
12 FORMAT(///,53H APPROX. 95 PER CENT CONF LIMIT ON IMPULSE RESPONSE =
1,F10.3)
NDATA=NDATA-1
ND=ND+1
IF(ND.GT.NDIFF)GO TO 100
DO 41 I=1,NDATA
X(I)=X(I+1)-X(I)
41 Y(I)=Y(I+1)-Y(I)
PRINT 19
19 FORMAT(52H1 CROSS CORRELATIONS AT + AND - LAGS FOR NDIFF = 1)
GO TO 6
100 RETURN
END

```

```

SUBROUTINE ACORR(Z,AC,SOZ,N,NL)
DIMENSION Z(1),AC(1)
NL1 = NL+1
TN = N
SZ = 0.
DO 13 I=1,N
13 SZ = SZ+Z(I)
ZBAR = SZ/TN
DO 10 JJ=1,NL1
J = JJ-1
SZZ = 0.
NN = N-J
DO 11 I=1,NN
K=I+J
11 SZZ=SZZ+(Z(I)-ZBAR)*(Z(K)-ZBAR)
10 AC(JJ) = SZZ/TN
SOZ = SQRT(AC(1))
VZ = AC(1)
DO 12 J=1,NL
12 AC(J) = AC(J+1)/VZ
RETURN
END

```

```

SUBROUTINE CROSS(X,A,NOB,NL,CC1,CC2)
COMMON SDA,SDX
DIMENSION X(NOB),A(NOB)
DIMENSION CC1(41),CC2(41)
CC1 ARE CROSSCORRELATIONS AT NEGATIVE LAGS
CC2 ARE CROSSCORRELATION AT POSITIVE LAGS
CALL CRCORP(X,A,CC2,SOX,SDA,NOB,NL)
CALL CRCORR(A,X,CC1,SDA,SDX,NOB,NL)
PRINT 6
6 FORMAT(79H CROSS-CORRELATIONS BETWEEN MANIPULATED VARIABLES +
1 RESIDUALS X(T)*A(T+K),//)
NL1 = NL+1
DO 7 K=1,NL1
KK = K-1
K1 = -KK
7 PRINT 8, K1,CC1(K),KK,CC2(K)
8 FORMAT(5X,I3,5X,F6.3,10X,I3,5X,F6.3)
CL = 2.0/SQRT(FLOAT(NOB))
PRINT 12, CL
12 FORMAT(//,55H APPROX. 95 PERCENT CONF. LIMIT ON CROSS-CORRELATIONS
1 =,F6.3)
PRINT 9, SDX,SDA
9 FORMAT(/,28H STANDARD DEVIATIONS S(X) =,F12.4,5X,6HS(A) =,E12.4)
Q = 0.
DO 10 J=1,NL1
10 Q = Q+ CC2(J)*CC2(J)
Q = Q*FLOAT(NOB)
NDF = NL+1
PRINT 11, Q,NDF
11 FORMAT(/,25H CHI SQUARED STATISTIC = ,F6.2,/,10H BASED ON(,I2,46H
1 NO. OF DYNAMIC PARAMETERS) DEGREES OF FREEDOM)
RETURN
END

```

```

SUBROUTINE CRCORR(X,Y,CC,SDX,SDY,N,NL)
DIMENSION X(N),Y(N),CC(1)
SX = 0.
SY = 0.
SXX = 0.
SYY = 0.
DO 2 I=1,N
SX = SX+X(I)
SY = SY+Y(I)
SXX = SXX+X(I)*X(I)
2 SYY = SYY+Y(I)*Y(I)
TN = N
SDX = SQRT((SXX-SX*SX/TN)/TN)
SDY = SQRT((SYY-SY*SY/TN)/TN)
NL1 = NL+1
DO 3 K=1,NL1
SXY = 0.
NN = N-K+1
DO 4 I=1,NN
KK = I+K-1
4 SXY = SXY+(X(I)-SX/TN)*(Y(KK)-SY/TN)
3 CC(K) = (SXY/TN)/(SDX*SDY)
RETURN

```

FLOW (GAL/MIN)	FILTERABLE EFF TKN (MG/L)	LOADING (GM/DAY)	FILTERABLE EFF TKN (MG/L)
X	Y	Z	W
1.00	22.20	145.45	1.00
1.00	22.10	151.35	2.70
1.00	22.60	157.73	0.80
1.00	22.70	148.73	1.00
1.00	22.40	133.66	0.70
1.00	22.90	163.14	1.90
1.00	22.70	271.25	1.30
1.00	13.30	174.28	2.70
1.00	12.70	166.42	3.30
1.00	11.40	149.30	3.10
1.00	9.80	117.94	1.70
1.00	8.80	115.32	1.10
1.00	15.10	137.97	2.90
1.00	23.90	313.16	3.30
1.00	24.30	318.43	3.30
1.00	22.50	294.84	8.00
1.00	21.90	286.98	9.40
1.00	20.90	273.87	10.10
1.00	21.60	441.52	11.70
1.00	35.10	229.98	12.20
1.00	33.90	222.11	13.10
1.00	22.70	188.04	13.70
1.00	27.20	178.21	14.00
1.00	35.50	232.60	11.40
1.00	37.80	439.33	12.30
1.00	14.30	187.39	10.90
1.00	14.60	191.32	7.20
1.00	11.20	146.76	4.90
1.00	12.90	169.04	2.60
1.00	14.10	184.77	1.60
1.00	16.40	187.45	3.30
1.00	18.40	120.56	4.90
1.00	16.10	105.49	8.30
1.00	13.90	91.07	9.40
1.00	9.90	64.86	9.20
1.00	8.80	57.66	8.00
1.00	19.50	127.76	5.60
1.00	14.50	95.82	4.50
1.00	17.30	113.35	2.60
1.00	14.00	91.33	2.00
1.00	14.40	94.35	1.70
1.00	14.00	91.33	1.40
2.00	13.50	176.90	1.50
2.00	29.30	383.95	4.10
2.00	25.40	332.84	9.20
2.00	22.30	292.22	10.80
2.00	18.90	247.67	10.50
2.00	25.10	328.91	9.90
1.00	22.40	146.76	10.40
1.00	12.00	78.62	7.50
1.00	6.50	42.59	5.00
1.00	5.30	34.73	1.40
1.00	4.00	26.21	1.20
1.00	5.50	36.04	1.10
1.00	6.00	39.31	1.00
1.00	9.90	58.97	1.10
1.00	12.00	78.62	1.20
1.00	12.10	79.28	1.20
1.00	10.00	65.52	1.10
1.00	6.00	39.31	2.50
2.00	2.00	26.21	6.50
2.00	5.50	45.86	2.50
2.00	5.00	65.52	1.40
2.00	6.70	87.80	1.20
2.00	6.80	78.62	1.10
2.00	5.00	65.52	1.00
2.00	4.20	55.84	1.00
2.00	8.00	134.33	1.00
2.00	12.00	137.25	1.00
2.00	14.80	193.94	1.40
2.00	11.00	157.25	1.80
2.00	13.50	176.90	1.50
1.00	16.90	110.73	1.20
1.00	25.50	167.08	2.00
1.00	9.00	190.01	2.60
1.00	2.00	170.35	2.20

TABLE F4 (Cont'd)

1.00	26.00	170.35	5.00
1.00	22.40	146.76	5.40
1.00	22.00	143.46	5.40
1.00	22.80	193.46	5.50
1.00	22.90	186.08	5.50
1.00	22.90	196.01	5.50
1.00	33.10	203.11	5.50
1.00	33.10	433.74	5.50
1.00	32.50	425.88	5.50
1.00	27.00	353.81	5.50
1.00	19.20	251.60	5.50
1.00	26.00	340.70	5.50
1.00	37.00	399.67	5.50
1.00	31.00	412.78	5.50
1.00	21.50	281.74	5.50
1.00	16.00	209.66	5.50
1.00	14.50	190.01	5.50
1.00	13.50	176.97	5.50
1.00	20.00	252.08	5.50
1.00	13.00	85.16	5.50
1.00	12.40	81.24	5.50
1.00	11.90	77.97	5.50
1.00	10.50	68.80	5.50
1.00	12.00	78.62	5.50
1.00	10.20	66.83	5.50
1.00	10.80	141.52	5.50
1.00	17.70	231.94	5.50
1.00	15.90	208.35	5.50
1.00	16.20	212.28	5.50
1.00	10.90	142.83	5.50
1.00	11.10	145.45	5.50
1.00	22.70	148.73	5.50
1.00	18.70	122.52	5.50
1.00	14.20	93.74	5.50
1.00	13.90	91.07	5.50
1.00	13.60	89.11	5.50
1.00	11.60	76.00	5.50
1.00	10.40	136.28	5.50
1.00	15.90	208.35	5.50
1.00	15.70	205.73	5.50
1.00	14.50	190.01	5.50
1.00	9.40	123.18	5.50
1.00	9.80	128.42	5.50

Z MEAN
166.677

W MEAN
5.854

CROSS CORRELATIONS AT + AND - LAGS FOR NDIFF = 0
CROSS-CORRELATIONS BETWEEN MANIPULATED VARIABLES + RESIDUALS X(T)*A(T+K)

0	0.525	0	0.525
1	0.394	1	0.646
2	0.304	2	0.681
3	0.225	3	0.619
4	0.138	4	0.535
5	0.083	5	0.486
6	0.038	6	0.454
7	0.013	7	0.406
8	0.020	8	0.329
9	0.071	9	0.225
10	0.115	10	0.133
11	0.179	11	0.103
12	0.233	12	0.083
13	0.295	13	0.041
14	0.337	14	0.043
15	0.371	15	0.062
16	0.388	16	0.030
17	0.359	17	0.006
18	0.310	18	0.005
19	0.268	19	0.003
20	0.233	20	0.003

	V WEIGHTS	AT + AND - LAGS	FOR NOIFF = 0
-0	0.0026	0	0.0006
-1	0.0033	1	0.0012
-2	0.0039	2	0.0022
-3	0.0045	3	0.0035
-4	0.0057	4	0.0052
-5	0.0074	5	0.0072
-6	0.0096	6	0.0093
-7	0.0124	7	0.0126
-8	0.0162	8	0.0167
-9	0.0203	9	0.0211
-10	0.0253	10	0.0272
-11	0.0313	11	0.0342
-12	0.0384	12	0.0420
-13	0.0466	13	0.0505
-14	0.0553	14	0.0594
-15	0.0631	15	0.0683
-16	0.0707	16	0.0771
-17	0.0783	17	0.0852
-18	0.0800	18	0.0906
-19	0.0806	19	0.0944

APPROX. 95 PER CENT CONF LIMIT ON IMPULSE RESPONSE = 0.014

CROSS CORRELATIONS AT + AND - LAGS FOR NOIFF = 1
 CROSS-CORRELATIONS BETWEEN MANIPULATED VARIABLES + RESIDUALS X(T)*A(T+K)

-0	0.024	0	0.024
-1	-0.118	1	0.281
-2	-0.030	2	0.327
-3	0.018	3	0.069
-4	-0.116	4	-0.113
-5	-0.026	5	-0.060
-6	-0.026	6	0.043
-7	-0.000	7	0.098
-8	0.060	8	0.093
-9	-0.023	9	-0.044
-10	0.057	10	-0.198
-11	-0.043	11	-0.031
-12	0.051	12	0.073
-13	-0.036	13	0.140
-14	-0.027	14	-0.205
-15	-0.073	15	-0.161
-16	-0.151	16	0.026
-17	-0.069	17	0.068
-18	-0.018	18	-0.030
-19	0.049	19	-0.660
-20	-0.612	20	0.092

APPROX. 95 PERCENT CONF. LIMIT ON CROSS-CORRELATIONS = 0.183

STANDARD DEVIATIONS S(X) = 68.2263 S(A) = 0.1961E+01

CHI SQUARED STATISTIC = 45.79
 BASED ON (21 NO. OF DYNAMIC PARAMETERS) DEGREES OF FREEDOM

APPROX. 95 PER CENT CONF LIMIT ON IMPULSE RESPONSE = 0.006
1 1 1

STOP

```

PROGRAM SUTTON
DIMENSION SCRAT(1200), TH(8), A(2, 120)
COMMON Z(120), W(120), X(120), Y(120)
EXTERNAL MODELA

```

TRANSFER FUNCTION MODEL PARAMETER DETERMINATION FOR SSC SYSTEM EFFLUENT TKN
AS A FUNCTION OF FILTERABLE TKN LOADING

```

IDENTIFY PARAMETERS
X = FLOW (IGAL/ MIN)
Y = FILTERABLE RAW FEED TKN (MG/L)
W = FILTERABLE EFFLUENT TKN (MG/L)
Z = LOADING (GM/DAY)
AW = MEAN FILTERABLE EFFLUENT TKN (MG/L)
AZ = MEAN LOADING (GM/DAY)
NOB = NUMBER OF DATA POINTS
TH = CONSTANT PARAMETERS USED IN TRANSFER FUNCTION MODEL
NP = NUMBER OF TH VALUES
NPROB = NUMBER OF DIFFERENCINGS

```

PROGRAM IDENTICAL TO TABLE F6 EXCEPT FOR FOLLOWING SUBROUTINE AND OUTPUT

```

SUBROUTINE MODELA (NPROB, TH, A, NOB, NP)
DIMENSION TH(8), A(1)
COMMON Z(120), W(120), X(120), Y(120)

```

TRANSFER FUNCTION MODEL A

```

A(1)=0.0
DO 100 I=2, NOB
100 A(I) = (TH(1)*A(I-1)) + W(I)
1 - (TH(1)*W(I-1))
1 - (TH(2)*Z(I-1))
RETURN
END

```

OUTPUT

~~NON-LINEAR ESTIMATION, PROBLEM NUMBER 1~~
120 OBSERVATIONS, 2 PARAMETERS 374 SCRATCH REQUIRED

INITIAL PARAMETER VALUES

~~0.7700E+00 0.1500E-01~~

INITIAL SUM OF SQUARES = 0.1011E+04

DETERMINANT = 0.4216E+00 ITERATION NO. 1
ANGLE IN SCALED COORD. = 24.89 DEGREES

TEST POINT PARAMETER VALUES
0.7581E+00 0.1263E-01

TEST POINT SUM OF SQUARES = 0.9292E+03

PARAMETER VALUES VIA REGRESSION

$0.7581E+00$ $0.1263E-01$

LAMBDA = $0.100E-02$

SUM OF SQUARES
AFTER REGRESSION = 0.9291839E+03

ITERATION NO. 2
DETERMINANT = 0.4146E+00 ANGLE IN SCALED COORD. = 17.790 DEGREES

TEST POINT PARAMETER VALUES
 $0.7566E+00$ $0.1260E-01$

TEST POINT SUM OF SQUARES = 0.9291E+03

PARAMETER VALUES VIA REGRESSION

$0.7566E+00$ $0.1260E-01$

LAMBDA = $0.100E-03$

SUM OF SQUARES
AFTER REGRESSION = 0.9290996E+03

ITERATION NO. 3
DETERMINANT = 0.4133E+00 ANGLE IN SCALED COORD. = 17.230 DEGREES

TEST POINT PARAMETER VALUES
 $0.7564E+00$ $0.1261E-01$

TEST POINT SUM OF SQUARES = 0.9291E+03

PARAMETER VALUES VIA REGRESSION

$0.7564E+00$ $0.1261E-01$

LAMBDA = $0.100E-04$

SUM OF SQUARES
AFTER REGRESSION = 0.9290978E+03

ITERATION STOPS - RELATIVE CHANGE IN EACH PARAMETER LESS THAN $0.1000E-02$

FINAL RESIDUAL VALUES

$0.0000E+00$	$-0.1215E+01$	$-0.1881E+01$	$-0.2468E+01$	$-0.3123E+01$	$-0.3001E+01$
$-0.3032E+01$	$-0.3322E+01$	$-0.2777E+01$	$-0.2920E+01$	$-0.4061E+01$	$-0.4069E+01$
$-0.1788E+01$	$-0.2066E+01$	$-0.1325E+00$	$-0.8862E+00$	$-0.3639E+00$	$-0.2287E+00$
$-0.1189E+01$	$-0.3081E+01$	$-0.3978E+01$	$-0.4675E+01$	$-0.5478E+01$	$-0.3382E+01$
$0.3978E+01$	$-0.9657E+00$	$-0.3462E+01$	$-0.4902E+01$	$-0.5989E+01$	$-0.6352E+01$
$-0.4269E+01$	$-0.5801E+00$	$0.2554E+01$	$0.4399E+01$	$0.4945E+01$	$0.4639E+01$
+01	-	+00	-00	-00	-01

-0.8591E+00	0.7664E+00	0.2586E+01	0.2215E+01	0.9378E+00	0.2651E+00
-0.3599E+00	-0.1814E+01	-0.2360E+01	-0.4028E+01	-0.2668E+01	-0.1480E+01
-0.7301E+00	-0.2848E+01	0.2787E+00	0.1874E+00	0.1014E+01	0.1525E+01
0.5943E+01	0.2484E+01	0.1440E+01	0.1080E+01	0.5777E+00	0.2892E+00
0.3120E+00	0.4614E+00	-0.3365E+01	-0.7043E+00	-0.1562E+01	-0.2350E+01
-0.3267E+01	-0.3100E+01	-0.3532E+01	-0.2949E+01	-0.1367E+01	-0.6144E+00
-0.3192E+00	0.9991E+00	0.1401E+01	0.1952E+01	0.2179E+01	0.2499E+01
0.2597E+01	0.3060E+01	0.2286E+01	0.1775E+01	0.3151E+01	0.3039E+01
-0.4232E+01	-0.1253E+01	-0.4095E+00	-0.2667E+01	-0.4453E+01	-0.3210E+01
-0.4580E+00	0.8867E+01	0.2024E+01	-0.3181E+01	-0.3186E+01	-0.2582E+01
-0.1901E+01	-0.2427E+01	-0.1390E+01	-0.7996E+00	0.3881E+01	0.9143E+00
0.1665E+01	0.3414E+01	0.3857E+01	0.3964E+01	0.3623E+01	0.3371E+01
0.3075E+01	0.2596E+01	0.3200E+01	0.2923E+01	0.1568E+01	0.1373E+00

CORRELATION MATRIX

	1	2
1	1.0000	
2	-0.7660	1.0000

NORMALIZING ELEMENTS

0.1145E-01	0.5161E-03
------------	------------

VARIANCE OF RESIDUALS = 0.7874E+01, 118 DEGREES OF FREEDOM

INDIVIDUAL CONFIDENCE LIMITS FOR EACH PARAMETER (ON LINEAR HYPOTHESIS)

0.8206E+00	0.1551E-01
0.6921E+00	0.9716E-02

AUTO AND PARTIAL CORRELATIONS OF THE RESIDUALS

I	AUTO	PARTIAL
1	0.800	0.800
2	0.524	-0.321
3	0.266	-0.095
4	0.063	-0.057
5	-0.084	-0.069
6	-0.187	-0.077
7	-0.210	0.067
8	-0.227	-0.149
9	-0.217	0.012
10	-0.184	-0.007
11	-0.143	-0.030
12	-0.095	0.001
13	-0.107	-0.176

14	-0.143	-0.082
15	-0.175	-0.011
16	-0.171	-0.020
17	-0.157	-0.059
18	-0.103	0.090
19	0.001	0.070
20	0.111	0.015

APPROX. 95 PERCENT CONF. LIMIT ON CORRELATIONS = 0.183

CHI-SQUARED STATISTIC = 154.78
 BASED ON (23 - NO. OF STOCHASTIC PARAMETERS) DEGREES OF FREEDOM

STOP

```

PROGRAM SUTTON
DIMENSION SCRAT(1000),TH(8),A(24,12)
COMMON Z(120),W(120),X(120),Y(120)
EXTERNAL MODELA

```

TRANSFER FUNCTION - NOISE MODEL PARAMETER DETERMINATION FOR SSC SYSTEM
EFFLUENT TKN AS A FUNCTION OF FILTERABLE TKN LOADING

IDENTIFY PARAMETERS

```

X = FLOW(IGAL/MIN)
Y = FILTERABLE RAW FEED TKN(MG/L)
W = FILTERABLE EFFLUENT TKN(MG/L)
Z = LOADING (GM/DAY)
AW = MEAN FILTERABLE EFFLUENT TKN(IG/L)
AZ = MEAN LOADING (GM/DAY)
NOB = NUMBER OF DATA POINTS
TH = CONSTANT PARAMETERS USED IN TRANSFER FUNCTION NOISE MODEL
NP = NUMBER OF TH VALUES
NPROB = NUMBER OF DIFFERENCINGS

```

```

DATA MIT,FLAM,FNU/10,,01,10./
DATA EPS1,EPS2/1,0E-07,1,0E-03/
READ 1,((A(I,J),I=1,8),J=1,120)
READ 1,((A(I,J),I=9,16),J=1,120)
READ 1,((A(I,J),I=17,24),J=1,120)

```

```
1 FORMAT(17X,F3.0,19X,F6.0,4X,F4.0,F5.0,F5.0,F5.0,F5.0,2X,F5.0)
```

```
3 READ 4,IX,IY,IW,ICOUNT
```

```
IF(IEOF(60).EQ.-1) STOP
```

```
4 FORMAT(4I2)
```

```
PRINT 4,IX,IY,IW,ICOUNT
```

```
READ 8,NPROB,NOB,NP
```

```
8 FORMAT(3I5)
```

```
PRINT 5J,NPROB,NOB,NP
```

```
50 FORMAT(10X,3I5)
```

```
READ 2,(TH(I),I=1,NP)
```

```
2 FORMAT(F5.2)
```

```
PRINT 12
```

```
12 FORMAT(28X,10HFILTERABLE,31X,10HFILTERABLE)
```

```
PRINT 11
```

```
11 FORMAT(10X,14HFLOW(IGAL/MIN),3X,12HRAW TKN(MG/L),5X,  
115HLOADING(GM/DAY),8X,13HEFF TKN(MG/L))
```

```
PRINT 9
```

```
9 FORMAT(16X,1HX,16X,1HY,19X,1HZ,19X,1HW)
```

```
SZ=0.0
```

```
SH=0.0
```

```
DO 5 K=1,NOB
```

```
X(K)=A(IX,K)
```

```
Y(K)=A(IY,K)
```

```
W(K)=A(IW,K)
```

```
Z(K)=(X(K)*Y(K))+6.552
```

```
SW=SW+W(K)
```

```
SZ=SZ+Z(K)
```

```
PRINT 1J,(X(K),Y(K),Z(K),W(K))
```

```
10 FORMAT(9X,F10.2,7X,F10.2,10X,F10.2,10X,F10.2)
```

```
5 CONTINUE
```

```
AW=SW/FLOAT(NOB)
```

```
AZ=SZ/FLOAT(NOB)
```

```
PRINT 202
```

```
202 FORMAT(///,24X,6HZ MEAN,15X,6HW MEAN)
```

```
PRINT 201,AZ,AW
```

```
201 FORMAT(/,20X,F10.3,10X,F10.3)
```

```
DO 81 K=1,NOB
```

```
W(K)=W(K)-AW
```

```
81 Z(K)=Z(K)-AZ
```

```
IF(ICOUNT.EQ.1)GO TO 91
```

```
IF(ICOUNT.EQ.2)GO TO 92
```

```
IF(ICOUNT.EQ.3)GO TO 93
```

```
IF(ICOUNT.EQ.4)GO TO 94
```

```
IF(ICOUNT.EQ.5)GO TO 95
```

```
IF(ICOUNT.EQ.6)GO TO 96
```

```
IF(ICOUNT.EQ.7)GO TO 97
```

```
IF(ICOUNT.EQ.8)GO TO 98
```



```

IF (ICOUNT.EQ.9) GO TO 99
IF (ICOUNT.EQ.10) GO TO 100
IF (ICOUNT.EQ.11) GO TO 101
91 CALL TSHAUS(NPROB,MODEL A,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
92 CALL TSHAUS(NPROB,MODEL B,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
93 CALL TSHAUS(NPROB,MODEL C,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
94 CALL TSHAUS(NPROB,MODEL D,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
95 CALL TSHAUS(NPROB,MODEL E,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
96 CALL TSHAUS(NPROB,MODEL F,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
97 CALL TSHAUS(NPROB,MODEL G,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
98 CALL TSHAUS(NPROB,MODEL H,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
99 CALL TSHAUS(NPROB,MODEL I,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
100 CALL TSHAUS(NPROB,MODEL J,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
101 CALL TSHAUS(NPROB,MODEL K,NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU, SCRAT)
GO TO 3
END

```

```

SUBROUTINE MODEL A (NPROB, TH, A, NOB, NP)
DIMENSION TH(3), A(1)
COMMON Z(120), W(120), X(120), Y(120)

```

TRANSFER FUNCTION NOISE MODEL A

```

A(1)=0.0
A(2)=0.0
A(3)=0.0
DO 100 I=4, NOB
100 A(I)=(TH(1)*A(I-1))+W(I)-(TH(3)*W(I-1))
1+(TH(4)*W(I-2))
1-(TH(1)*W(I-1))
1+(TH(3)*TH(1)*W(I-2))
1-(TH(4)*TH(1)*W(I-3))
1-(TH(2)*Z(I-1))
1+(TH(3)*TH(2)*Z(I-2))
1-(TH(4)*TH(2)*Z(I-3))
RETURN
END

```

```

SUBROUTINE TSHAUS(NPROB, MODEL, NOB, NP, TH, EPS1, EPS2, MIT, FLAM, FNU,
1 SCRAT)

```

```

RESIDUALS ARE RETURNED IN SCRAT(IG) WHERE IG=5*NP+1
DIMENSION SCRAT(1)

```

```

IA=1
IB=IA+NP
IC=IB+NP
ID=IC+NP
IE=ID+NP
IG=IE+NP
IH=IG+NOB
II=IH+NP*NOB
IJ=IH

```

```

CALL TSHAUS(NPROB, MODEL, NOB, NP, TH, EPS1, EPS2, MIT,
1, FLAM, FNU, SCRAT(IA), SCRAT(IB), SCRAT(IC), SCRAT(ID),
2, SCRAT(IE), SCRAT(IG), SCRAT(IH), SCRAT(II), SCRAT(IJ))
RETURN
END

```

SUBROUTINE HAUSTS(NPR30, MODEL, NOB, NO, TH, EP1S, EP2S,
 1 MIT, FLAM, FNU, Q, P, E, PHI, TB, R, A, D, DELZ)

FORTRAN II VERSION

ADAPTED FOR THE CDC 6400 (J. F. MACGREGOR 9/72)

DIMENSION TH(NQ), R(NQ)

DIMENSION Q(NQ), P(NQ), E(NQ), PHI(NQ), TB(NQ)

DIMENSION A(NQ,NO), D(NQ,NO), DELZ(NQ,NO)

DIMENSION TH(1), Q(1), P(1), E(1),
 1 PHI(1), TB(1), R(1), A(1), D(1), DELZ(1)

DIMENSION AC(16), PP(16)

ACOS(X) = ATAN(SCRT(1.0/X**2 - 1.0))

NP = NQ

NPROB = NPR30

NOB = NBO

EPS1 = EPS

EPS2 = EP2S

NPSQ = NP * NP

NSCRAC = 5*NP+NPSQ + NOB+NP*NOB

PRINT 1000, NPROB, NOB, NP, NSCRAC

PRINT 1001

CALL GASS60(1, NP, TH, TEMP, TMEP)

IF(MIN3(NP-1, 50-NP, NOB-NP, MIT-1, 999-MIT)) 99, 15, 15

15 IF(FNU-1.0) 99, 99, 16

16 CONTINUE

DO 19 I=1, NP

IF(ABS(TH(I))) 99, 99, 19

19 CONTINUE

GA = FLAM

NIT = 1

IF(EPS1) 5, 70, 70

5 EPS1 = 0

70 SSQ = 0

CALL MODEL(NPROB, TH, R, NOB, NP)

DO 90 I = 1, NOB

90 SSQ=SSQ+R(I)*R(I)

PRINT 1003, SSQ

BEGIN ITERATION

100 GA = GA / FNU

INICNT = 0

PRINT 1004, NIT

101 JS = 1 - NOB

DO 130 J=1, NP

TEMP = TH(J)

P(J) = 0.01*TH(J)

TH(J) = TH(J)+P(J)

Q(J) = 0

JS = JS + NOB

CALL MODEL(NPROB, TH, DELZ(JS), NOB, NP)

IJ = JS-1

DO 120 I = 1, NOB

IJ = IJ + 1

DELZ(IJ) = R(I) - DELZ(IJ)

120 Q(IJ) = Q(IJ) + DELZ(IJ) * R(I)

Q(IJ) = Q(IJ)/P(IJ)

Q=XT*R (STEEPEST DESCENT)

130 TH(J) = TEMP

131 DO 150 I = 1, NP

DO 151 J=1, I

SUM = 0

KJ = NOB*(J-1)

KI = NOB*(I-1)

DO 160 K = 1, NOB

KI = KI + 1

KJ = KJ + 1

160 SUM = SUM + DELZ(KI) * DELZ(KJ)

TEMP = SUM/(P(I)*P(J))

J1 = J + NP*(I-1)

D(J1) = TEMP

IJ = I + NP*(J-1)

151 D(IJ) = TEMP

150 E(I) = SORT(D(IJ))

666 CONTINUE

DO 153 I = 1, NP

IJ = I - NP

DO 153 J=1, I

```

IJ = IJ + NP
A(IJ) = Q(IJ) / (E(I)*E(J))
JI = J + NP*(I-1)
153 A(JI) = A(IJ)
A= SCALED MOMENT MATRIX

II = - NP
DO 155 I=1, NP
P(I)=Q(I)/E(I)
PHI(I)=P(I)
II = NP + 1 + II
155 A(II) = A(II) + GA

I=1
CALL MATIN(A, NP, P, I, DET)
P/E = CORRECTION VECTOR

STEP=1.0
SUM1=0.
SUM2=0.
SUM3=0.
DO 231 I=1, NP
SUM1=P(I)*PHI(I)+SUM1
SUM2=P(I)*P(I)+SUM2
SUM3=PHI(I)*PHI(I)+SUM3
231 PHI(I) = P(I)
TEMP = SUM1/SQRT(SUM2*SUM3)
TEMP = AMIN1(TEMP, 1.0)
TEMP = 57.295*ACOS(TEMP)
PRINT 1041, DET, TEMP
170 DO 220 I = 1, NP
P(I) = PHI(I) * STEP / E(I)
TB(I) = TH(I) + P(I)
220 CONTINUE
PRINT 7000
7000 FORMAT(30HTEST POINT PARAMETER VALUES )
PRINT 2006, (TB(I), I = 1, NP)
SUMB=0
CALL MODEL(NPROB, TB, R, NOB, NP)
DO 230 I=1, NOB
230 SUMB=SUMB+R(I)*R(I)
PRINT 1043, SUMB
IF(SUMB - (1.0+EPS1)*SSQ) 652, 662, 663
663 IF(AMIN1(TEMP-30.0, GA)) 655, 665, 664
665 STEP=STEP/2.0
INTCNT = INTCNT + 1
IF(INTCNT - 35) 170, 2700, 2700
664 GA=GA*FNU
INTCNT = INTCNT + 1
IF(INTCNT - 36) 666, 2700, 2700
662 PRINT 1007
DO 669 I=1, NP
669 TH(I)=TB(I)
CALL GASS60(1, NP, TH, TEMP, TEMP)
PRINT 1040, GA, SUMB
IF(EPS2) 229, 229, 225
229 IF(EPS1) 270, 270, 265
225 DO 240 I = 1, NP
IF(ABS(P(I))/(1.E-20+ABS(TH(I)))-EPS2) 240, 240, 241
241 IF(EPS1) 270, 270, 265
240 CONTINUE
PRINT 1009, EPS2
GO TO 280
265 IF(ABS(SUMB - SSQ) - EPS1*SSQ) 266, 266, 270
266 PRINT 1010, EPS1
GO TO 280
270 SSQ=SUMB
NIT=NIT+1
IF(NIT-MIT) 100, 100, 280
2700 PRINT 2710
2710 FORMAT(//115H0**** THE SUM OF SQUARES CANNOT BE REDUCED TO THE SUM
10F SQUARES AT THE END OF THE LAST ITERATION - ITERATING STOPS //)

END ITERATION

280 PRINT 1011
PRINT 2001, (R(I), I = 1, NOB)
SSQ=SUMB
IDF=NOB-NP

```

```

I=L
CALL 141IN(D, NP, P, I, DEF)
DO 7592 I=1, NP
II = I + NP*(I-1)
7592 E(I) = SQRT(3*(II))
DO 340 I=1, NP
JI = I + NP*(I-1) - 1
IJ = I + NP*(I-2)
DO 340 J = I, NP
JI = JI + 1
A(JI) = D(JI) / (E(I)*E(J))
IJ = IJ + NP
340 A(IJ) = A(JI)
CALL GASS60(3, NP, TEMP, TEMP, A)
PRINT 131b
CALL GASS60(1, NP, E, TEMP, TEMP)
IF(IDF) 341, 410, 341
341 SDEV = SSQ / IDF
PRINT 1014, SDEV, IDF
SDEV = SQRT(SDEV)
DO 391 I=1, NP
P(I) = T4(I) + 2.0 * E(I) * SDEV
391 TB(I) = TH(I) - 2.0 * E(I) * SDEV
PRINT 1939
CALL GASS60(2, NP, TB, P, TEMP)
CALL ACORR(R, AC, SDF, NOB, 15)
CALL PARTAL(AC, PP, 15)
PRINT 53
59 FORMAT(11H1, 47H AUTO AND PARTIAL CORRELATIONS OF THE RESIDUALS, //
19X, 11H1, 14X, 4HAUTO, 14X, 7HPARTIAL //)
DO 58 I=1, 15
58 PRINT 57, I, AC(I), PP(I)
57 FORMAT (8X, I2, 13X, F6.3, 13X, F6.3)
CL = 2.3 / SQRT(FLOAT(NOB))
PRINT 54, CL
54 FORMAT(//50H APPROX. 95 PERCENT CONF. LIMIT ON CORRELATIONS = ,F5.
13)
CHI = 0.
DO 56 I=1, 15
56 CHI = CHI + AC(I) * AC(I)
CHI = CHI * FLOAT(NOB)
PRINT 55, CHI
55 FORMAT(/25H CHI-SQUARED STATISTIC = ,F6.2/65H BASED ON (15 - NO. 0
1F STOCHASTIC PARAMETERS) DEGREES OF FREEDOM /)
410 CONTINUE
RETURN
99 PRINT 1034
GO TO 410
10000 FORMAT(38H1NON-LINEAR ESTIMATION, PROBLEM NUMBER I3, // I5,
1 14H OBSERVATIONS, I5, 11H PARAMETERS I14, 17H SCRATCH REQUIRED)
1001 FORMAT(/25H0INITIAL PARAMETER VALUES )
1003 FORMAT(/25H0INITIAL SUM OF SQUARES = E12.4)
1004 FORMAT(///145X, 13HITERATION NO. I)
1007 FORMAT(/32H0PARAMETER VALUES VIA REGRESSION )
10090 FORMAT(/62H0ITERATION STOPS - RELATIVE CHANGE IN EACH PARAMETER LE
1SS THAN E12.4)
10100 FORMAT(/52H0ITERATION STOPS - RELATIVE CHANGE IN SUM OF SQUARES LE
1SS THAN E12.4)
1011 FORMAT(22H1FINAL RESIDUAL VALUES )
1012 FORMAT(///10H0RESIDUALS )
1014 FORMAT(///24H0VARIANCE OF RESIDUALS = ,E12.4, 1H, I4,
120H DEGREES OF FREEDOM )
1015 FORMAT(///19H0CORRELATION MATRIX )
1016 FORMAT(///21H0NORMALIZING ELEMENTS )
1034 FORMAT(/16H0PARAMETER ERROR )
10390 FORMAT(/71H0INDIVIDUAL CONFIDENCE LIMITS FOR EACH PARAMETER (ON LI
1NEAR HYPOTHESIS) )
10400 FORMAT(/9H0LAMBDA = E10.3, 40X, 33HSUM OF SQUARES AFTER REGRESSION =
1E15.7)
1041 FORMAT(14H DETERMINANT = E12.4, 6X, 25H ANGLE IN SCALED COORD. =
1 F5.2, 8H DEGREES )
1043 FORMAT(28H0TEST POINT SUM OF SQUARES = E12.4)
2001 FORMAT(/10E12.4)
2005 FORMAT(10E12.4)
END

```

```

SUBROUTINE MATIN(A, NVAR, B, NB, DET)
DIMENSION A(NVAR, 1), B(NVAR, 1)
COMMON/GASPAP/DUMIES(7), PIVOTM
PIVOTM = A(1,1)
DET = 1.0
DO 350 ICOL = 1, NVAR
  PIVOT = A(ICOL, ICOL)
  PIVOTM = AMIN(PIVOT, PIVOTM)
  DET = PIVOT * DET

  DIVIDE PIVOT ROW BY PIVOT ELEMENT
  A(ICOL, ICOL) = 1.0

  PIVOT = AMAX1(PIVOT, 1.E-20)
  PIVOT = A(ICOL, ICOL)/PIVOT
DO 350 L=1, NVAR
350  A(ICOL, L) = A(ICOL, L)*PIVOT
  IF(NB .EQ. 0) GO TO 371
DO 370 L=1, NB
370  B(ICOL, L) = B(ICOL, L)*PIVOT

  REDUCE NON-PIVOT ROWS
371  DO 550 L1=1, NVAR
    IF(L1 .EQ. ICOL) GO TO 550
    T = A(L1, ICOL)
    A(L1, ICOL) = 0.
    DO 450 L=1, NVAR
450  A(L1, L) = A(L1, L) - A(ICOL, L)*T
    IF(NB .EQ. 0) GO TO 550
    DO 500 L=1, NB
500  B(L1, L) = B(L1, L) - B(ICOL, L)*T
550  CONTINUE
  RETURN
  END

```

```

SUBROUTINE GASSED(ITYPE, NQ, A, B, C)
DIMENSION A(NQ), B(NQ), C(NQ, NQ)
NP = NQ
NR = NP/10
LOW = 1
LUP = 10
10  IF( NR )15,20,30
15  RETURN
20  LUP=NP
  IF(LOW .GT. LUP) RETURN
30  PRINT 500, (J, J=LOW, LUP)
  GO TO (40,60,80), ITYPE
40  PRINT 600, (A(J), J=LOW, LUP)
  GO TO 100
60  PRINT 600, (B(J), J=LOW, LUP)
  GO TO 40
80  DO 90 I=LOW, LUP
90  PRINT 720, I, (C(J, I), J=LOW, I)
  LOW2=LUP+1
  IF(LOW2 .GT. NP) GO TO 100
  DO 95 I=LOW2, NP
95  PRINT 720, I, (C(J, I), J=LOW, LUP)
100  LOW = LOW + 10
  LUP = LUP + 10
  NR = NR - 1
  GO TO 10
500  FORMAT(/I8,9I12)
600  FORMAT(10E12.4)
720  FORMAT(1H6, I3, 1X, F7.4, 9F12.+)
1  CONTINUE
  RETURN
  END

```

```

SUBROUTINE ACORR(Z, AC, SOZ, N, NL)
DIMENSION Z(1), AC(1)
NL1 = NL+1
IN = N
SZ = 0.
DO 13 I=1, N
13  SZ=SZ+Z(I)
  ZBAR=SZ/IN
DO 10 JJ=1, NL1
  J = JJ-1
  0.

```

```

NN = N-J
30 I=1,NN
K=I+J
11 SZ7=SZ7+(Z(I)-ZBAR)*(Z(K)-ZBAR)
10 AC(JJ) = SZ7/IN
SCZ = SORT(AC(1))
VZ = AC(1)
DO 12 J=1,NL
12 AC(J) = AC(J+1)/VZ
RETURN
END

SUBROUTINE PARTIAL (R, PAUTO, 4)
DIMENSION P(1), PAUTO(1), PHAT(60), PHATN(60)
PAUTO(1) = R(1)
PHAT(1) = P(1)*(1.-P(2))/(1.-P(1)**2)
PHAT(2) = (P(2)-P(1)**2)/(1.-P(1)**2)
PAUTO(2) = PHAT(2)
DO 4 I=3,4
L = I-1
FNUM = J.
DENOM = 3.
DO 1 J=1,L
K = I-J
FNUM = PHAT(J)*R(I)+FNUM
1 DENOM = DENOM+PHAT(J)*R(J)
PHATN(I) = (R(I)-FNUM)/(1.-DENOM)
PAUTO(I) = PHATN(I)
DO 2 J=1,L
K = I-J
2 PHATN(J) = PHAT(J)-PHATN(I)*PHAT(K)
DO 3 J=1,I
3 PHAT(J) = PHATN(J)
4 CONTINUE
RETURN
END
    
```

1	120	4	FILTERABLE		FILTERABLE	
			FLOW (GAL/MIN)	RF TKN (MG/L)	LOADING (GM/DAY)	EFF TKN (MG/L)
X	Y	Z	W			
1.00	22.20	145.45	1.00			
1.00	23.10	151.35	0.70			
1.00	25.60	167.73	0.60			
1.00	22.70	148.73	1.00			
1.00	20.40	133.66	0.70			
1.00	24.90	163.14	0.90			
2.00	20.70	271.25	1.30			
2.00	13.30	174.28	2.70			
2.00	12.70	166.42	3.30			
2.00	11.40	149.39	3.10			
2.00	9.00	117.94	1.70			
2.00	8.80	115.32	1.10			
2.00	15.10	197.87	2.90			
2.00	23.90	313.19	3.30			
2.00	24.30	318.43	7.20			
2.00	22.50	294.84	8.00			
2.00	21.50	286.98	9.40			
2.00	20.90	273.87	10.10			
1.00	21.60	141.52	11.70			
1.00	35.10	229.98	12.20			
1.00	33.90	222.11	13.10			
1.00	28.70	188.04	13.70			
1.00	27.20	178.21	14.00			
1.00	35.50	232.67	11.40			
2.00	37.80	495.33	12.30			
2.00	14.30	187.39	10.90			
2.00	14.60	191.32	7.20			
2.00	11.20	146.76	4.90			
2.00	12.90	169.04	2.60			
2.00	17.10	184.77	1.60			
1.00	16.40	107.45	3.40			
1.00	18.40	120.56	5.90			
1.00	16.10	105.49	5.40			
1.00	13.90	91.07	9.40			
1.00	9.90	64.86	9.20			

TABLE F6 (Cont'd)

1.00	8.50	57.66	5.00
1.00	19.50	127.76	5.60
1.00	17.50	95.00	6.50
1.00	17.00	113.35	2.60
1.00	14.00	91.73	2.00
1.00	14.50	94.35	1.70
1.00	14.00	91.73	1.40
2.00	13.50	176.90	1.50
2.00	19.50	383.95	4.10
2.00	25.40	332.84	9.20
2.00	22.30	292.22	10.80
2.00	18.50	247.67	10.50
2.00	25.10	328.91	9.90
1.00	22.40	146.76	10.40
1.00	12.00	78.62	7.50
1.00	6.50	42.59	5.00
1.00	5.30	34.73	1.40
1.00	4.00	26.21	1.20
1.00	5.50	36.64	1.10
1.00	6.00	39.31	1.00
1.00	9.00	58.97	1.10
1.00	12.00	78.62	1.20
1.00	12.10	79.28	1.20
1.00	10.00	65.52	1.10
1.00	6.00	39.31	2.50
2.00	2.00	26.21	6.50
2.00	3.50	45.86	2.50
2.00	5.00	65.52	1.40
2.00	6.70	87.80	1.20
2.00	6.00	78.62	1.10
2.00	5.00	65.52	1.00
2.00	4.20	55.14	1.00
2.00	8.00	104.83	1.00
2.00	12.00	157.29	1.00
2.00	14.80	193.94	1.40
2.00	12.00	157.29	1.80
2.00	13.50	176.90	1.50
1.00	16.90	110.73	1.20
1.00	25.50	167.08	1.00
1.00	29.00	190.01	1.00
1.00	26.00	170.35	2.20
1.00	27.00	176.90	4.00
1.00	26.00	170.35	5.60
1.00	22.40	146.76	5.40
1.00	28.00	183.46	6.50
1.00	29.50	193.28	7.20
1.00	28.40	186.08	8.10
1.00	29.00	190.01	8.50
1.00	31.00	203.11	9.00
2.00	33.10	433.74	9.40
2.00	32.50	425.88	13.60
2.00	27.00	353.81	14.50
2.00	19.20	251.60	14.80
2.00	26.00	340.70	15.50
2.00	30.50	399.67	16.00
2.00	31.50	412.78	18.40
2.00	21.50	281.74	16.50
2.00	16.00	209.66	14.00
2.00	14.50	194.01	10.00
2.00	13.50	176.90	7.00
2.00	20.00	262.08	7.00
1.00	13.00	85.18	9.90
1.00	12.40	81.24	17.10
1.00	11.00	77.97	8.60
1.00	10.50	68.80	2.10
1.00	12.00	78.62	1.00
1.00	16.20	66.83	0.90
2.00	10.80	141.52	0.90
2.00	17.70	231.94	0.80
2.00	15.90	208.35	3.30
2.00	16.20	212.28	4.70
2.00	10.90	142.83	6.20
2.00	11.10	145.45	6.70
1.00	22.70	148.73	7.20
1.00	18.70	122.52	8.80

TABLE F6 (Cont'd)

1.00	14.20	33.04	8.60
1.00	13.90	31.07	8.20
1.00	13.60	33.11	7.30
1.00	11.60	76.00	6.60
2.00	11.40	136.28	5.80
2.00	15.90	208.35	5.70
2.00	15.70	205.73	7.50
2.00	14.50	196.01	8.10
2.00	9.40	123.10	7.20
2.00	9.80	128.42	5.00

Z MEAN	W MEAN
166.677	5.834

NON-LINEAR ESTIMATION, PROBLEM NUMBER 1
 120 OBSERVATIONS, 4 PARAMETERS 636 SCRATCH REQUIRED

INITIAL PARAMETER VALUES
 $0.7606E+00$ $0.1390E-01$ $0.1063E+01$ $0.3200E+00$

INITIAL SUM OF SQUARES = $0.2962E+03$

DETERMINANT = $0.2289E+00$ ITERATION NO. 1
 ANGLE IN SCALED COORD. = 37.19 DEGREES

TEST POINT PARAMETER VALUES
 $0.7815E+00$ $0.1066E-01$ $0.1056E+01$ $0.3217E+00$
 TEST POINT SUM OF SQUARES = $0.2925E+03$

PARAMETER VALUES VIA REGRESSION
 $0.7815E+00$ $0.1066E-01$ $0.1056E+01$ $0.3217E+00$

LAMBDA = $0.100E-02$ SUM OF SQUARES
 AFTER REGRESSION = $0.2924856E+03$

DETERMINANT = $0.2120E+00$ ITERATION NO. 2
 ANGLE IN SCALED COORD. = 49.00 DEGREES

TEST POINT PARAMETER VALUES
 $0.7899E+00$ $0.1066E-01$ $0.1065E+01$ $0.3353E+00$
 TEST POINT SUM OF SQUARES = $0.2924E+03$

PARAMETER VALUES VIA REGRESSION
 $0.7899E+00$ $0.1066E-01$ $0.1065E+01$ $0.3353E+00$

LAMBDA = $0.100E-03$ SUM OF SQUARES

TABLE F6 (Cont'd)

ITERATION NO. 3
 DETERMINANT = 0.2111E+00 ANGLE IN SCALED COORD. = 39.90 DEGREES

TEST POINT PARAMETER VALUES
 0.7863E+00 0.1062E-01 0.1066E+01 0.3355E+00

TEST POINT SUM OF SQUARES = 0.2924E+03

PARAMETER VALUES VIA REGRESSION

0.7863¹E+00 0.1062²E-01 0.1066³E+01 0.3355⁴E+00

LAMBDA = 0.100E-04

SUM OF SQUARES

AFTER REGRESSION = 0.2924019E+03

ITERATION NO. 4
 DETERMINANT = 0.2109E+00 ANGLE IN SCALED COORD. = 49.56 DEGREES

TEST POINT PARAMETER VALUES
 0.7864E+00 0.1062E-01 0.1066E+01 0.3358E+00

TEST POINT SUM OF SQUARES = 0.2924E+03

PARAMETER VALUES VIA REGRESSION

0.7864¹E+00 0.1062²E-01 0.1066³E+01 0.3358⁴E+00

LAMBDA = 0.100E-05

SUM OF SQUARES

AFTER REGRESSION = 0.2924018E+03

ITERATION STOPS - RELATIVE CHANGE IN EACH PARAMETER LESS THAN 0.1000E-02

FINAL RESIDUAL VALUES

0.0000E+00	0.0000E+00	0.0000E+00	-0.3706E+00	-0.7699E+00	-0.2332E+00
-0.6024E+00	-0.6801E+00	-0.1696E+00	-0.9410E+00	-0.1805E+01	-0.7151E+00
0.1195E+01	-0.1365E+01	0.1771E+01	-0.1237E+01	0.6870E+00	0.1422E-01
0.1355E+01	0.1083E+01	0.1210E+01	0.1506E+01	0.1804E+01	-0.9048E+00
0.2308E+01	-0.3504E+01	-0.1388E+01	-0.1516E+01	-0.2015E+01	-0.1625E+01
0.4848E+00	0.1663E+01	0.1666E+01	0.1367E+01	0.9666E+00	0.6848E+00
-0.4238E+00	-0.3872E-01	-0.9321E+00	-0.1885E+00	-0.1785E+00	-0.4555E+00
-0.7683E-01	0.1419E+01	0.1852E+01	0.4655E-01	0.3877E+00	0.2687E-01
-0.3241E-01	-0.1518E+01	-0.6971E+00	-0.2296E+01	0.6633E+00	-0.1747E+00
-0.2055E+00	0.9772E-01	-0.4669E-01	-0.1996E+00	-0.1835E+00	0.1471E+01
0.4183E+01	-0.3533E+01	0.7713E+00	0.3020E+00	-0.1159E+00	-0.2428E-01
0.1243E+00	0.1460E+00	0.4113E+00	0.4051E+00	0.7251E+00	0.9122E+00
-0.1202E+01	-0.4768E+00	-0.1226E+01	-0.1405E+00	0.6105E+00	-0.9791E-01
-0.9722E-01	4E+01	0.3015E+00	0.8466E+00	0.5955E+00	0.8723E+00

0.7261E+00	0.1637E+01	0.1699E+01	0.5122E+00	0.2034E+01	0.5440E+00
0.2335E+01	-0.1980E+01	-0.3544E+00	-0.2060E+01	-0.1579E+01	0.5000E+00
0.1587E+01	0.7951E+01	-0.7740E+01	-0.2527E+01	0.7058E+00	-0.3968E+00
-0.3846E+00	-0.1263E+01	0.6943E+00	-0.1245E+00	0.4766E+00	0.5203E+00
0.6919E+00	0.1934E+01	0.7080E+00	0.8957E+00	0.6124E+00	0.7559E+00
-0.5912E+00	0.4780E+00	0.1584E+01	0.4413E+00	0.4404E+00	-0.9111E+00

CORRELATION MATRIX

	1	2	3	4
1	1.0000			
2	-0.6074	1.0000		
3	0.1185	-0.1492	1.0000	
4	0.1299	-0.0645	0.8063	1.0000

NORMALIZING ELEMENTS

1	2	3	4
0.3334E-01	0.1239E-02	0.5590E-01	0.5527E-01

VARIANCE OF RESIDUALS = 0.2521E+01, 116 DEGREES OF FREEDOM

INDIVIDUAL CONFIDENCE LIMITS FOR EACH PARAMETER (ON LINEAR HYPOTHESIS)

1	2	3	4
0.8922E+00	0.1455E-01	0.1243E+01	0.5113E+00
0.6805E+00	0.6683E-02	0.8883E+00	0.1603E+00

AUTO AND PARTIAL CORRELATIONS OF THE RESIDUALS

I	AUTO	PARTIAL
1	-0.029	-0.029
2	0.037	0.036
3	-0.008	-0.006
4	-0.021	0.022
5	0.004	0.003
6	-0.177	-0.176
7	0.043	0.034
8	-0.102	-0.091
9	-0.084	-0.097
10	-0.034	-0.041
11	-0.103	-0.108
12	0.160	0.062
13	-0.032	-0.018
14	-0.065	-0.119
15	-0.072	-0.111

APPROX. 95 PERCENT CONF. LIMIT ON CORRELATIONS = 0.183

CHI-SQUARED STATISTIC = 10.28
 BASED ON (15 - NO. OF STOCHASTIC PARAMETERS) DEGREES OF FREEDOM

with $k+1 - (r+s+1)$ degrees of freedom where $(r+s+1)$ is the number of parameters in the transfer function model. Applying these methods led to the final form of the TF-N models (Table 14).

Effect of Altering Sampling Interval on TF-N Models

The optimal choice of the sampling interval is an important consideration when dealing with process control. In this regard McGregor (1976) has presented a procedure whereby given a discrete dynamic-stochastic model based on a given sampling interval, the alteration in the form and the parameters of the model can be determined for a new sampling interval. The approach is illustrated below for the linear dynamic-stochastic model developed to describe the effluent filterable TKN from the combined sludge system (Table 14) and leads to the new model form given in Table 15. A similar procedure was employed for determination of the new separate sludge effluent filterable TKN model.

Combined-sludge effluent TKN TF-N model for new sampling interval

The original TF-N model was developed on the basis of a two hour sampling interval. In order to utilise the model for forecasting purposes, with respect to experiments D3 and D4, the form of the model and the parameters must be altered to account for a sampling interval of three hours. The stochastic portion of the original TF-N model is given by the autoregressive model

$$(1 - 1.066\beta + 0.336\beta^2) N_t = a_t \quad \dots\dots\dots(50)$$

with autoregressive parameters

$$\phi_{2hr}^1 = 1.066$$

$$\phi_{2hr}^2 = -0.336$$

by calculating the reciprocal of the roots of

$$(1 - 1.066\beta + 0.336\beta^2) = 0 \quad \dots\dots\dots(51)$$

given by G_1 and G_2 the new parameter values can be determined from

$$\phi_{3hr}^1 = G_1^h + G_2^h \quad \dots\dots\dots(52)$$

$$\phi_{3hr}^2 = G_1^h G_2^h \quad \dots\dots\dots(53)$$

where h is the number of times the basic sampling interval is increased ($h = 3/2$). By carrying out this procedure the new stochastic model was determined to be

$$(1 - 0.7254\beta + .1949\beta^2) N_t = a_t \quad \dots\dots\dots(54)$$

The original transfer function model is also affected by the change in sampling interval. By assuming that the discrete transfer function model is a discretely coincident representation of an underlying continuous process of corresponding order, one can show using modified Z - transforms how the parameters of the model will change with sampling interval (Box and Jenkins, 1970 d). The original TF model is first order in nature and of the form

$$Y_t = \frac{0.001}{1 - 0.786\beta} X_{1,t-1} \quad \dots\dots\dots(55)$$

with parameters

$$\delta_{2hr} = 0.786$$

$$\omega_{2hr} = 0.011$$

For the new sampling interval the parameter values can be determined from

$$\delta_{3hr} = \delta_{2hr}^h \quad \dots\dots\dots(56)$$

$$\omega_{3hr} = \frac{\omega_{2hr}(1 - \delta_{2hr}^h)}{1 - \delta_{2hr}} \quad \dots\dots\dots(57)$$

These calculations lead to the new TF model given by

$$Y_t = \frac{0.0156}{1 - 0.697\beta} X_{1,t-1} \quad \dots\dots\dots(58)$$

Forecasting and Simulation Procedures

Forecasting system response to impulse forcings

The forecasted effluent values in experiments D3 and D4 were determined by using the "difference" forms of the TF-N models (three-hour interval) together with the observed values of the input variable, filterable TKN loading (X_1). Details of the computation methods are outlined elsewhere (Box and Jenkins, 1970C). To briefly illustrate the procedure reference will be made to experiment D3 and the combined sludge system results (Figure 26).

In order to forecast the initial effluent TKN results, past values of the influent variable (X_1) as well as the effluent TKN are necessary. By beginning the forecast following the baseline day of the experiment these values were then available. The form of the TF-N model forecast equation also requires past values for the residuals (a_t 's), the difference between the observed and model results. These residuals were determined by fitting the TF-N model to the baseline day influent conditions and thereby determining model effluent values. Comparing the observed and model results allows determination of the residuals for the baseline day of the experiment. A computer program was written to carry out the above calculations and determine the forecast results (Table F7):

Predicting responses to simulated input conditions

In order to utilize the transfer function (TF) and the TF-N models to predict the response of the combined and separate sludge systems to natural input conditions, the baseline day influent variations encountered in experiments D3 and D6 were simulated. Each simulation involved approximating the three-hour sampling results as a continuous record and then picking off discrete two-hour interval results. These results were used in conjunction with the TF and TF-N models (two-hour interval) to predict effluent results. As in the case with forecasting, the initial TF results are influenced by past values of the influent

TRANSFER FUNCTION - NOISE MODEL FORECASTING PROGRAM - RUN 03
 FILTERABLE EFFLUENT TKN, SSC SLUDGE SYSTEM

DIMENSION A(5,50),X(50),Y(50),T(50)
 COMMON Z(50),W(50),TH(20),R(50)
 CALL FORMS(1)
 DATA NOB/177,NAB/77,NIR/11/
 NUB=NAB+2

IDENTIFY INPUT
 X = FLOW(GAL/MIN)
 Y = FILTERABLE RAW FEED TKN(MG/L)
 W = FILTERABLE EFFLUENT TKN(MG/L)
 NP = NUMBER OF TH VALUES
 R = TIME(HRS)

READ 4,IX,IY,IW,NP,IR
 4 FORMAT(5I2)
 PRINT 6,IX,IY,IW,NP,IR
 6 FORMAT(1H1,5I2)

A7 = MEAN LOADING FROM EXPERIMENT 05 (GM/DAY)
 AW = MEAN FILTERABLE EFFLUENT TKN FROM EXPERIMENT 05 (MG/L)

READ 82,AZ,AW
 82 FORMAT(1GX,F7.3,2X,F5.3)
 PRINT 84
 64 FORMAT(///// ,19X,30HMEAN VALUES FROM EXPERIMENT 05,///
 PRINT 86,AZ
 86 FORMAT(20X,19HLOADING (GM/DAY) = ,F7.3,/
 PRINT 87,AW
 87 FORMAT(20X,31HFILTERABLE EFFLUENT A (MG/L) = ,F5.3,//////////)

READ IN MODEL PARAMETERS

READ 2,(TH(I),I=1,NP)
 2 FORMAT(F6.4)
 PRINT 3
 3 FORMAT(3X,28HINPUT MODEL PARAMETER VALUES)
 DO 98 J=1,NP
 PRINT 97,TH(J),J
 97 FORMAT(10X,F10.4,2X,3HTH(,I2,1H))
 98 CONTINUE

READ IN DATA

READ 1,((A(I,J),I=1,5),J=1,NOB)
 1 FORMAT(3X,F4.1,2X,F3.1,F6.1,F6.1,F7.1)
 PRINT 20
 20 FORMAT(/// ,8X,1HX,15X,1HY,14X,14Z,14X,1HW,12X,1HR)
 PRINT 23
 23 FORMAT(/ ,19X,10HFILTERABLE,22X,10HFILTERABLE)
 PRINT 21
 21 FORMAT(2X,14HFLOW (GAL/MIN),2X,12HRF TKN(MG/L),2X,
 15HLOADING (GM/DAY),2X,13HEFF TKN(MG/L),2X,9HTIME (HRS))
 DO 5 K=1,NOB
 X(K)=A(IX,K)
 Y(K)=A(IY,K)
 W(K)=A(IW,K)
 R(K)=A(IR,K)
 Z(K)=(X(K)*Y(K))*E.552
 PRINT 10,(X(K),Y(K),Z(K),W(K),R(K))
 10 FORMAT(7X,F4.2,6X,F10.2,5X,F10.2,5X,F10.2,4X,F10.2)
 5 CONTINUE
 DO 81 K=1,NOB
 Z(K)=Z(K)-AZ
 W(K)=W(K)-AW
 81 CONTINUE

CALCULATION OF RESIDUALS FOR FIRST 9 VALUES (24 HR PERIOD)

T(1)=0.0
 T(2)=0.0
 T(3)=0.0

```

PRINT 14
14 FORMAT(///,6X,9HRESIDUALS,/)
DO 15 I=1,7
PRINT 99,I,T(I)
87 FORMAT(5X,2HT(,I2,1H),F6.2)
88 CONTINUE
DO 100 I=4,NUB
T(I)=(TH(1)*T(I-1))+W(I)-(TH(2)*W(I-1))
1+(TH(3)*W(I-2))-(TH(1)*W(I-1))+(TH(2)+TH(1)*W(I-2))
1-(TH(2)+TH(1)*W(I-3))-(TH(4)+Z(I-1))
1+(TH(2)+TH(4)+Z(I-2))-(TH(3)+TH(4)+Z(I-3))
PRINT 11,I,T(I)
11 FORMAT(5X,2HT(,I2,1H),F6.2)
TC=T(NUB)*(-0.597)
100 CONTINUE

```

CALL FORECAST CALCULATION SUBROUTINE FROT .

CALL FROT(NCP,NIB,TO,NAB,AW)
 EN)

SUBROUTINE FROT(NOB,NIB,T,NAB,AW)

FORECAST CALCULATION

```

DIMENSION S(50),TA(50),TD(50),WT(50),WS(10)
COMMON Z(50),W(50),TH(20),P(50)
I=0
DO 20 J=NAB,NOB
I=I+1
S(I)=Z(J)
20 CONTINUE
TA(1)=W(NAB)
TA(2)=W(NAB+1)
TA(3)=W(NAB+2)
PRINT 30
30 FORMAT(////////,5X,45HYN = FORECASTED EFFLUENT FILTERABLE TKN VALUE
1,/,5X,36HY = OBSERVED EFFLUENT FILTERABLE TKN,/,5X,55HBARY = MEAN
2EFFLUENT FILTERABLE TKN VALUE EXPERIMENT 05,////////)
PRINT 14
14 FORMAT(18X,8HFORECAST,16X,8HOBSEPED,/)
PRINT 13
13 FORMAT(14X,2HYN,3X,7HYN-BARY,15X,6HY-BARY,8X,1HY,3X,9HTIME(HPS),/)
LL=NAB+2
DO 11 L=NAB,LL
WS(L)=W(L)+AW
PPINT 12,WS(L),W(L),W(L),WS(L),P(L)
12 FORMAT(12X,F6.2,2X,F6.2,16X,F6.2,5X,F6.2,5X,F4.1)
11 CONTINUE
K=NAB+2
N=0

```

FORECASTING NEXT 8 VALUES

```

DO 100 J=4,NIB
TA(J)=(TH(2)*TA(J-1))-(TH(3)*TA(J-2))+(TH(1)*TA(J-1))
1-(TH(2)*TH(1)*TA(J-2))+(TH(3)*TH(1)*TA(J-3))
1+(TH(4)*S(J-1))-(TH(2)*TH(4)*S(J-2))+(TH(3)*TH(4)*S(J-3))
K=K+1
IF(J.GT.4) GO TO 7
IF(J.EQ.4) GO TO 5
5 CONTINUE
TA(4)=TA(4)+T
7 N=N+1
WT(K)=W(K)+AW
TC(J)=TA(J)+AW
100 PRINT 6,TD(J),TA(J),N,W(K),WT(K),R(K)
6 FORMAT(12X,F6.2,2X,F6.2,5X,4HT=,I2,5X,F6.2,5X,F6.2,5X,F4.1)
RETURN
END

```

FINIS

MEAN VALUES FROM EXPERIMENT 05

LOADING (GM/DAY) = 166.677

FILTERABLE EFFLUENT A (MG/L) = 5.850

INPUT MODEL PARAMETER VALUES

C.6970 TH(1)
 C.7254 TH(2)
 C.1950 TH(3)
 0.0156 TH(4)

X	Y	Z	W	R
FLOW (IGAL/MIN)	FILTERABLE RF TKN (MG/L)	LOADING (GM/DAY)	FILTERABLE EFF TKN (MG/L)	TIME (HRS)
1.00	5.70	37.35	1.70	0.00
1.00	15.70	102.87	1.00	3.00
1.00	10.30	67.49	1.20	6.00
1.00	9.10	59.62	1.10	9.00
1.00	7.20	47.17	1.20	12.00
1.00	7.10	46.52	1.00	15.00
1.00	7.80	51.11	1.10	18.00
1.00	4.30	28.17	0.90	21.00
2.00	4.10	53.73	1.30	24.00
2.00	17.20	225.39	0.90	27.00
2.00	15.50	203.11	3.70	30.00
2.00	11.10	145.45	4.30	33.00
1.00	9.60	62.90	3.00	36.00
1.00	9.00	58.97	1.20	39.00
1.00	9.30	60.93	0.70	42.00
1.00	6.20	40.62	0.60	45.00
1.00	5.50	36.04	1.00	48.00

RESIDUALS

T	RESIDUAL
T(1)	0.00
T(2)	0.00
T(3)	0.00
T(4)	0.25
T(5)	0.42
T(6)	0.32
T(7)	0.61
T(8)	0.27
T(9)	1.23

YN = FORECASTED EFFLUENT FILTERABLE TKN VALUE
 Y = OBSERVED EFFLUENT FILTERABLE TKN
 BARY = MEAN EFFLUENT FILTERABLE TKN VALUE EXPERIMENT 05

FORECAST		OBSERVED	
YN	YN-BARY	Y-BARY	Y TIME (HRS)
1.10	-4.75	-4.75	1.10
0.90	-4.95	-4.95	0.30
1.30	-4.55	-4.55	1.30
0.85	-5.05	-4.95	0.90
2.95	-2.90	-2.15	3.70
4.21	-1.64	-1.55	4.30
4.30	-1.55	-2.85	3.00
3.13	-2.72	-4.65	1.20
2.27	-3.58	-5.15	0.70
1.71	-4.14	-5.25	0.60
1.00	-4.85	-4.85	1.00

T= 1
T= 2
T= 3
T= 4
T= 5
T= 6
T= 7
T= 8

variables and effluent results but in this case these values are unknown. This problem was overcome by assuming the influent variation over the 24 hour period was repeatable. This procedure, together with assuming initial values for the past effluent results, allowed the simulation to be carried out. By extending the computation for a number of repeatable influent sequences the results stabilized to the final predicted effluent sequence, independent of the initially assumed effluent values. In determining the TF-N model results, in addition to the requirement for past effluent and influent values a series of values for the white noise sequence (a_t 's) is required. This series was generated using a random numbers routine. The mean of the series was specified as zero and the standard deviation was set equal to the standard deviation of the residuals determined during the TF-N model development (experiment D5). The computer program developed to carry out the above computations and generate the stable predicted effluent results is illustrated in Table F8. for a particular example.

TABLE F8 PROGRAM TO DETERMINE TRANSFER FUNCTION-NOISE MODEL PREDICTIONS
FOR SIMULATED INPUT CONDITIONS

369

DIMENSION TY(100), TT(100), TX(100), KA(100), V(100), VX(100)

TRANSFER FUNCTION - NOISE MODEL SIMULATION PROGRAM

~~BASELINE 06 INPUT CONDITIONS~~

COMPUTATIONS FOR SSC SLUDGE SYSTEM - FILTERABLE EFFLUENT TKN (2 HR MODEL
(FIG. 35)

IDENTIFY PARAMETERS

TY = PREDICTED FILTERABLE EFFLUENT TKN(MG/L) MINUS MEAN

VX = PSEUDO-RANDOM NUMBER, OBTAINED FROM G.C.I.W. COMPUTER LIBRARY
SUBROUTINE GAUSS. THIS SUBROUTINE COMPUTES A NORMALLY DISTRIBUTED RANDOM
NUMBER WITH A GIVEN MEAN OF 0.6 AND A STANDARD DEVIATION OF 1.5877

TX = RAW SEWAGE FILTERABLE TKN LOADING(GM/DAY)

TT = PREDICTED FILTERABLE EFFLUENT TKN(MG/L)

KA = HOUR OF PREDICTED FILTERABLE EFFLUENT TKN

```

DO 4 J=1,99
READ 1, TX(J), KA(J)
1 FORMAT(2X, F8.3, 2X, I4)
4 CONTINUE
PRINT 1J
17) FORMAT(10X, 42HR RAW SEWAGE FILTERABLE TKN LOADING SEQUENCE, //)
DO 12 J=1,12
PRINT 11, TX(J), KA(J)
11 FORMAT(19X, F8.3, 2X, I4)
12 CONTINUE
DO 102 I=1,37
READ 5, V(I)
5 FORMAT(2X, F5.2)
102 CONTINUE
DO 101 I=1,37
VX(I+2)=V(I)
101 CONTINUE
PRINT 15
15 FORMAT(//, //, 10X, 36RANDOM NUMBER SEQUENCE FOR RESIDUALS, //)
DO 13 J=3,14
PRINT 14, VX(J), J
14 FORMAT(10X, F5.2, 2X, 3HVX(, I2, I1))
13 CONTINUE
PRINT 16
16 FORMAT(//, //, 10X, 33HPREDICTED FILTERABLE EFFLUENT TKN, //)

```

INITIAL ESTIMATE OF PREDICTED FILTERABLE EFFLUENT(MG/L) MINUS MEAN

TY(1)=3.05

TY(2)=2.65

TY(3)=1.15

```

DO 100 J=4,99
TY(J)=VX(J)-(0.786*VX(J-1))+(1.066*TY(J-1))-(0.336*TY(J-2))
1+(0.786*TY(J-1))-(1.066*0.786*TY(J-2))+(0.336*(0.786*TY(J-3)))
1+(0.011*TX(J-1))-(1.066*0.011*TX(J-2))+(0.336*0.011*TX(J-3))
TT(J)=TY(J)+5.85
100 CONTINUE
PRINT 19
19) FORMAT(6X, 3HTKN, 5X, 2HHR, 8X, 3HTKN, 4X, 24HR //)
PRINT 18, (TT(J), KA(J), J=4,99)
18 FORMAT(2(F10.2, 3X, I4) //)
END

```

RAW SEWAGE FILTERABLE TKN LOADING SEQUENCE

-25.677	330
-34.677	500
-46.677	700
-81.677	900
-32.677	1100

36.323	1500
33.323	1700
23.323	1900
11.323	2100
13.323	2300
3.323	100

RANDOM NUMBER SEQUENCE FOR RESIDUALS

-0.47	VX(3)
-1.52	VX(4)
-1.54	VX(5)
-0.96	VX(6)
-0.23	VX(7)
3.46	VX(8)
-1.55	VX(9)
0.44	VX(10)
0.58	VX(11)
-1.54	VX(12)
-0.30	VX(13)
0.50	VX(14)

PREDICTED FILTERABLE EFFLUENT TKN

TKN	HR	TKN	HR
5.32	900	2.51	1100
2.37	1300	3.22	1500
7.91	1700	7.41	1900
7.37	2100	7.88	2300
6.11	100	5.12	300
4.24	500	3.65	700
3.10	900	1.23	1100
1.70	1300	2.91	1500
7.77	1700	7.36	1900
7.34	2100	7.86	2300
6.08	100	5.09	300
4.22	500	3.63	700
3.12	900	1.24	1100
1.71	1300	2.92	1500
7.78	1700	7.36	1900
7.34	2100	7.86	2300
6.09	100	5.10	300
4.22	500	3.63	700
3.10	900	1.23	1100
1.70	1300	2.91	1500
7.77	1700	7.36	1900
7.34	2100	7.86	2300
6.08	100	5.09	300
4.22	500	3.63	700

APPENDIX G

Abbreviations and Symbols

Abbreviations and symbols appearing in this report, not commonly used or not defined within the report are listed on the following pages.

They are arranged according to where they appear in the report.

Abbreviations and symbols appearing in "Data Listing"

Appendix B:

MON	- month
OPERATING MODE	- reactor system under operation; 1 - SSC 2 - TSS 3 - TSC 4 - FSC
SSC	- single-stage combined sludge system
TSS	- two-stage separate sludge system
TSC	- two-stage combined sludge system
FSC	- five-stage combined sludge system
SSRT	- system solids retention time (days)
TEMP	- temperature ($^{\circ}\text{C}$)
SS	- suspended solids (mg/l)
HACH NH_3N	- ammonia - nitrogen determination by HACH Chemical Co. method
ALK	- alkalinity as CaCO_3 (mg/l)
APPROX	- approximately
MLSS	- mixed liquor suspended solids (mg/l)
VSS	- mixed liquor volatile suspended solids (mg/l)
WASTE CONC	- concentration of solids wasted (mg/l)
IGAL WASTE	- imperial gallons of solids wasted
30 MIN SET	- settled volume of 1000 ml of mixed liquor after 30 min. (ml)

DO	- dissolved oxygen (mg/l)
OUR	- mixed liquor oxygen uptake rate (mg O ₂ /g-hr)
REACTOR	- aeration tank of reactor system referred to; A - SSC system A1- first-stage of TSC system A2- second-stage of TSC system B1- first-stage of TSS system or FSC system B2- second-stage of TSS system B3- third-stage of FSC system B5- fifth-stage of FSC system
RF	- raw sewage
-0900	- time sample taken
-GAM	- grab sample taken in AM
-GPM	- grab sample taken in PM
-C	- composite of 24 hr. by hr. samples
-C1	- composite of 0900, 1000, and 1100 hour samples
-C2	- composite of 1200, 1300, and 1400 hour samples
-C3	- composite of 1500, 1600, and 1700 hour samples
-C4	- composite of 1800, 1900, and 2000 hour samples
-C5	- composite of 2100, 2200, and 2300 hour samples
-C6	- composite of 2400, 0100, and 0200 hour samples
-C7	- composite of 0300, 0400, and 0500 hour samples
-C8	- composite of 0600, 0700, and 0800 hour samples
-CC1	- composite of samples from 0900 to 1600 hr.

-CC2	- composite of samples from 1700 to 2400 hours
-CC3	- composite of samples from 0100 to 0800 hours
EA1	- sample from aeration tank A1
EA2	- clarified effluent sample from TSC system
EA	- clarified effluent sample from SSC system
EB1	- clarified effluent sample from first-stage of TSS system
EB2	- clarified effluent sample from second-stage of TSS system
EB*	- clarified effluent from FSC system
MLA	- mixed liquor sample from aeration tank A
MLA1	- mixed liquor sample from aeration tank A1
MLA2	- mixed liquor sample from aeration tank A2
MLB1	- mixed liquor sample from aeration tank B1
MLB2	- mixed liquor sample from aeration tank B2
MLB1*	- mixed liquor sample from first-stage of FSC system
MLB3*	- mixed liquor sample from third-stage of FSC system
MLB5*	- mixed liquor sample from fifth-stage of FSC system
COD	- chemical oxygen demand (mg/l)
BOD	- five-day, 20 ⁰ C biochemical oxygen demand (mg/l)
TKN	- total kjeldahl nitrogen (mg/l)

FOC	- filtered organic carbon (mg/l)
NH ₄ N	- ammonia plus ammonium-nitrogen (mg/l)
NO ₃ N	- nitrate-nitrogen (mg/l)
NO ₂ N	- nitrite-nitrogen (mg/l)

Other abbreviations and symbols appearing throughout the report:

SRT	- solids retention time (days)
PSS-1	- pseudo "steady-state" run number 1
D/uL	- dimensionless dispersion number
u	- velocity (L/T)
L	- length (L)
D	- dispersion coefficient (L ² /T)
ANOVA	- analysis of variance
D-1	- dynamic or non-steady run number 1
HRT	- hydraulic residence time